

## 2<sup>nd</sup> Quarter Water Quality Monitoring

SAMPLE POINT IDENTIFICATION					PARAMETERS AND RESULTS				
Distribution System Location Number	Sample Point Name & Address	Sample Date	Time	Temperature (°C)	Conductivity (mS)	pH (s.u)	Total Alkalinity (mg/L CaCO <sub>3</sub> )	Calcium (mg/L Ca <sup>2+</sup> )	Phosphate (mg/L PO <sub>4</sub> )
#1	Davison Rd	6/21		17.3	0.23	7.30	76	32.9	3.29
#2	E. Court St	6/21		16.5	0.23	7.33	76	32.1	3.12
#3	S. Dort Hwy	6/21		17.3	0.23	7.40	76	33.7	3.17
#4	Corunna Rd	6/21		17.0	0.23	7.50	74	32.1	3.52
#5	Chevrolet Ave	6/21		18.3	0.23	7.44	74	32.9	3.21
#6	M.L.K. Jr Blvd	6/21		20.8	0.24	7.49	74	32.9	2.91
#7	Clio Rd	6/21		16.5	0.23	7.40	74	35.3	3.12
#8	N. Saginaw St	6/21		17.7	0.23	7.38	76	32.9	3.13
CS	Cedar Street Res.	6/21		15.2	0.23	7.57	74	34.5	3.52
WS	West Side Res.	6/21		15.7	0.23	7.55	74	33.7	3.19
1A	Richfield Rd	6/24	1117	20.6	0.23	7.36	76	31.3	3.36
2A	E. Court St	6/22	1226	18.8	0.23	7.33	74	33.7	3.27
3A	S. Dort Hwy	6/24	1230	20.8	0.22	7.33	75	30.5	2.95
4A	S. Dort Hwy	6/24	1204	19.7	0.22	7.32	74	30.5	3.05

## 2<sup>nd</sup> Quarter Water Quality Monitoring

SAMPLE POINT IDENTIFICATION					PARAMETERS AND RESULTS				
Distribution System Location Number	Sample Point Name & Address	Sample Date	Time	Temperature (°C)	Conductivity (mS)	pH (s.u)	Total Alkalinity (mg/L CaCO <sub>3</sub> )	Calcium (mg/L Ca <sup>2+</sup> )	Phosphate (mg/L PO <sub>4</sub> )
5A	S. Dort Hwy	6/24	1143	19.4	0.21	7.31	74	29.7	3.14
6A	Flint City Hall	6/22	1127	19.7	0.24	7.38	74	32.1	3.39
7A	Flint Public Library	6/22	1145	20.6	0.25	7.57	74	33.7	2.83
1B	Clio Rd	6/22	1003	20.5	0.23	7.27	78	33.7	3.05
2B	Ballenger Hwy	6/22	1022	19.9	0.23	7.43	78	32.9	3.41
3B	Corunna Rd	6/22	1046	18.6	0.23	7.29	82	32.9	3.31
4B	Hogarth Ave	6/21	1020	18.7	0.22	7.44	74	34.5	2.95
5B	Van Slyke Rd	6/21	0955	20.4	0.22	7.41	74	35.3	2.89
6B	Fenton Rd	6/21	1110	19.7	0.22	7.37	76	33.7	2.98
7B	W. 12 <sup>th</sup> St	6/21	0932	22.9	0.22	7.41	74	35.3	3.19
8B	W. Court St	6/21	1050	19.5	0.22	7.33	76	33.7	1.86