



3rd Quarter Distribution Quality Monitoring

SAMPLE POINT IDENTIFICATION					PARAMETERS AND RESULTS				
Distribution System Location Number	Sample Point Name & Address	Sample Date	Time	Temperature (°C)	Conductivity (mS)	pH (s.u)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Phosphate (mg/L PO ₄)
#1	Davison Rd	9/13/16	0911	21.5	0.23	7.43	72	34.5	3.08
#2	E. Court St	9/13/16	0935	22.1	0.23	7.40	72	34.5	3.06
#3	S. Dort Hwy	9/13/16	0956	21.7	0.23	7.39	70	35.3	3.11
#4	Corunna Rd	9/13/16	1046	21.6	0.23	7.50	70	35.3	3.09
#5	Chevrolet Ave	9/13/16	1108	22.1	0.23	7.41	70	35.3	3.03
#6	M.L.K. Jr Blvd	9/13/16	1159	22.5	0.23	7.39	70	34.5	3.21
#7	Clio Rd	9/13/16	1225	21.3	0.23	7.42	70	36.1	3.26
#8	N. Saginaw St	9/13/16	1249	21.4	0.23	7.41	70	33.7	3.37
CS	Cedar Street Res. Cedar St	9/13/16	1020	20.8	0.23	7.35	68	35.3	3.12
WS	West Side Res. Dupont St	9/13/16	1122	20.7	0.23	7.37	70	36.1	3.26
1A	Richfield Rd	9/16/16	1045	22.1	0.23	7.47	72	33.7	2.95
2A	E. Court St	9/16/16	1106	21.4	0.23	7.46	72	33.7	3.26
3A	S. Dort Hwy	9/16/16	1123	22.1	.23	7.45	72	34.5	2.97
Distribution System Location Number	Sample Point Name & Address	Sample Date	Time	Temperature (°C)	Conductivity (mS)	pH (s.u)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Phosphate (mg/L PO ₄)



3rd Quarter Distribution Quality Monitoring

4A	S. Dort Hwy	9/16/16	1156	22.3	0.23	7.49	72	32.9	3.03
5A	S. Dort Hwy	9/16/16	1213	21.5	0.23	7.41	72	34.5	2.69
6A	Flint City Hall S. Saginaw St	9/16/16	1237	20.6	0.23	7.41	72	30.5	3.11
7A	Flint Public Library e. Kearsley Rd	9/16/16	1307	23.2	0.24	7.51	74	34.5	3.04
1B	Clio Rd	9/17/16	1015	20.9	0.23	7.43	70	33.7	3.51
2B	Ballenger Hwy	9/17/16	1045	23.0	0.23	7.45	72	35.3	3.10
3B	Corunna Rd	9/17/16	1110	21.2	0.23	7.44	72	32.9	2.97
4B	Hogarth Ave	9/19/16	1036	22.1	0.23	7.43	74	34.5	2.73
5B	Van Slyke Rd	9/19/16	1100	22.4	0.23	7.32	74	32.9	3.17
6B	Fenton Rd	9/19/16	1123	21.6	0.23	7.35	72	33.7	2.74
7B	W. 12 th St	9/19/16	1140	21.6	0.23	7.44	74	33.7	3.18
8B	W. Court St	9/19/16	1156	23.5	0.23	7.36	72	32.9	2.74