

Day Care Facility
Follow-Up Testing
2018

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Date Collected	School	Street Name
LH63452	Lead 250	12	01WC013	P1	Copper 250	400	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63381	Lead	1	01WC013-1		Copper	80	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63382	Lead	1	01WC013-2		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63383	Lead	2	01WC013-3		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63384	Lead	0	01WC013-4		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63385	Lead	0	01WC013-5		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63386	Lead	0	01WC013-6		Copper	60	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63387	Lead	0	01WC013-7		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63388	Lead	0	01WC013-8		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63389	Lead	0	01WC013-9		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63390	Lead	0	01WC013-10		Copper	70	25-Jan-18	MOTT EARLY CHILDHOOD LEARNING	E COURT ST
LH63453	Lead 250	93	01KC003	P1	Copper 250	90	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63391	Lead	2	01KC003-1		Copper	0	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63392	Lead	0	01KC003-2		Copper	0	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63393	Lead	1	01KC003-3		Copper	0	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63394	Lead	0	01KC003-4		Copper	0	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63395	Lead	0	01KC003-5		Copper	0	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63396	Lead	0	01KC003-6		Copper	70	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63397	Lead	0	01KC003-7		Copper	100	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63398	Lead	0	01KC003-8		Copper	80	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63399	Lead	0	01KC003-9		Copper	50	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63400	Lead	0	01KC003-10		Copper	0	24-Jan-18	JUST FOR KIDS GROUP HOME	ODETTE ST
LH63455	Lead 250	3	KC040A	P1	Copper 250	110	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63411	Lead	2	KC040A-1		Copper	190	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63412	Lead	1	KC040A-2		Copper	150	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63413	Lead	2	KC040A-3		Copper	140	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63414	Lead	0	KC040A-4		Copper	110	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63415	Lead	0	KC040A-5		Copper	80	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63416	Lead	1	KC040A-6		Copper	70	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63417	Lead	0	KC040A-7		Copper	60	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63418	Lead	0	KC040A-8		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63419	Lead	0	KC040A-9		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63420	Lead	0	KC040A-10		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63456	Lead 250	0	DW022	P1	Copper 250	440	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63421	Lead	0	DW022-1		Copper	160	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63422	Lead	0	DW022-2		Copper	60	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63423	Lead	0	DW022-3		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63424	Lead	0	DW022-4		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63425	Lead	0	DW022-5		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST

Day Care Facility
Follow-Up Testing
2018

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Date Collected	School	Street Name
LH63426	Lead	0	DW022-6		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63427	Lead	0	DW022-7		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63428	Lead	0	DW022-8		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63429	Lead	0	DW022-9		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63430	Lead	0	DW022-10		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63457	Lead 250	8	KC038A	P1	Copper 250	80	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63431	Lead	2	KC038A-1		Copper	70	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63432	Lead	3	KC038A-2		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63433	Lead	2	KC038A-3		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63434	Lead	3	KC038A-4		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63435	Lead	2	KC038A-5		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63436	Lead	2	KC038A-6		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63437	Lead	0	KC038A-7		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63438	Lead	0	KC038A-8		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63439	Lead	0	KC038A-9		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST
LH63440	Lead	0	KC038A-10		Copper	0	26-Jan-18	MANLEY SCHOOL	FARLEY ST