



WEEKLY ENHANCED QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION		PARAMETERS AND RESULTS									
Distribution System Location #	Sample Week	Temperature (°C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Hardness (mg/L CaCO ₃)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Ortho phosphate (mg/L PO ₄)
#1	Jan. 10	13.4	0.22	7.55	72	34.5	100	0.083	0.07	15	3.09
#2	Jan. 10	9.3	0.20	7.50	72	35.3	102	0.087	0.02	15	3.32
#3	Jan. 10	10.4	0.21	7.35	70	36.1	98	0.093	0.03	13	3.31
#4	Jan. 10	12.5	0.20	7.54	72	35.3	100	0.167	0.04	15	3.10
#5	Jan. 10	14.0	0.21	7.51	70	34.5	100	0.146	0.03	13	3.07
#6	Jan. 10	15.1	0.22	7.74	76	36.1	104	0.15	0.04	14	2.55
#7	Jan. 10	12.9	0.20	7.44	72	32.1	102	0.123	0.04	14	3.27
#8	Jan. 10	13.1	0.20	7.48	72	32.1	102	0.071	0.03	13	3.34
#9	Jan. 10	8.7	0.21	7.38	70	31.3	100	0.134	0.02	14	1.21
CS	Jan. 10	10.7	0.21	7.54	70	36.9	104	0.198	0.06	15	2.85
WS	Jan. 10	10.3	0.21	7.60	72	37.7	100	0.132	0.01	15	3.22