



WEEKLY ENHANCED QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION		PARAMETERS AND RESULTS									
Distribution System Location #	Sample Week	Temperature (°C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Hardness (mg/L CaCO ₃)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Ortho phosphate (mg/L PO ₄)
#1	JAN. 05	15.8	0.22	7.44	74	32.9	102	0.135	0.08	14	2.42
#2	JAN. 05	9.7	0.20	7.34	70	32.1	100	0.103	0.03	13	3.19
#3	JAN. 05	12.9	0.18	7.27	70	31.3	102	0.117	0.04	14	3.26
#4	JAN. 05	10.6	0.18	7.37	70	34.5	100	0.121	0.04	13	3.20
#5	JAN. 05	15.6	0.18	7.37	72	36.1	98	0.134	0.05	13	3.01
#6	JAN. 05	15.2	0.19	7.68	72	35.3	102	0.232	0.08	13	2.34
#7	JAN. 05	13.6	0.20	7.24	70	34.5	100	0.094	0.04	15	3.26
#8	JAN. 05	15.4	0.19	7.21	68	35.3	98	0.085	0.04	14	3.26
#9	JAN. 05	7.3	0.21	7.38	72	28.9	98	0.087	0.03	10	1.07
CS	JAN. 05	12.4	0.20	7.49	70	32.1	100	0.157	0.06	15	3.20
WS	JAN. 05	10.4	0.19	7.47	72	34.5	102	0.143	0.02	15	2.99

F = Well was *Filling* when sample was taken. P = Well was *Pumping* when sample was taken. N = Well was *Neutral* when sample was taken.