

**Summary of  
Michigan Department of Environment, Great Lakes, and Energy  
Actions in Response to the  
United States Environmental Protection Agency  
Emergency Administrative Order  
Updated: 9/22/2020**

**EXECUTIVE SUMMARY:**

The United States Environmental Protection Agency (USEPA) Emergency Administrative Order contains 15 overall items to be addressed by the Michigan Department of Environment, Great Lakes, and Energy (EGLE). This update includes status only on items for which progress was made in the last week. It is anticipated that the next update to this summary will be provided on Tuesday, September 29, 2020.

Paragraph 53B

- On September 17, 2020, EGLE completed their review of the city of Flint's (City) Lead and Copper Rule Report and calculated the 90<sup>th</sup> percentile at 4 parts per billion (ppb) for lead based on the 49 samples that were included for compliance monitoring.
- On September 17, 2020, EGLE issued a Monitoring and Reporting Violation to the City for only having 49 of the required 60 samples for compliance. The City must distribute a public notice informing their customers of the violation.