



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS										
Distribution System Location #	Sample Point Name & Address	Sample Week	Tech	Temperature (°F)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Hardness (mg/L CaCO ₃)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Ortho phosphate (mg/L PO ₄)
#1	[REDACTED]	Jan. 24	SB / CB	13.9	0.25	7.64	72	32.9	104	0.170	0.10	15	3.11
#2	[REDACTED]	Jan. 24	SB / CB	10.9	0.25	7.52	72	33.7	98	0.401	0.10	14	3.87
#3	[REDACTED]	Jan. 24	SB / CB	15.3	0.20	7.50	70	37.7	100	0.138	0.03	13	3.83
#4	[REDACTED]	Jan. 24	SB / CB	10.9	0.21	7.54	70	32.9	100	0.209	0.02	14	3.79
#5	[REDACTED]	Jan. 24	SB / CB	9.6	0.24	7.57	70	36.9	98	0.201	0.05	14	3.69
#6	[REDACTED]	Jan. 24	SB / CB	16.7	0.26	7.57	72	34.5	100	0.107	0.09	15	3.54
#7	[REDACTED]	Jan. 24	SB / CB	13.7	0.22	7.46	70	39.3	98	0.092	0.06	13	3.92
#8	[REDACTED]	Jan. 24	SB / CB	14.8	0.20	7.52	70	31.3	100	0.088	0.06	14	3.73
#9	[REDACTED]	Jan. 24	SB / CB	4.9	0.21	7.56	72	34.5	100	0.103	0.01	14	1.22
CS	[REDACTED]	Jan. 24	SB / CB	10.1	0.23	7.64	72	34.5	100	0.125	0.07	14	3.67
WS	[REDACTED]	Jan. 24	SB / CB	9.2	0.23	7.58	72	40.1	104	0.165	0.05	14	3.64