

Flint Community Schools
Round 1, Week 1
1/19/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH61947	Lead 250	0	01CF023 PRE Flush	P1	Copper 250	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	0.8	All residuals were taken the day after the flush
LH61948	Lead 250	0	01CF033 PRE Flush	P1	Copper 250	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.0	
LH61949	Lead 250	0	01CF030 PRE Flush	P1	Copper 250	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	0.8	
LH61950	Lead 250	9	01KC040 PRE Flush	P1	Copper 250	300	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	0.6	
LH61951	Lead 250	4	BCF042 PRE Flush	P1	Copper 250	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.0	
LH61952	Lead 250	16	01CF021 PRE Flush	P1	Copper 250	380	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.0	
LH61953	Lead 250	2	01CF024 PRE Flush	P1	Copper 250	160	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.1	
LH61954	Lead 250	1	01CF019 PRE Flush	P1	Copper 250	130	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.4	
LH61955	Lead 250	0	01KC008 PRE Flush	P1	Copper 250	60	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.2	
LH61956	Lead 250	10	BCF045 PRE Flush	P1	Copper 250	170	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	0.6	
LH61957	Lead 250	4	01CF037 PRE Flush	P1	Copper 250	130	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.0	
LH61958	Lead 250	6	01KC049 PRE Flush	P1	Copper 250	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	0.0, 0.4, 0.8	Suspect Radiant Line caused cold water to run hot at first
LH61959	Lead 250	3	01CF011 PRE Flush	P1	Copper 250	220	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.3	
LH61960	Lead 250	3	01CF006 PRE Flush	P1	Copper 250	240	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.2	
LH61961	Lead 250	0	BCF048 PRE Flush	P1	Copper 250	180	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY	1.1	
LH61962	Lead 250	1	01CF024 ROOM 70	P1	Copper 250	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61963	Lead 250	3	01CF029 ROOM 61	P1	Copper 250	60	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61964	Lead 250	7	01CF037 ROOM 78	P1	Copper 250	70	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61965	Lead 250	8	01CF030 ROOM 59	P1	Copper 250	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61966	Lead 250	2	01CF039 ROOM 79	P1	Copper 250	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61967	Lead 250	2	01CF035 ROOM 77	P1	Copper 250	50	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61968	Lead 250	0	01KC041 ROOM 53	P1	Copper 250	80	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61969	Lead 250	0	01KC040 ROOM 53	P1	Copper 250	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61970	Lead 250	4	01CF034 ROOM 76	P1	Copper 250	70	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61971	Lead 250	4	01CF028 ROOM 72	P1	Copper 250	60	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61972	Lead 250	6	01KC049 ROOM 13	P1	Copper 250	60	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61973	Lead 250	3	01CF010 ROOM 39	P1	Copper 250	230	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61974	Lead 250	0	01CF033 ROOM 58	P1	Copper 250	80	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61975	Lead 250	4	01CF027 ROOM 62	P1	Copper 250	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61976	Lead 250	0	01CF023 ROOM 64	P1	Copper 250	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61977	Lead 250	2	01CF031 ROOM 75	P1	Copper 250	80	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61978	Lead 250	3	BCF042 ROOM 2 (BASEMENT)	P1	Copper 250	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61979	Lead 250	1	01CF013 ROOM 36	P1	Copper 250	150	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61980	Lead 250	0	01KC008 LOUNGE	P1	Copper 250	50	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61981	Lead 250	0	01CF016 ROOM 34	P1	Copper 250	70	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61982	Lead 250	0	BCF048 ROOM 7 (BASEMENT)	P1	Copper 250	120	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61983	Lead 250	2	01CF019 ROOM 32	P1	Copper 250	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61984	Lead 250	3	BCF045 ROOM 3 (BASEMENT)	P1	Copper 250	70	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61985	Lead 250	5	01CF021 INSTR MATERIAL CENTER	P1	Copper 250	110	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61986	Lead 250	0	01KC004 KITCHEN	P1	Copper 250	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61987	Lead 250	0	01CF011 ROOM 38	P1	Copper 250	150	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61988	Lead 250	1	01CF009 ROOM 39	P1	Copper 250	60	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61989	Lead 250	0	01KC015 MAIN OFFICE	P1	Copper 250	290	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61990	Lead 250	0	01CF006 ROOM 47 (DHHS)	P1	Copper 250	170	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61731	Lead	0	01CF006 ROOM 47 DHHS A1		Copper	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61732	Lead	0	01CF006 ROOM 47 DHHS A2		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61733	Lead	0	01CF006 ROOM 47 DHHS A3		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61734	Lead	0	01CF006 ROOM 47 DHHS A4		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61735	Lead	0	01CF006 ROOM 47 DHHS A5		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61736	Lead	0	01CF006 ROOM 47 DHHS A6		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61737	Lead	0	01CF006 ROOM 47 DHHS A7		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61738	Lead	0	01CF006 ROOM 47 DHHS A8		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61739	Lead	0	01CF006 ROOM 47 DHHS A9		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61740	Lead	0	01CF006 ROOM 47 DHHS A10		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61741	Lead	2	01CF021 INSTR MATERIAL CENTER B1		Copper	130	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61742	Lead	1	01CF021 INSTR MATERIAL CENTER B2		Copper	110	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61743	Lead	0	01CF021 INSTR MATERIAL CENTER B3		Copper	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61744	Lead	2	01CF021 INSTR MATERIAL CENTER B4		Copper	140	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61745	Lead	2	01CF021 INSTR MATERIAL CENTER B5		Copper	130	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61746	Lead	0	01CF021 INSTR MATERIAL CENTER B6		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61747	Lead	0	01CF021 INSTR MATERIAL CENTER B7		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61748	Lead	0	01CF021 INSTR MATERIAL CENTER B8		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61749	Lead	0	01CF021 INSTR MATERIAL CENTER B9		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61750	Lead	0	01CF021 INSTR MATERIAL CENTER B10		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61751	Lead	0	BCF048 ROOM 7 BASEMENT C1		Copper	120	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61752	Lead	0	BCF048 ROOM 7 BASEMENT C2		Copper	110	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		

Flint Community Schools
Round 1, Week 1
1/19/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH61753	Lead	0	BCF048 ROOM 7 BASEMENT C3		Copper	110	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61754	Lead	0	BCF048 ROOM 7 BASEMENT C4		Copper	110	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61755	Lead	0	BCF048 ROOM 7 BASEMENT C5		Copper	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61756	Lead	0	BCF048 ROOM 7 BASEMENT C6		Copper	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61757	Lead	0	BCF048 ROOM 7 BASEMENT C7		Copper	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61758	Lead	0	BCF048 ROOM 7 BASEMENT C8		Copper	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61759	Lead	0	BCF048 ROOM 7 BASEMENT C9		Copper	80	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61760	Lead	0	BCF048 ROOM 7 BASEMENT C10		Copper	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61761	Lead	3	01KC041 ROOM 53 D1		Copper	120	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61762	Lead	0	01KC041 ROOM 53 D2		Copper	70	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61763	Lead	0	01KC041 ROOM 53 D3		Copper	50	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61764	Lead	0	01KC041 ROOM 53 D4		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61765	Lead	0	01KC041 ROOM 53 D5		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61766	Lead	0	01KC041 ROOM 53 D6		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61767	Lead	0	01KC041 ROOM 53 D7		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61768	Lead	0	01KC041 ROOM 53 D8		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61769	Lead	0	01KC041 ROOM 53 D9		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61770	Lead	0	01KC041 ROOM 53 D10		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61771	Lead	1	01CF030 ROOM 59 E1		Copper	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61772	Lead	1	01CF030 ROOM 59 E2		Copper	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61773	Lead	3	01CF030 ROOM 59 E3		Copper	100	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61774	Lead	2	01CF030 ROOM 59 E4		Copper	70	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61775	Lead	2	01CF030 ROOM 59 E5		Copper	60	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61776	Lead	1	01CF030 ROOM 59 E6		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61777	Lead	0	01CF030 ROOM 59 E7		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61778	Lead	0	01CF030 ROOM 59 E8		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61779	Lead	0	01CF030 ROOM 59 E9		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61780	Lead	0	01CF030 ROOM 59 E10		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61781	Lead	2	01CF024 ROOM 70 F1		Copper	90	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61782	Lead	2	01CF024 ROOM 70 F2		Copper	70	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61783	Lead	1	01CF024 ROOM 70 F3		Copper	50	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61784	Lead	0	01CF024 ROOM 70 F4		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61785	Lead	0	01CF024 ROOM 70 F5		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61786	Lead	0	01CF024 ROOM 70 F6		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61787	Lead	0	01CF024 ROOM 70 F7		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61788	Lead	0	01CF024 ROOM 70 F8		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61789	Lead	0	01CF024 ROOM 70 F9		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH61790	Lead	0	01CF024 ROOM 70 F10		Copper	0	UNIVERSITY AVE	FLINT	####	DURANT TUURI MOTT ELEMENTARY		
LH62022	Lead 250	1	02CF021 PRE Flush	P1	Copper 250	70	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.6	All residuals were taken the day after the flush
LH62023	Lead 250	2	02CF036 PRE Flush	P1	Copper 250	140	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.9	
LH62024	Lead 250	0	02CF034 PRE Flush	P1	Copper 250	100	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.6	
LH62025	Lead 250	2	02CF030 PRE Flush	P1	Copper 250	140	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.7	
LH62026	Lead 250	2	01CF014 PRE Flush	P1	Copper 250	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.6	
LH62027	Lead 250	1	01CF018 PRE Flush	P1	Copper 250	70	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.4	
LH62028	Lead 250	1	02CF026 PRE Flush	P1	Copper 250	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.6	
LH62029	Lead 250	0	02CF010 PRE Flush	P1	Copper 250	50	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	1.1	
LH62030	Lead 250	0	02CF022 PRE Flush	P1	Copper 250	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.5	
LH62031	Lead 250	2	01CF004 PRE Flush	P1	Copper 250	100	PERSHING ST	FLINT	####	EISENHOWER SCHOOL	0.8	
LH62032	Lead 250	0	04KC044	P1	Copper 250	140	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62033	Lead 250	0	03KC041	P1	Copper 250	120	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62034	Lead 250	0	03KC040	P1	Copper 250	160	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62035	Lead 250	1	04KC043	P1	Copper 250	180	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62036	Lead 250	3	02CF036 ROOM 209	P1	Copper 250	100	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62037	Lead 250	2	01KC019 ROOM 108	P1	Copper 250	60	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62038	Lead 250	2	02CF028 ROOM 205	P1	Copper 250	70	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62039	Lead 250	1	02CF034 ROOM 208	P1	Copper 250	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62040	Lead 250	3	01CF014 ROOM 104	P1	Copper 250	60	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62041	Lead 250	1	02CF026 ROOM 204	P1	Copper 250	60	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62042	Lead 250	3	02CF021 ROOM 201	P1	Copper 250	70	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62043	Lead 250	1	02CF032 ROOM 207	P1	Copper 250	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62044	Lead 250	1	01CF018 ROOM 107	P1	Copper 250	60	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62045	Lead 250	3	02CF024 ROOM 203	P1	Copper 250	90	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62046	Lead 250	2	02CF022 ROOM 202	P1	Copper 250	70	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62047	Lead 250	3	01CF012 ROOM 103	P1	Copper 250	70	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62048	Lead 250	0	01CF010 ROOM 102	P1	Copper 250	60	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62049	Lead 250	0	01CF006 CLINIC	P1	Copper 250	120	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		

Flint Community Schools
Round 1, Week 1
1/19/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH62050	Lead 250	2	01CF004 ROOM 109	P1	Copper 250	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62051	Lead 250	2	02CF030 ROOM 206	P1	Copper 250	130	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62052	Lead 250	3	01CF016 ROOM 106	P1	Copper 250	70	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62053	Lead 250	1	01CF008 ROOM 101	P1	Copper 250	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61851	Lead	0	04KC044 UNIT 2 OUTBUILDING A1		Copper	110	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61852	Lead	0	04KC044 UNIT 2 OUTBUILDING A2		Copper	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61853	Lead	0	04KC044 UNIT 2 OUTBUILDING A3		Copper	80	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61854	Lead	0	04KC044 UNIT 2 OUTBUILDING A4		Copper	170	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61855	Lead	0	04KC044 UNIT 2 OUTBUILDING A5		Copper	220	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61856	Lead	0	04KC044 UNIT 2 OUTBUILDING A6		Copper	240	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61857	Lead	0	04KC044 UNIT 2 OUTBUILDING A7		Copper	250	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61858	Lead	0	04KC044 UNIT 2 OUTBUILDING A8		Copper	250	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61859	Lead	0	04KC044 UNIT 2 OUTBUILDING A9		Copper	240	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61860	Lead	0	04KC044 UNIT 2 OUTBUILDING A10		Copper	240	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61861	Lead	0	03KC040 UNIT 1 OUTBUILDING B1		Copper	90	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61862	Lead	0	03KC040 UNIT 1 OUTBUILDING B2		Copper	130	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61863	Lead	0	03KC040 UNIT 1 OUTBUILDING B3		Copper	230	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61864	Lead	0	03KC040 UNIT 1 OUTBUILDING B4		Copper	260	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61865	Lead	0	03KC040 UNIT 1 OUTBUILDING B5		Copper	280	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61866	Lead	0	03KC040 UNIT 1 OUTBUILDING B6		Copper	240	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61867	Lead	0	03KC040 UNIT 1 OUTBUILDING B7		Copper	220	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61868	Lead	0	03KC040 UNIT 1 OUTBUILDING B8		Copper	210	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61869	Lead	0	03KC040 UNIT 1 OUTBUILDING B9		Copper	210	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61870	Lead	0	03KC040 UNIT 1 OUTBUILDING B10		Copper	190	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61871	Lead	4	01CF004 ROOM 109 C1		Copper	60	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61872	Lead	0	01CF004 ROOM 109 C2		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61873	Lead	0	01CF004 ROOM 109 C3		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61874	Lead	0	01CF004 ROOM 109 C4		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61875	Lead	0	01CF004 ROOM 109 C5		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61876	Lead	0	01CF004 ROOM 109 C6		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61877	Lead	0	01CF004 ROOM 109 C7		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61878	Lead	0	01CF004 ROOM 109 C8		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61879	Lead	0	01CF004 ROOM 109 C9		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61880	Lead	0	01CF004 ROOM 109 C10		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61881	Lead	1	01CF010 ROOM 102 D1		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61882	Lead	0	01CF010 ROOM 102 D2		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61883	Lead	0	01CF010 ROOM 102 D3		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61884	Lead	0	01CF010 ROOM 102 D4		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61885	Lead	0	01CF010 ROOM 102 D5		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61886	Lead	0	01CF010 ROOM 102 D6		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61887	Lead	0	01CF010 ROOM 102 D7		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61888	Lead	0	01CF010 ROOM 102 D8		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61889	Lead	0	01CF010 ROOM 102 D9		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61890	Lead	0	01CF010 ROOM 102 D10		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61891	Lead	3	02CF036 ROOM 209 E1		Copper	60	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61892	Lead	1	02CF036 ROOM 209 E2		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61893	Lead	1	02CF036 ROOM 209 E3		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61894	Lead	0	02CF036 ROOM 209 E4		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61895	Lead	0	02CF036 ROOM 209 E5		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61896	Lead	0	02CF036 ROOM 209 E6		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61897	Lead	0	02CF036 ROOM 209 E7		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61898	Lead	0	02CF036 ROOM 209 E8		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61899	Lead	0	02CF036 ROOM 209 E9		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH61900	Lead	0	02CF036 ROOM 209 E10		Copper	0	PERSHING ST	FLINT	####	EISENHOWER SCHOOL		
LH62054	Lead 250	0	CF013 PRE Flush	P1	Copper 250	120	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	No Access	All residuals were taken the day after the flush
LH62055	Lead 250	0	CF015 PRE Flush	P1	Copper 250	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	0.4	
LH62056	Lead 250	0	CF030 PRE Flush	P1	Copper 250	140	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	1.0	
LH62057	Lead 250	0	CF027 PRE Flush	P1	Copper 250	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	0.9	
LH62058	Lead 250	0	CF025 PRE Flush	P1	Copper 250	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	0.9	
LH62059	Lead 250	0	KC003 PRE Flush	P1	Copper 250	140	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	0.5	
LH62060	Lead 250	0	CF010A ROOM 6 PRE Flush	P1	Copper 250	100	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	0.6	
LH62061	Lead 250	0	CF011A ROOM 7 PRE Flush	P1	Copper 250	70	OGEMA AVE	FLINT	####	FREEMAN SCHOOL	0.6	
LH62062	Lead 250	0	CF012A ROOM 9 FAUCET	P1	Copper 250	100	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62063	Lead 250	0	CF027 ROOM 21	P1	Copper 250	70	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62064	Lead 250	0	CF010A ROOM 6 FAUCET	P1	Copper 250	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62065	Lead 250	0	CF006A ROOM 2 FAUCET	P1	Copper 250	90	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		

Flint Community Schools
Round 1, Week 1
1/19/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH62066	Lead 250	0	CF025 ROOM 14	P1	Copper 250	60	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62067	Lead 250	0	CF030 RAINBOW/PRE K	P1	Copper 250	100	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62068	Lead 250	0	CF024 ROOM 19	P1	Copper 250	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62069	Lead 250	0	CF013 ROOM 10	P1	Copper 250	210	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62070	Lead 250	0	CF021 ROOM 12	P1	Copper 250	60	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62071	Lead 250	0	CF007A ROOM 3 (FAUCET)	P1	Copper 250	100	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62072	Lead 250	0	KC003 COMMUNITY ROOM	P1	Copper 250	70	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62073	Lead 250	12	CF011 A ROOM 7 (FAUCET)	P1	Copper 250	510	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62074	Lead 250	0	CF004 ROOM 1	P1	Copper 250	90	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62075	Lead 250	0	CF020 ROOM 17	P1	Copper 250	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62076	Lead 250	0	CF017 ROOM 15	P1	Copper 250	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62077	Lead 250	0	CF016 ROOM 11 (FAUCET)	P1	Copper 250	170	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62078	Lead 250	2	CF029 DHS OFFICE	P1	Copper 250	150	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62079	Lead 250	0	CF008A ROOM 4 (FAUCET)	P1	Copper 250	110	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62080	Lead 250	0	CF009A ROOM 5 (FAUCET)	P1	Copper 250	100	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH62081	Lead 250	2	CF015 ROOM 11	P1	Copper 250	140	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61901	Lead	0	CF030 RAINBOW/PRE K A1		Copper	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61902	Lead	0	CF030 RAINBOW/PRE K A2		Copper	50	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61903	Lead	0	CF030 RAINBOW/PRE K A3		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61904	Lead	0	CF030 RAINBOW/PRE K A4		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61905	Lead	0	CF030 RAINBOW/PRE K A5		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61906	Lead	0	CF030 RAINBOW/PRE K A6		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61907	Lead	0	CF030 RAINBOW/PRE K A7		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61908	Lead	0	CF030 RAINBOW/PRE K A8		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61909	Lead	0	CF030 RAINBOW/PRE K A9		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61910	Lead	0	CF030 RAINBOW/PRE K A10		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61911	Lead	0	CF015 ROOM 11 B1		Copper	90	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61912	Lead	0	CF015 ROOM 11 B2		Copper	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61913	Lead	0	CF015 ROOM 11 B3		Copper	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61914	Lead	0	CF015 ROOM 11 B4		Copper	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61915	Lead	0	CF015 ROOM 11 B5		Copper	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61916	Lead	0	CF015 ROOM 11 B6		Copper	80	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61917	Lead	0	CF015 ROOM 11 B7		Copper	70	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61918	Lead	0	CF015 ROOM 11 B8		Copper	70	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61919	Lead	0	CF015 ROOM 11 B9		Copper	70	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61920	Lead	0	CF015 ROOM 11 B10		Copper	70	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61921	Lead	0	CF027 ROOM 21 C1		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61922	Lead	0	CF027 ROOM 21 C2		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61923	Lead	0	CF027 ROOM 21 C3		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61924	Lead	0	CF027 ROOM 21 C4		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61925	Lead	0	CF027 ROOM 21 C5		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61926	Lead	0	CF027 ROOM 21 C6		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61927	Lead	0	CF027 ROOM 21 C7		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61928	Lead	0	CF027 ROOM 21 C8		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61929	Lead	0	CF027 ROOM 21 C9		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61930	Lead	0	CF027 ROOM 21 C10		Copper	0	OGEMA AVE	FLINT	####	FREEMAN SCHOOL		
LH61991	Lead 250	20	01CF039 PRE Flush	P1	Copper 250	170	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.7	All residuals were taken the day after the flush
LH61992	Lead 250	2	01CF035 PRE Flush	P1	Copper 250	120	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.5	
LH61993	Lead 250	0	02KC001 PRE Flush	P1	Copper 250	70	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.9	
LH61994	Lead 250	2	01CF022 PRE Flush	P1	Copper 250	110	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.4	
LH61995	Lead 250	1	01CF025 PRE Flush	P1	Copper 250	100	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.7	
LH61996	Lead 250	18	01CF011 PRE Flush	P1	Copper 250	230	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.4	
LH61997	Lead 250	3	01CF031 PRE Flush	P1	Copper 250	90	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.4	
LH61998	Lead 250	1	01KC040 PRE Flush	P1	Copper 250	70	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.9	
LH61999	Lead 250	1	01CF016 PRE Flush	P1	Copper 250	150	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.0, 0.6, 0.7	Suspect Radiant Line caused cold water to run hot at first
LH62000	Lead 250	0	01CF013 PRE Flush	P1	Copper 250	120	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.3	
LH62001	Lead 250	29	01KC006 PRE Flush	P1	Copper 250	270	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL	0.6	
LH62002	Lead 250	0	01CF010 ROOM 100	P1	Copper 250	90	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62003	Lead 250	2	01KC040 KITCHEN	P1	Copper 250	60	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62004	Lead 250	3	01CF022 ROOM 109	P1	Copper 250	130	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62005	Lead 250	2	01CF019 ROOM 107	P1	Copper 250	130	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62006	Lead 250	4	01KC006 LOUNGE	P1	Copper 250	100	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62007	Lead 250	1	01CF013 ROOM 105	P1	Copper 250	100	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62008	Lead 250	12	02KC002 DHHS OFFICE	P1	Copper 250	160	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62009	Lead 250	0	02KC001 DHHS OFFICE	P1	Copper 250	70	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62010	Lead 250	3	01CF016 ROOM 104	P1	Copper 250	120	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		

Flint Community Schools
Round 1, Week 1
1/19/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH62011	Lead 250	4	01CF027 COPY ROOM	P1	Copper 250	160	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62012	Lead 250	2	01CF025 ROOM 110	P1	Copper 250	110	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62013	Lead 250	6	01CF037 ROOM 114	P1	Copper 250	150	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62014	Lead 250	5	01CF028 ROOM 112	P1	Copper 250	180	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62015	Lead 250	8	01CF031 ROOM 112	P1	Copper 250	160	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62016	Lead 250	0	01CF032 ROOM 113	P1	Copper 250	50	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62017	Lead 250	2	01CF035 ROOM 115	P1	Copper 250	110	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62018	Lead 250	4	01CF011 LIBRARY	P1	Copper 250	140	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62019	Lead 250	1	01CF024 ROOM 108	P1	Copper 250	90	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62020	Lead 250	2	01CF018 ROOM 106	P1	Copper 250	70	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH62021	Lead 250	2	01CF039 ROOM 116	P1	Copper 250	70	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61791	Lead	6	02KC001 DHHS OFFICE A1		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61792	Lead	0	02KC001 DHHS OFFICE A2		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61793	Lead	0	02KC001 DHHS OFFICE A3		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61794	Lead	0	02KC001 DHHS OFFICE A4		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61795	Lead	0	02KC001 DHHS OFFICE A5		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61796	Lead	0	02KC001 DHHS OFFICE A6		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61797	Lead	0	02KC001 DHHS OFFICE A7		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61798	Lead	0	02KC001 DHHS OFFICE A8		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61799	Lead	0	02KC001 DHHS OFFICE A9		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61800	Lead	0	02KC001 DHHS OFFICE A10		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61801	Lead	0	01KC040 KITCHEN B1		Copper	70	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61802	Lead	0	01KC040 KITCHEN B2		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61803	Lead	0	01KC040 KITCHEN B3		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61804	Lead	0	01KC040 KITCHEN B4		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61805	Lead	0	01KC040 KITCHEN B5		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61806	Lead	0	01KC040 KITCHEN B6		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61807	Lead	0	01KC040 KITCHEN B7		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61808	Lead	0	01KC040 KITCHEN B8		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61809	Lead	0	01KC040 KITCHEN B9		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61810	Lead	0	01KC040 KITCHEN B10		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61811	Lead	2	01CF007 ROOM 101 C1		Copper	70	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61812	Lead	0	01CF007 ROOM 101 C2		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61813	Lead	0	01CF007 ROOM 101 C3		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61814	Lead	0	01CF007 ROOM 101 C4		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61815	Lead	0	01CF007 ROOM 101 C5		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61816	Lead	0	01CF007 ROOM 101 C6		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61817	Lead	0	01CF007 ROOM 101 C7		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61818	Lead	0	01CF007 ROOM 101 C8		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61819	Lead	0	01CF007 ROOM 101 C9		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61820	Lead	0	01CF007 ROOM 101 C10		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61821	Lead	2	01SP041 LOCKER ROOM D1		Copper	90	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61822	Lead	0	01SP041 LOCKER ROOM D2		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61823	Lead	0	01SP041 LOCKER ROOM D3		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61824	Lead	0	01SP041 LOCKER ROOM D4		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61825	Lead	0	01SP041 LOCKER ROOM D5		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61826	Lead	0	01SP041 LOCKER ROOM D6		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61827	Lead	0	01SP041 LOCKER ROOM D7		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61828	Lead	0	01SP041 LOCKER ROOM D8		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61829	Lead	0	01SP041 LOCKER ROOM D9		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61830	Lead	0	01SP041 LOCKER ROOM D10		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61831	Lead	0	01CF025 ROOM 110 E1		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61832	Lead	0	01CF025 ROOM 110 E2		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61833	Lead	0	01CF025 ROOM 110 E3		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61834	Lead	0	01CF025 ROOM 110 E4		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61835	Lead	0	01CF025 ROOM 110 E5		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61836	Lead	0	01CF025 ROOM 110 E6		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61837	Lead	0	01CF025 ROOM 110 E7		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61838	Lead	0	01CF025 ROOM 110 E8		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61839	Lead	0	01CF025 ROOM 110 E9		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61840	Lead	0	01CF025 ROOM 110 E10		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61841	Lead	2	01CF039 ROOM 116 F1		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61842	Lead	0	01CF039 ROOM 116 F2		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61843	Lead	0	01CF039 ROOM 116 F3		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61844	Lead	0	01CF039 ROOM 116 F4		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61845	Lead	0	01CF039 ROOM 116 F5		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		

Flint Community Schools
 Round 1, Week 1
 1/19/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH61846	Lead	0	01CF039 ROOM 116 F6		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61847	Lead	0	01CF039 ROOM 116 F7		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61848	Lead	0	01CF039 ROOM 116 F8		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61849	Lead	0	01CF039 ROOM 116 F9		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		
LH61850	Lead	0	01CF039 ROOM 116 F10		Copper	0	CRESTBROOK LN	FLINT	####	NEITHERCUT ELEMENTARY SCHOOL		