

Flint Community Schools
Round 1, Week 2
1/26/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH63279	Lead 250 mL	0	CF012-PRE Flush	P1	Copper 250	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY	1.9	All residuals were taken the day after the flush
LH63280	Lead 250 mL	14	CF023-PRE Flush	P1	Copper 250	190	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY	1.4	
LH63281	Lead 250 mL	6	CF010-PRE Flush	P1	Copper 250	70	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY	1.6	
LH63282	Lead 250 mL	3	CF007-PRE Flush	P1	Copper 250	500	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY	1.1	
LH63283	Lead 250 mL	4	KC019-PRE Flush	P1	Copper 250	110	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY	1.5	
LH63285	Lead 250 mL	1	CF003-PRE Flush	P1	Copper 250	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY	0.2, 0.9	Warm water during pre-flush sampling
LH63286	Lead 250 mL	4	KC017-PRE Flush	P1	Copper 250	110	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY	1.4	
LH63287	Lead 250 mL	3	CF018 ROOM 4	P1	Copper 250	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63288	Lead 250 mL	16	CF006 ROOM 26	P1	Copper 250	330	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		Low water flow during pre-flush sampling
LH63289	Lead 250 mL	2	KC016 ROOM 1	P1	Copper 250	160	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63290	Lead 250 mL	5	CF023 ROOM 7	P1	Copper 250	90	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63291	Lead 250 mL	11	CF005 ROOM 17	P1	Copper 250	130	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63292	Lead 250 mL	2	CF022 ROOM 6	P1	Copper 250	70	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63293	Lead 250 mL	3	CF004 ROOM 17	P1	Copper 250	120	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63294	Lead 250 mL	7	CF007 ROOM 26	P1	Copper 250	260	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63295	Lead 250 mL	3	CF010 LOUNGE- ROOM 27	P1	Copper 250	50	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63296	Lead 250 mL	1	KC015 ROOM 1	P1	Copper 250	240	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63297	Lead 250 mL	2	KC017 ROOM 2	P1	Copper 250	90	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63298	Lead 250 mL	3	CF003 ROOM 15	P1	Copper 250	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		Warm water during sampling
LH63299	Lead 250 mL	7	KC019 ROOM 4	P1	Copper 250	80	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63300	Lead 250 mL	3	CF012 COMMUNITY ROOM	P1	Copper 250	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63072	Lead	3	CF004 (ROOM 17)-A1		Copper	170	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63073	Lead	1	CF004 (ROOM 17)-A2		Copper	160	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63074	Lead	0	CF004 (ROOM 17)-A3		Copper	120	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63075	Lead	0	CF004 (ROOM 17)-A4		Copper	110	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63076	Lead	0	CF004 (ROOM 17)-A5		Copper	100	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63077	Lead	0	CF004 (ROOM 17)-A6		Copper	110	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		Warm water during sampling
LH63078	Lead	0	CF004 (ROOM 17)-A7		Copper	100	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63079	Lead	0	CF004 (ROOM 17)-A8		Copper	100	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63080	Lead	0	CF004 (ROOM 17)-A9		Copper	110	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63081	Lead	0	CF004 (ROOM 17)-A10		Copper	110	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63082	Lead	2	CF012 (COMMUNITY ROOM)-B1		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63083	Lead	0	CF012 (COMMUNITY ROOM)-B2		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63084	Lead	0	CF012 (COMMUNITY ROOM)-B3		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63085	Lead	0	CF012 (COMMUNITY ROOM)-B4		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63086	Lead	0	CF012 (COMMUNITY ROOM)-B5		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63087	Lead	0	CF012 (COMMUNITY ROOM)-B6		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63088	Lead	0	CF012 (COMMUNITY ROOM)-B7		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63089	Lead	0	CF012 (COMMUNITY ROOM)-B8		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63090	Lead	0	CF012 (COMMUNITY ROOM)-B9		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63091	Lead	0	CF012 (COMMUNITY ROOM)-B10		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63092	Lead	2	CF023 ROOM 7-C1		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63093	Lead	0	CF023 ROOM 7-C2		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63094	Lead	0	CF023 ROOM 7-C3		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63095	Lead	0	CF023 ROOM 7-C4		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63096	Lead	0	CF023 ROOM 7-C5		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63097	Lead	0	CF023 ROOM 7-C6		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63098	Lead	0	CF023 ROOM 7-C7		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63099	Lead	0	CF023 ROOM 7-C8		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63100	Lead	0	CF023 ROOM 7-C9		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63101	Lead	0	CF023 ROOM 7-C10		Copper	0	OXLEY DR	FLINT	48504	BROWNELL STEM ACADEMY		
LH63284	Lead 250 mL	6	01KC044-PRE Flush	P1	Copper 250	80	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	0.7	
LH63330	Lead 250 mL	109	02CF039-PRE Flush	P1	Copper 250	150	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.0	Debris observed in aerator after flushing
LH63331	Lead 250 mL	4	02CF030-PRE Flush	P1	Copper 250	70	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.2	
LH63332	Lead 250 mL	5	02CF036-PRE Flush	P1	Copper 250	90	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.1	
LH63336	Lead 250 mL	42	02CF041-PRE Flush	P1	Copper 250	120	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.0	Debris observed in aerator after flushing
LH63337	Lead 250 mL	0	02CF026-PRE Flush	P1	Copper 250	0	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.2	
LH63339	Lead 250 mL	19	02KC052-PRE Flush	P1	Copper 250	160	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.2	Debris observed in aerator after flushing
LH63333	Lead 250 mL	3	02CF034-PRE Flush	P1	Copper 250	90	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.2	
LH63334	Lead 250 mL	5	02CF021-PRE Flush	P1	Copper 250	100	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.2	
LH63335	Lead 250 mL	0	01KC048-PRE Flush	P1	Copper 250	60	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.2	
LH63338	Lead 250 mL	2	03KC055-PRE Flush	P1	Copper 250	120	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL	1.2	
LH63340	Lead 250 mL	23	02CF024 ROOM 256	P1	Copper 250	150	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63342	Lead 250 mL	4	02KC052 TEACHER'S LOUNGE	P1	Copper 250	130	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63343	Lead 250 mL	21	01CF018 ROOM 155	P1	Copper 250	120	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63344	Lead 250 mL	13	02CF039 ROOM 260	P1	Copper 250	90	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63345	Lead 250 mL	4	02CF021 ROOM 257	P1	Copper 250	80	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63346	Lead 250 mL	41	01CF016 ROOM 151	P1	Copper 250	180	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		Low water flow during sampling
LH63347	Lead 250 mL	145	01CF009 ROOM 154	P1	Copper 250	180	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63348	Lead 250 mL	6	02CF019 ROOM 258	P1	Copper 250	70	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		

Flint Community Schools
Round 1, Week 2
1/26/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH63349	Lead 250 mL	21	01KC048 ROOM 110	P1	Copper 250	80	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63351	Lead 250 mL	37	01CF014 ROOM 152	P1	Copper 250	160	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		Low water flow during sampling
LH63352	Lead 250 mL	85	02CF041 ROOM 262	P1	Copper 250	110	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63353	Lead 250 mL	6	01CF001 ROOM 159	P1	Copper 250	90	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63354	Lead 250 mL	47	01CF012 ROOM 153	P1	Copper 250	120	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63355	Lead 250 mL	4	01CF008 ROOM 156	P1	Copper 250	90	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63356	Lead 250 mL	5	02CF034 ROOM 252	P1	Copper 250	80	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63358	Lead 250 mL	13	02CF032 ROOM 253	P1	Copper 250	80	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63359	Lead 250 mL	4	01CF003 ROOM 160	P1	Copper 250	130	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63360	Lead 250 mL	5	02CF036 ROOM 251	P1	Copper 250	110	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63361	Lead 250 mL	5	02CF026 ROOM 259	P1	Copper 250	70	N SAGINAW ST	FLINT	48503	DOYLE/ RYDER SCHOOL		
LH63341	Lead 250 mL	4	02CF030 ROOM 254	P1	Copper 250	70	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63350	Lead 250 mL	7	01KC044 OFFICE KITCHEN	P1	Copper 250	70	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63357	Lead 250 mL	3	03KC055 KITCHEN	P1	Copper 250	120	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63142	Lead	0	01CF001 ROOM 159-A1		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63143	Lead	0	01CF001 ROOM 159-A2		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63144	Lead	0	01CF001 ROOM 159-A3		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63145	Lead	0	01CF001 ROOM 159-A4		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63146	Lead	0	01CF001 ROOM 159-A5		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63147	Lead	0	01CF001 ROOM 159-A6		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63148	Lead	0	01CF001 ROOM 159-A7		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63149	Lead	0	01CF001 ROOM 159-A8		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63150	Lead	0	01CF001 ROOM 159-A9		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63151	Lead	0	01CF001 ROOM 159-A10		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63152	Lead	1	01CF018 ROOM 155-B1		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63153	Lead	0	01CF018 ROOM 155-B2		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63154	Lead	0	01CF018 ROOM 155-B3		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63155	Lead	29	01CF018 ROOM 155-B4		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63156	Lead	0	01CF018 ROOM 155-B5		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63157	Lead	0	01CF018 ROOM 155-B6		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63158	Lead	0	01CF018 ROOM 155-B7		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63159	Lead	0	01CF018 ROOM 155-B8		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63160	Lead	0	01CF018 ROOM 155-B9		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63161	Lead	0	01CF018 ROOM 155-B10		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63162	Lead	3	02CF030 ROOM 254-C1		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63163	Lead	1	02CF030 ROOM 254-C2		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63164	Lead	0	02CF030 ROOM 254-C3		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63165	Lead	0	02CF030 ROOM 254-C4		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63166	Lead	0	02CF030 ROOM 254-C5		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63167	Lead	0	02CF030 ROOM 254-C6		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63168	Lead	0	02CF030 ROOM 254-C7		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63169	Lead	0	02CF030 ROOM 254-C8		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63170	Lead	0	02CF030 ROOM 254-C9		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63171	Lead	0	02CF030 ROOM 254-C10		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63172	Lead	40	02CF039 ROOM 260-D1		Copper	70	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63173	Lead	2	02CF039 ROOM 260-D2		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63174	Lead	1	02CF039 ROOM 260-D3		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63175	Lead	0	02CF039 ROOM 260-D4		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63176	Lead	0	02CF039 ROOM 260-D5		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63177	Lead	0	02CF039 ROOM 260-D6		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63178	Lead	0	02CF039 ROOM 260-D7		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63179	Lead	0	02CF039 ROOM 260-D8		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63180	Lead	0	02CF039 ROOM 260-D9		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63181	Lead	0	02CF039 ROOM 260-D10		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63182	Lead	5	02KC052 TEACHERS LOUNGE-E1		Copper	90	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63183	Lead	3	02KC052 TEACHERS LOUNGE-E2		Copper	60	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63184	Lead	2	02KC052 TEACHERS LOUNGE-E3		Copper	60	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63185	Lead	1	02KC052 TEACHERS LOUNGE-E4		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63186	Lead	0	02KC052 TEACHERS LOUNGE-E5		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63187	Lead	0	02KC052 TEACHERS LOUNGE-E6		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63188	Lead	0	02KC052 TEACHERS LOUNGE-E7		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63189	Lead	0	02KC052 TEACHERS LOUNGE-E8		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63190	Lead	0	02KC052 TEACHERS LOUNGE-E9		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63191	Lead	0	02KC052 TEACHERS LOUNGE-E10		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63192	Lead	23	01KC048 ROOM 110-F1		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63193	Lead	0	01KC048 ROOM 110-F2		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63194	Lead	0	01KC048 ROOM 110-F3		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63195	Lead	0	01KC048 ROOM 110-F4		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63196	Lead	0	01KC048 ROOM 110-F5		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63197	Lead	0	01KC048 ROOM 110-F6		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		

Flint Community Schools
Round 1, Week 2
1/26/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH63198	Lead	0	01KC048 ROOM 110-F7		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63199	Lead	0	01KC048 ROOM 110-F8		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63200	Lead	0	01KC048 ROOM 110-F9		Copper	0	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63201	Lead	0	01KC048 ROOM 110-F10		Copper	50	N SAGINAW ST	FLINT	48503	DOYLE/RYDER SCHOOL		
LH63254	Lead 250 mL	3	01CF032-PRE Flush	P1	Copper 250	100	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY	1.4	
LH63255	Lead 250 mL	0	01CF024-PRE Flush	P1	Copper 250	260	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY	1.2	
LH63256	Lead 250 mL	4	01KC036-PRE Flush	P1	Copper 250	110	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		No Access to Main Office on 1/27/18
LH63257	Lead 250 mL	0	01KC022-PRE Flush	P1	Copper 250	190	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY	1.2	
LH63258	Lead 250 mL	4	01KC037-PRE Flush	P1	Copper 250	100	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY	1.0	
LH63259	Lead 250 mL	1	01KC030-PRE Flush	P1	Copper 250	250	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY	1.0	
LH63260	Lead 250 mL	5	01KC037 SUPPLY ROOM	P1	Copper 250	70	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		NOTES: Urinals in building in constant flow.
LH63261	Lead 250 mL	5	01KC034 COMMUNITY ROOM	P1	Copper 250	370	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63262	Lead 250 mL	0	01CF024 ROOM B105	P1	Copper 250	160	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63263	Lead 250 mL	1	01KC029 ROOM B114	P1	Copper 250	240	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63264	Lead 250 mL	3	01CF028 ROOM B114	P1	Copper 250	90	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63265	Lead 250 mL	0	01KC011 ROOM B110	P1	Copper 250	130	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63266	Lead 250 mL	7	01CF032 COMMUNITY ROOM	P1	Copper 250	130	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63267	Lead 250 mL	1	01KC026 ROOM B105	P1	Copper 250	250	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63268	Lead 250 mL	2	01KC025	P1	Copper 250	230	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63269	Lead 250 mL	0	01CF020 ROOM B102	P1	Copper 250	140	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63270	Lead 250 mL	0	01KC017 ROOM B109	P1	Copper 250	280	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63271	Lead 250 mL	0	01KC021 ROOM B102	P1	Copper 250	130	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63272	Lead 250 mL	1	01KC033 COMMUNITY ROOM	P1	Copper 250	170	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63273	Lead 250 mL	0	01KC030 ROOM B114	P1	Copper 250	150	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63274	Lead 250 mL	0	01KC022 ROOM B102	P1	Copper 250	160	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63275	Lead 250 mL	0	01KC016 ROOM B109	P1	Copper 250	260	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63276	Lead 250 mL	0	01KC010 ROOM B110	P1	Copper 250	110	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63277	Lead 250 mL	0	01CF013 ROOM B110	P1	Copper 250	110	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63278	Lead 250 mL	0	01CF015 ROOM B109	P1	Copper 250	210	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63042	Lead	4	01KC037 (SUPPLY ROOM)-A1		Copper	60	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63043	Lead	1	01KC037 (SUPPLY ROOM)-A2		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63044	Lead	0	01KC037 (SUPPLY ROOM)-A3		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63045	Lead	0	01KC037 (SUPPLY ROOM)-A4		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63046	Lead	0	01KC037 (SUPPLY ROOM)-A5		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63047	Lead	0	01KC037 (SUPPLY ROOM)-A6		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63048	Lead	0	01KC037 (SUPPLY ROOM)-A7		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63049	Lead	0	01KC037 (SUPPLY ROOM)-A8		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63050	Lead	0	01KC037 (SUPPLY ROOM)-A9		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63051	Lead	0	01KC037 (SUPPLY ROOM)-A10		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63052	Lead	0	01CF024 (ROOM B105)-B1		Copper	190	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63053	Lead	0	01CF024 (ROOM B105)-B2		Copper	190	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63054	Lead	0	01CF024 (ROOM B105)-B3		Copper	170	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63055	Lead	0	01CF024 (ROOM B105)-B4		Copper	140	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63056	Lead	0	01CF024 (ROOM B105)-B5		Copper	80	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		Warm water during sampling
LH63057	Lead	0	01CF024 (ROOM B105)-B6		Copper	50	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63058	Lead	0	01CF024 (ROOM B105)-B7		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63059	Lead	0	01CF024 (ROOM B105)-B8		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63060	Lead	0	01CF024 (ROOM B105)-B9		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63061	Lead	0	01CF024 (ROOM B105)-B10		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63062	Lead	2	01CF032 (COMMUNITY ROOM)-C1		Copper	50	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63063	Lead	0	01CF032 (COMMUNITY ROOM)-C2		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63064	Lead	0	01CF032 (COMMUNITY ROOM)-C3		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63065	Lead	0	01CF032 (COMMUNITY ROOM)-C4		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63066	Lead	0	01CF032 (COMMUNITY ROOM)-C5		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63067	Lead	0	01CF032 (COMMUNITY ROOM)-C6		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63068	Lead	0	01CF032 (COMMUNITY ROOM)-C7		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63069	Lead	0	01CF032 (COMMUNITY ROOM)-C8		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63070	Lead	0	01CF032 (COMMUNITY ROOM)-C9		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63071	Lead	0	01CF032 (COMMUNITY ROOM)-C10		Copper	0	OXLEY DR	FLINT	48504	HOLMES STEM ACADEMY		
LH63301	Lead 250 mL	0	01KC016-PRE Flush	P1	Copper 250	120	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.8	
LH63302	Lead 250 mL	0	01CF023-PRE Flush	P1	Copper 250	140	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.1	Taken 4 times, all results 0.1
LH63303	Lead 250 mL	7	01CF003-PRE Flush	P1	Copper 250	240	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.8	
LH63304	Lead 250 mL	0	01KC033 OUTBUILDING-PRE Flush	P1	Copper 250	110	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.9	
LH63305	Lead 250 mL	0	01CF018-PRE Flush	P1	Copper 250	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	1.1	
LH63306	Lead 250 mL	0	01CF032-PRE Flush	P1	Copper 250	220	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.3	
LH63307	Lead 250 mL	4	01CF021-PRE Flush	P1	Copper 250	140	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.9	
LH63308	Lead 250 mL	0	01CF014 -PRE Flush	P1	Copper 250	70	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	1.0	
LH63309	Lead 250 mL	4	01CF011-PRE Flush	P1	Copper 250	150	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.6	
LH63310	Lead 250 mL	1	01CF010-PRE Flush	P1	Copper 250	180	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.6	
LH63311	Lead 250 mL	10	01CF030-PRE Flush	P1	Copper 250	190	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY	0.9	

Flint Community Schools
Round 1, Week 2
1/26/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH63315	Lead 250 mL	8	01CF014	P1	Copper 250	100	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		NOTES: Toilets in rooms 107 & 112 in constant flow.
LH63312	Lead 250 mL	7	01CF026 ROOM 307	P1	Copper 250	260	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		Recent fire in Outbuilding 1-water now shut off.
LH63313	Lead 250 mL	0	01KC016 TEACHER'S LOUNGE	P1	Copper 250	140	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63314	Lead 250 mL	0	01CF023 ROOM 312	P1	Copper 250	140	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63316	Lead 250 mL	2	01CF021 ROOM 306	P1	Copper 250	110	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63317	Lead 250 mL	2	01CF028 ROOM 311	P1	Copper 250	110	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63318	Lead 250 mL	1	01CF013 ROOM 100	P1	Copper 250	70	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63319	Lead 250 mL	1	01CF003 ROOM 109	P1	Copper 250	130	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63320	Lead 250 mL	1	01CF005 ROOM 110	P1	Copper 250	110	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63321	Lead 250 mL	2	01CF010 ROOM 111	P1	Copper 250	180	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63322	Lead 250 mL	6	01CF030 ROOM 308	P1	Copper 250	120	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63323	Lead 250 mL	2	01CF032 ROOM 310	P1	Copper 250	200	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63324	Lead 250 mL	1	01CF020 ROOM 302	P1	Copper 250	140	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63325	Lead 250 mL	1	01CF018 ROOM 301	P1	Copper 250	80	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63326	Lead 250 mL	0	01CF007 ROOM 108	P1	Copper 250	100	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63327	Lead 250 mL	0	01CF035 ROOM 112	P1	Copper 250	160	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63328	Lead 250 mL	0	02KC033 TEMP. RM BY PARKING	P1	Copper 250	180	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63329	Lead 250 mL	1	01CF011 ROOM 107	P1	Copper 250	110	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63102	Lead	0	01CF013 ROOM 100-A1		Copper	80	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63103	Lead	0	01CF013 ROOM 100-A2		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63104	Lead	0	01CF013 ROOM 100-A3		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63105	Lead	0	01CF013 ROOM 100-A4		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63106	Lead	0	01CF013 ROOM 100-A5		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63107	Lead	0	01CF013 ROOM 100-A6		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63108	Lead	0	01CF013 ROOM 100-A7		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63109	Lead	0	01CF013 ROOM 100-A8		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63110	Lead	0	01CF013 ROOM 100-A9		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63111	Lead	0	01CF013 ROOM 100-A10		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63112	Lead	1	01CF018 ROOM 301-B1		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63113	Lead	0	01CF018 ROOM 301-B2		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63114	Lead	0	01CF018 ROOM 301-B3		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63115	Lead	0	01CF018 ROOM 301-B4		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63116	Lead	0	01CF018 ROOM 301-B5		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63117	Lead	0	01CF018 ROOM 301-B6		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63118	Lead	0	01CF018 ROOM 301-B7		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63119	Lead	0	01CF018 ROOM 301-B8		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63120	Lead	0	01CF018 ROOM 301-B9		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63121	Lead	0	01CF018 ROOM 301-B10		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63122	Lead	3	01CF032 ROOM 310-C1		Copper	100	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63123	Lead	1	01CF032 ROOM 310-C2		Copper	50	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63124	Lead	2	01CF032 ROOM 310-C3		Copper	60	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63125	Lead	0	01CF032 ROOM 310-C4		Copper	50	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63126	Lead	0	01CF032 ROOM 310-C5		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63127	Lead	0	01CF032 ROOM 310-C6		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63128	Lead	0	01CF032 ROOM 310-C7		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63129	Lead	0	01CF032 ROOM 310-C8		Copper	60	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63130	Lead	0	01CF032 ROOM 310-C9		Copper	80	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63131	Lead	0	01CF032 ROOM 310-C10		Copper	90	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63132	Lead	0	02KC033 TEMP CLASS ROOM-D1		Copper	210	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63133	Lead	0	02KC033 TEMP CLASS ROOM-D2		Copper	190	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63134	Lead	0	02KC033 TEMP CLASS ROOM-D3		Copper	120	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63135	Lead	0	02KC033 TEMP CLASS ROOM-D4		Copper	80	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63136	Lead	0	02KC033 TEMP CLASS ROOM-D5		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63137	Lead	0	02KC033 TEMP CLASS ROOM-D6		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63138	Lead	0	02KC033 TEMP CLASS ROOM-D7		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63139	Lead	0	02KC033 TEMP CLASS ROOM-D8		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63140	Lead	0	02KC033 TEMP CLASS ROOM-D9		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63141	Lead	0	02KC033 TEMP CLASS ROOM-D10		Copper	0	W VERNON DR	FLINT	48503	PIERCE ELEMENTARY		
LH63212	Lead 250 mL	0	01CF045-PRE Flush	P1	Copper 250	160	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.6	
LH63213	Lead 250 mL	0	01KC008-PRE Flush	P1	Copper 250	90	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.5	
LH63214	Lead 250 mL	0	01CF007-PRE Flush	P1	Copper 250	110	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.2	
LH63215	Lead 250 mL	0	01CF052-PRE Flush	P1	Copper 250	200	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.1	
LH63216	Lead 250 mL	0	01CF019-PRE Flush	P1	Copper 250	100	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.6	
LH63217	Lead 250 mL	2	01BF031-PRE Flush	P1	Copper 250	80	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.4	
LH63218	Lead 250 mL	0	01CF033-PRE Flush	P1	Copper 250	90	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	1.0	
LH63219	Lead 250 mL	0	01CF035-PRE Flush	P1	Copper 250	100	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.7	
LH63220	Lead 250 mL	0	01CF001-PRE Flush	P1	Copper 250	100	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	1.1	
LH63221	Lead 250 mL	2	01CF027-PRE Flush	P1	Copper 250	150	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.1	
LH63222	Lead 250 mL	1	01CF015-PRE Flush	P1	Copper 250	120	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.7	
LH63223	Lead 250 mL	2	01CF043-PRE Flush	P1	Copper 250	200	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	0.1	Water was off prior to sampling- had to be turned on

Flint Community Schools
Round 1, Week 2
1/26/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH63224	Lead 250 mL	14	01CF037-PRE Flush	P1	Copper 250	90	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY	1.2	
LH63225	Lead 250 mL	2	01CF013 ROOM 12	P1	Copper 250	90	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63226	Lead 250 mL	0	01KC008 COMMUNITY ROOM	P1	Copper 250	80	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		NOTES: FCS Custodian said there was a water main break about 2 weeks ago. Drains clogged during flushing, caused sewer back up.
LH63227	Lead 250 mL	0	01KC009 DHHS	P1	Copper 250	130	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63228	Lead 250 mL	0	01CF007 ROOM 15	P1	Copper 250	100	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63229	Lead 250 mL	1	01CF014 ROOM 9	P1	Copper 250	110	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63230	Lead 250 mL	4	01CF045 ROOM 34	P1	Copper 250	960	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63231	Lead 250 mL	1	01CF021 ROOM 6	P1	Copper 250	190	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63232	Lead 250 mL	0	01KC025 ROOM 5	P1	Copper 250	420	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63233	Lead 250 mL	0	01CF035 ROOM 2A	P1	Copper 250	110	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63234	Lead 250 mL	0	01CF004 ROOM 20	P1	Copper 250	70	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63235	Lead 250 mL	19	01CF039 ROOM 39	P1	Copper 250	140	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63236	Lead 250 mL	2	01CF024 ROOM 5	P1	Copper 250	220	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63237	Lead 250 mL	3	01CF033 ROOM 1A	P1	Copper 250	240	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63238	Lead 250 mL	6	01CF029 ROOM 3	P1	Copper 250	250	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63239	Lead 250 mL	5	01KC026 ROOM 5	P1	Copper 250	430	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63240	Lead 250 mL	1	01CF050 ROOM 33	P1	Copper 250	170	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63241	Lead 250 mL	0	01CF041 ROOM 36	P1	Copper 250	60	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63242	Lead 250 mL	3	01CF019 ROOM 7	P1	Copper 250	180	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63243	Lead 250 mL	0	01CF015 ROOM 10	P1	Copper 250	100	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63244	Lead 250 mL	0	02KC056 OUT OF UNIT 2	P1	Copper 250	70	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63245	Lead 250 mL	0	01CF037 ROOM 38	P1	Copper 250	90	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63246	Lead 250 mL	0	01CF001 ROOM 22	P1	Copper 250	70	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63247	Lead 250 mL	2	01CF052 ROOM 31	P1	Copper 250	170	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63248	Lead 250 mL	5	01CF027 ROOM 4	P1	Copper 250	180	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63249	Lead 250 mL	4	01CF043 ROOM 37	P1	Copper 250	240	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63250	Lead 250 mL	4	01BF031 ROOM 3	P1	Copper 250	150	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63251	Lead 250 mL	7	01CF047 ROOM 35	P1	Copper 250	210	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63252	Lead 250 mL	3	01CF003 ROOM 17	P1	Copper 250	350	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63253	Lead 250 mL	6	01CF017 ROOM 8	P1	Copper 250	140	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62982	Lead	0	01CF001 ROOM 22-A1		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62983	Lead	0	01CF001 ROOM 22-A2		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62984	Lead	0	01CF001 ROOM 22-A3		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62985	Lead	0	01CF001 ROOM 22-A4		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62986	Lead	0	01CF001 ROOM 22-A5		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62987	Lead	0	01CF001 ROOM 22-A6		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62988	Lead	0	01CF001 ROOM 22-A7		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62989	Lead	0	01CF001 ROOM 22-A8		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62990	Lead	0	01CF001 ROOM 22-A9		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62991	Lead	0	01CF001 ROOM 22-A10		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62992	Lead	0	01CF013 ROOM 12-B1		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62993	Lead	0	01CF013 ROOM 12-B2		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62994	Lead	0	01CF013 ROOM 12-B3		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62995	Lead	0	01CF013 ROOM 12-B4		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62996	Lead	0	01CF013 ROOM 12-B5		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62997	Lead	0	01CF013 ROOM 12-B6		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62998	Lead	0	01CF013 ROOM 12-B7		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH62999	Lead	0	01CF013 ROOM 12-B8		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63000	Lead	0	01CF013 ROOM 12-B9		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63001	Lead	0	01CF013 ROOM 12-B10		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63002	Lead	1	01CF035 ROOM 2A LIBRARY-C1		Copper	70	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63003	Lead	1	01CF035 ROOM 2A LIBRARY-C2		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63004	Lead	1	01CF035 ROOM 2A LIBRARY-C3		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63005	Lead	1	01CF035 ROOM 2A LIBRARY-C4		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63006	Lead	0	01CF035 ROOM 2A LIBRARY-C5		Copper	60	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63007	Lead	0	01CF035 ROOM 2A LIBRARY-C6		Copper	60	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63008	Lead	0	01CF035 ROOM 2A LIBRARY-C7		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63009	Lead	0	01CF035 ROOM 2A LIBRARY-C8		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63010	Lead	0	01CF035 ROOM 2A LIBRARY-C9		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63011	Lead	0	01CF035 ROOM 2A LIBRARY-C10		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63012	Lead	0	01CF037 ROOM 38-D1		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63013	Lead	0	01CF037 ROOM 38-D2		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63014	Lead	0	01CF037 ROOM 38-D3		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63015	Lead	0	01CF037 ROOM 38-D4		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63016	Lead	0	01CF037 ROOM 38-D5		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63017	Lead	0	01CF037 ROOM 38-D6		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63018	Lead	0	01CF037 ROOM 38-D7		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63019	Lead	0	01CF037 ROOM 38-D8		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63020	Lead	0	01CF037 ROOM 38-D9		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63021	Lead	0	01CF037 ROOM 38-D10		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		

Flint Community Schools
Round 1, Week 2
1/26/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH63022	Lead	0	01CF052 ROOM 31-E1		Copper	190	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63023	Lead	0	01CF052 ROOM 31-E2		Copper	180	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63024	Lead	0	01CF052 ROOM 31-E3		Copper	180	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63025	Lead	0	01CF052 ROOM 31-E4		Copper	170	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63026	Lead	0	01CF052 ROOM 31-E5		Copper	160	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63027	Lead	0	01CF052 ROOM 31-E6		Copper	140	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63028	Lead	0	01CF052 ROOM 31-E7		Copper	120	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63029	Lead	0	01CF052 ROOM 31-E8		Copper	120	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63030	Lead	0	01CF052 ROOM 31-E9		Copper	110	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63031	Lead	0	01CF052 ROOM 31-E10		Copper	110	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63032	Lead	0	03KC056 OUT BUILDING #3-F1		Copper	140	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63033	Lead	0	03KC056 OUT BUILDING #3-F2		Copper	90	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63034	Lead	0	03KC056 OUT BUILDING #3-F3		Copper	80	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63035	Lead	0	03KC056 OUT BUILDING #3-F4		Copper	80	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63036	Lead	0	03KC056 OUT BUILDING #3-F5		Copper	80	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63037	Lead	0	03KC056 OUT BUILDING #3-F6		Copper	80	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63038	Lead	0	03KC056 OUT BUILDING #3-F7		Copper	60	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63039	Lead	0	03KC056 OUT BUILDING #3-F8		Copper	50	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63040	Lead	0	03KC056 OUT BUILDING #3-F9		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		
LH63041	Lead	0	03KC056 OUT BUILDING #3-F10		Copper	0	N AVERILL AVE	FLINT	48506	POTTER ELEMENTARY		