

Flint Community Schools
Round 1, Week 3
2/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments	
LH64210	Lead	250	1	01KC001 EMPLOYEE LOUNGE-PRE	P1	Copper 250	90	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING	1.2	All residuals were taken the day after the flush
LH64211	Lead	250	0	02KC006 ROOM 119-PRE	P1	Copper 250	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING	1.0	
LH64212	Lead	250	54	01KC005 ROOM 3-PRE	P1	Copper 250	310	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING	0.9	Water pressure fluctuated during sampling.
LH64213	Lead	250	0	01KC013 ROOM 13 PRINT SHOP-PRE	P1	Copper 250	130	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING	1.0	
LH64214	Lead	250	2	01KC002 ROOM 10A-PRE	P1	Copper 250	90	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING	0.9	
LH64215	Lead	250	0	03BF012 WOMEN'S REST ROOM-PRE	P1	Copper 250	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING	1.0	
LH64216	Lead	250	449	01KC014 ROOM 2 MIS OFFICE-PRE	P1	Copper 250	2060	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING	No access on 2/2/18	
LH64217	Lead	250	0	01KC002 ROOM 10A		Copper 250	50	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64218	Lead	250	0	01KC001 EMPLOYEE LOUNGE		Copper 250	70	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64219	Lead	250	1	01KC005 ROOM 3		Copper 250	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64220	Lead	250	0	01KC013 ROOM 13 PRINT SHOP		Copper 250	110	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64221	Lead	250	0	02KC006 ROOM 119		Copper 250	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64067	Lead	0	0	02CK006 ROOM 119-A1		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64068	Lead	0	0	02CK006 ROOM 119-A2		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64069	Lead	0	0	02CK006 ROOM 119-A3		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64070	Lead	0	0	02CK006 ROOM 119-A4		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64071	Lead	0	0	02CK006 ROOM 119-A5		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64072	Lead	0	0	02CK006 ROOM 119-A6		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64073	Lead	0	0	02CK006 ROOM 119-A7		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64074	Lead	0	0	02CK006 ROOM 119-A8		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64075	Lead	0	0	02CK006 ROOM 119-A9		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64076	Lead	0	0	02CK006 ROOM 119-A10		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64077	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B1		Copper	60	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64078	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B2		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64079	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B3		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64080	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B4		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64081	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B5		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64082	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B6		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64083	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B7		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64084	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B8		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64085	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B9		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64086	Lead	0	0	01KC001 EMPLOYEE LOUNGE-B10		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64087	Lead	0	0	03BF012 WOMENS REST ROOM-C1		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64088	Lead	0	0	03BF012 WOMENS REST ROOM-C2		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64089	Lead	0	0	03BF012 WOMENS REST ROOM-C3		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64090	Lead	0	0	03BF012 WOMENS REST ROOM-C4		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64091	Lead	0	0	03BF012 WOMENS REST ROOM-C5		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64092	Lead	0	0	03BF012 WOMENS REST ROOM-C6		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64093	Lead	0	0	03BF012 WOMENS REST ROOM-C7		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64094	Lead	0	0	03BF012 WOMENS REST ROOM-C8		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64095	Lead	0	0	03BF012 WOMENS REST ROOM-C9		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64096	Lead	0	0	03BF012 WOMENS REST ROOM-C10		Copper	0	E KEARSLEY ST	FLINT	48503	ADMINISTRATION BUILDING		
LH64222	Lead	250	0	KC001 BREAK ROOM-PRE	P1	Copper 250	0	WALNUT ST	FLINT	48503	CENTRAL KITCHEN	1.1	
LH64223	Lead	250	0	KC004 NEXT TO ICE MACHINE-PRE	P1	Copper 250	140	WALNUT ST	FLINT	48503	CENTRAL KITCHEN	1.4	
LH64224	Lead	250	0	KC005 NEXT TO ICE MACHINE-PRE	P1	Copper 250	150	WALNUT ST	FLINT	48503	CENTRAL KITCHEN	1.4	
LH64227	Lead	250	0	KC001 BREAK ROOM		Copper 250	0	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64225	Lead	250	0	KC004 NEXT TO ICE MACHINE		Copper 250	100	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64226	Lead	250	0	KC005 NEXT TO ICE MACHINE		Copper 250	130	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64097	Lead	0	0	KC001 BREAK ROOM-A1		Copper	50	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64098	Lead	0	0	KC001 BREAK ROOM-A2		Copper	50	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64099	Lead	0	0	KC001 BREAK ROOM-A3		Copper	50	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64100	Lead	0	0	KC001 BREAK ROOM-A4		Copper	50	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64101	Lead	0	0	KC001 BREAK ROOM-A5		Copper	50	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64102	Lead	0	0	KC001 BREAK ROOM-A6		Copper	50	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64103	Lead	0	0	KC001 BREAK ROOM-A7		Copper	50	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64104	Lead	0	0	KC001 BREAK ROOM-A8		Copper	0	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64105	Lead	0	0	KC001 BREAK ROOM-A9		Copper	0	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64106	Lead	0	0	KC001 BREAK ROOM-A10		Copper	0	WALNUT ST	FLINT	48503	CENTRAL KITCHEN		
LH64265	Lead	250	4	CF035-PRE	P1	Copper 250	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	0.8	
LH64266	Lead	250	24	BF052-PRE	P1	Copper 250	480	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	0.0,0.0,0.0	Auditorium was 122 degrees F.
LH64267	Lead	250	11	CF071-PRE	P1	Copper 250	190	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	1.2	
LH64268	Lead	250	5	CF013-PRE	P1	Copper 250	440	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	1.6	
LH64269	Lead	250	3	KC015-PRE	P1	Copper 250	140	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	1.2	
LH64270	Lead	250	22	CF025-PRE	P1	Copper 250	160	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	0.8	No aerator present.
LH64271	Lead	250	53	CF007-PRE	P1	Copper 250	5680	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	0.8	Room is being used for storage.
LH64272	Lead	250	57	CF036-PRE	P1	Copper 250	630	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	1.1	
LH64273	Lead	250	6	CF016-PRE	P1	Copper 250	200	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	0.3	

Flint Community Schools
Round 1, Week 3
2/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH64274	Lead 250	3	CF061-PRE	P1	Copper 250	120	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	0.8	
LH64275	Lead 250	0	KC001-PRE	P1	Copper 250	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	1.5	
LH64276	Lead 250	9	CF060-PRE	P1	Copper 250	150	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL	1.2	
LH64277	Lead 250	12	CF064 ROOM 313		Copper 250	70	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64278	Lead 250	3	CF063 ROOM 307		Copper 250	100	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64279	Lead 250	4	CF060 ROOM 304		Copper 250	180	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64280	Lead 250	2	CF080 ROOM 303		Copper 250	80	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64281	Lead 250	0	NS005 ROOM 2/ CLINIC		Copper 250	250	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64282	Lead 250	23	KC015 ROOM 415B		Copper 250	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64283	Lead 250	1	CF062 ROOM 308		Copper 250	100	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64284	Lead 250	2	CF061 ROOM 305		Copper 250	90	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64285	Lead 250	0	NS004 ROOM 1/CLINIC		Copper 250	140	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64286	Lead 250	0	KC001 CUSTODIAN BREAK ROOM		Copper 250	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64287	Lead 250	1	NS003 NURSE STA/ CLINIC		Copper 250	140	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64288	Lead 250	4	KC015A ROOM 415B		Copper 250	180	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64289	Lead 250	44	CF013 ROOM 310		Copper 250	1510	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		Warm water during sampling.
LH64290	Lead 250	0	CF007 INFANT ROOM		Copper 250	190	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64291	Lead 250	1	CF016 ROOM 415A		Copper 250	100	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64292	Lead 250	14	KC015C ROOM 415B		Copper 250	300	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64293	Lead 250	4	CF006 CHILD/ TODDLER CARE		Copper 250	260	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64294	Lead 250	2	CF074 ROOM 413A		Copper 250	130	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64295	Lead 250	4	KC015B ROOM 415B		Copper 250	220	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64296	Lead 250	8	CF014 427 WORK ROOM		Copper 250	120	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64297	Lead 250	9	CF076 ROOM 413A		Copper 250	200	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64298	Lead 250	2	CF072 ROOM 413A		Copper 250	80	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64299	Lead 250	5	CF036 ROOM 214		Copper 250	150	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64300	Lead 250	7	CF035 ROOM 207		Copper 250	180	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64301	Lead 250	0	CF023 ROOM 414		Copper 250	170	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64302	Lead 250	7	CF073 ROOM 413A		Copper 250	80	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64303	Lead 250	2	CF025 ROOM 217		Copper 250	70	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64304	Lead 250	3	CF071 ROOM 413A		Copper 250	60	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64305	Lead 250	22	BF052 STAGE/MEN'S DRESSING ROOM		Copper 250	380	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		Auditorium was 122 degrees F.
LH64306	Lead 250	3	CF075 ROOM 413A		Copper 250	150	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64167	Lead	3	CF013 ROOM 310-A1		Copper	60	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64168	Lead	1	CF013 ROOM 310-A2		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64169	Lead	1	CF013 ROOM 310-A3		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64170	Lead	1	CF013 ROOM 310-A4		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64171	Lead	0	CF013 ROOM 310-A5		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64172	Lead	0	CF013 ROOM 310-A6		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64173	Lead	0	CF013 ROOM 310-A7		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64174	Lead	0	CF013 ROOM 310-A8		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64175	Lead	0	CF013 ROOM 310-A9		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64176	Lead	0	CF013 ROOM 310-A10		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64177	Lead	2	CF023 ROOM 414-B1		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64178	Lead	0	CF023 ROOM 414-B2		Copper	180	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64179	Lead	0	CF023 ROOM 414-B3		Copper	90	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64180	Lead	0	CF023 ROOM 414-B4		Copper	60	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64181	Lead	0	CF023 ROOM 414-B5		Copper	50	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64182	Lead	0	CF023 ROOM 414-B6		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64183	Lead	0	CF023 ROOM 414-B7		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64184	Lead	0	CF023 ROOM 414-B8		Copper	60	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64185	Lead	0	CF023 ROOM 414-B9		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64186	Lead	0	CF023 ROOM 414-B10		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64187	Lead	13	CF036 ROOM 214-C1		Copper	180	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64188	Lead	4	CF036 ROOM 214-C2		Copper	180	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64189	Lead	2	CF036 ROOM 214-C3		Copper	160	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64190	Lead	1	CF036 ROOM 214-C4		Copper	130	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64191	Lead	0	CF036 ROOM 214-C5		Copper	100	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64192	Lead	0	CF036 ROOM 214-C6		Copper	60	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64193	Lead	0	CF036 ROOM 214-C7		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64194	Lead	0	CF036 ROOM 214-C8		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64195	Lead	0	CF036 ROOM 214-C9		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64196	Lead	0	CF036 ROOM 214-C10		Copper	0	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64197	Lead	4	BF052 STAGE/MEN'S DRESSING ROOM-E1		Copper	300	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64198	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E2		Copper	220	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64199	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E3		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64200	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E4		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		

Flint Community Schools
Round 1, Week 3
2/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH64201	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E5		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64202	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E6		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64203	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E7		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64204	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E8		Copper	220	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64205	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E9		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64206	Lead	0	BF052 STAGE/MEN'S DRESSING ROOM-E10		Copper	210	W CARPENTER RD	FLINT	48505	NORTHWESTERN HIGH SCHOOL		
LH64228	Lead 250	0	CF042-PRE	P1	Copper 250	70	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.3	
LH64229	Lead 250	0	CF041-PRE	P1	Copper 250	150	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.2	
LH64230	Lead 250	7	KC038-PRE	P1	Copper 250	190	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.2	
LH64231	Lead 250	37	CF047-PRE	P1	Copper 250	1930	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.0	Sample felt warm.
LH64232	Lead 250	50	CF034-PRE	P1	Copper 250	1730	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.2	Water is cloudy & slightly yellow.
LH64233	Lead 250	2	KC009 B-PRE	P1	Copper 250	90	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.0	
LH64234	Lead 250	0	CF050-PRE	P1	Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.0	
LH64235	Lead 250	1	KC023 A-PRE	P1	Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.4	
LH64236	Lead 250	2	CF031-PRE	P1	Copper 250	70	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.2	
LH64237	Lead 250	3	KC018-PRE	P1	Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		No access on 2/3/18
LH64238	Lead 250	2	CF044-PRE	P1	Copper 250	410	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY	1.2	
LH64239	Lead 250	0	CF047 ROOM 24		Copper 250	140	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64240	Lead 250	0	CF044 ROOM 20		Copper 250	160	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64241	Lead 250	2	KC038 ROOM 33		Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64242	Lead 250	0	CF037 ROOM 30		Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64243	Lead 250	1	CF041 ROOM 4		Copper 250	190	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64244	Lead 250	1	KC028A ROOM 65		Copper 250	60	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64245	Lead 250	0	CF034 ROOM 85		Copper 250	80	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64246	Lead 250	0	CF033 ROOM 87		Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64247	Lead 250	0	CF032 ROOM 89		Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64248	Lead 250	0	KC028B ROOM 65		Copper 250	80	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64249	Lead 250	2	KC009B SERVING LINE EAST		Copper 250	80	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64250	Lead 250	0	KC009A SERVING LINE WEST		Copper 250	60	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64251	Lead 250	2	CF024 ROOM 59		Copper 250	100	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64252	Lead 250	0	CF042 ROOM 8		Copper 250	130	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64253	Lead 250	0	CF050		Copper 250	80	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64254	Lead 250	0	KC028C ROOM 65		Copper 250	80	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64255	Lead 250	2	KC023A ROOM 64		Copper 250	50	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64256	Lead 250	0	CF051		Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64257	Lead 250	0	CF035 ROOM 84		Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64258	Lead 250	1	KC053 ROOM 83		Copper 250	180	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64259	Lead 250	4	KC027 ROOM 65		Copper 250	70	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64260	Lead 250	0	CF025 ROOM 57		Copper 250	240	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64261	Lead 250	1	CF031 ROOM 88		Copper 250	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64262	Lead 250	62	KC046 CLOSET IN ROOM 50		Copper 250	480	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		Fixture was not replaced.
LH64263	Lead 250	2	KC023C ROOM 64		Copper 250	120	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64264	Lead 250	1	KC023D ROOM 64		Copper 250	60	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64107	Lead	1	KC009B SERVING LINE WEST-A1		Copper	70	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64108	Lead	0	KC009B SERVING LINE WEST-A2		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64109	Lead	0	KC009B SERVING LINE WEST-A3		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64110	Lead	0	KC009B SERVING LINE WEST-A4		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64111	Lead	0	KC009B SERVING LINE WEST-A5		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64112	Lead	1	KC009B SERVING LINE WEST-A6		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64113	Lead	0	KC009B SERVING LINE WEST-A7		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64114	Lead	0	KC009B SERVING LINE WEST-A8		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64115	Lead	0	KC009B SERVING LINE WEST-A9		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64116	Lead	0	KC009B SERVING LINE WEST-A10		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64117	Lead	1	KC027 ROOM 65-B1		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64118	Lead	2	KC027 ROOM 65-B2		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64119	Lead	0	KC027 ROOM 65-B3		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64120	Lead	0	KC027 ROOM 65-B4		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64121	Lead	0	KC027 ROOM 65-B5		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64122	Lead	0	KC027 ROOM 65-B6		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64123	Lead	0	KC027 ROOM 65-B7		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64124	Lead	0	KC027 ROOM 65-B8		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64125	Lead	0	KC027 ROOM 65-B9		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64126	Lead	0	KC027 ROOM 65-B10		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64127	Lead	3	CF025 ROOM 57-D1		Copper	70	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64128	Lead	0	CF025 ROOM 57-D2		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64129	Lead	0	CF025 ROOM 57-D3		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64130	Lead	0	CF025 ROOM 57-D4		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		

Flint Community Schools
Round 1, Week 3
2/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Address	City	Zip	School	Chlorine Residual (PPM)	Comments
LH64131	Lead	0	CF025 ROOM 57-D5		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64132	Lead	0	CF025 ROOM 57-D6		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64133	Lead	0	CF025 ROOM 57-D7		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64134	Lead	0	CF025 ROOM 57-D8		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64135	Lead	0	CF025 ROOM 57-D9		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64136	Lead	0	CF025 ROOM 57-D10		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64137	Lead	0	CF035 ROOM 84-E1		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64138	Lead	0	CF035 ROOM 84-E2		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64139	Lead	0	CF035 ROOM 84-E3		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64140	Lead	0	CF035 ROOM 84-E4		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64141	Lead	0	CF035 ROOM 84-E5		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64142	Lead	0	CF035 ROOM 84-E6		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64143	Lead	0	CF035 ROOM 84-E7		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64144	Lead	0	CF035 ROOM 84-E8		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64145	Lead	0	CF035 ROOM 84-E9		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64146	Lead	0	CF035 ROOM 84-E10		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64147	Lead	0	CF042 ROOM 8-F1		Copper	100	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64148	Lead	0	CF042 ROOM 8-F2		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64149	Lead	0	CF042 ROOM 8-F3		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64150	Lead	0	CF042 ROOM 8-F4		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64151	Lead	0	CF042 ROOM 8-F5		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64152	Lead	0	CF042 ROOM 8-F6		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64153	Lead	0	CF042 ROOM 8-F7		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64154	Lead	0	CF042 ROOM 8-F8		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64155	Lead	0	CF042 ROOM 8-F9		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64156	Lead	0	CF042 ROOM 8-F10		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64157	Lead	0	CF044 ROOM 20-G1		Copper	140	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64158	Lead	0	CF044 ROOM 20-G2		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64159	Lead	0	CF044 ROOM 20-G3		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64160	Lead	0	CF044 ROOM 20-G4		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64161	Lead	0	CF044 ROOM 20-G5		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64162	Lead	0	CF044 ROOM 20-G6		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64163	Lead	0	CF044 ROOM 20-G7		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64164	Lead	0	CF044 ROOM 20-G8		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64165	Lead	0	CF044 ROOM 20-G9		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		
LH64166	Lead	0	CF044 ROOM 20-G10		Copper	0	W 12TH ST	FLINT	48507	SOUTHWESTERN CLASSICAL ACADEMY		