

Flint Community Schools
Round 3, Week 1
3/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH68456	Lead 250	0	01CF006 ROOM 47 DHHS	PRE	Copper 250	200	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68485	Lead 250	0	01CF006 ROOM 47 DHHS	3S1	Copper 250	130	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68514	Lead 250	0	01CF006 ROOM 47 DHHS	3S2	Copper 250	120	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68459	Lead 250	0	01CF009 ROOM 39	PRE	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68488	Lead 250	0	01CF009 ROOM 39	3S1	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	Water felt luke warm.
LH68517	Lead 250	0	01CF009 ROOM 39	3S2	Copper 250	50	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68462	Lead 250	3	01CF010 ROOM 39	PRE	Copper 250	190	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68491	Lead 250	1	01CF010 ROOM 39	3S1	Copper 250	80	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68520	Lead 250	0	01CF010 ROOM 39	3S2	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68458	Lead 250	0	01CF011 ROOM 38	PRE	Copper 250	110	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68487	Lead 250	0	01CF011 ROOM 38	3S1	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68516	Lead 250	0	01CF011 ROOM 38	3S2	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68461	Lead 250	2	01CF013 ROOM 36	PRE	Copper 250	230	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68490	Lead 250	4	01CF013 ROOM 36	3S1	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	Water felt luke warm.
LH68519	Lead 250	0	01CF013 ROOM 36	3S2	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68464	Lead 250	0	01CF016 ROOM 34	PRE	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68493	Lead 250	0	01CF016 ROOM 34	3S1	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68522	Lead 250	0	01CF016 ROOM 34	3S2	Copper 250	50	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68465	Lead 250	1	01CF019 ROOM 32	PRE	Copper 250	130	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68494	Lead 250	0	01CF019 ROOM 32	3S1	Copper 250	70	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68523	Lead 250	0	01CF019 ROOM 32	3S2	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68466	Lead 250	2	01CF021 INSTRUCTIONAL MATERIAL CENTER	PRE	Copper 250	250	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68495	Lead 250	2	01CF021 INSTRUCTIONAL MATERIAL CENTER	3S1	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68524	Lead 250	1	01CF021 INSTRUCTIONAL MATERIAL CENTER	3S2	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68472	Lead 250	1	01CF023 ROOM 64	PRE	Copper 250	110	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68501	Lead 250	2	01CF023 ROOM 64	3S1	Copper 250	130	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68530	Lead 250	0	01CF023 ROOM 64	3S2	Copper 250	70	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68471	Lead 250	5	01CF024 ROOM 70	PRE	Copper 250	180	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68500	Lead 250	0	01CF024 ROOM 70	3S1	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68529	Lead 250	0	01CF024 ROOM 70	3S2	Copper 250	80	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68473	Lead 250	0	01CF027 ROOM 62	PRE	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68502	Lead 250	2	01CF027 ROOM 62	3S1	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68531	Lead 250	1	01CF027 ROOM 62	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68474	Lead 250	1	01CF028 ROOM 72	PRE	Copper 250	70	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68503	Lead 250	1	01CF028 ROOM 72	3S1	Copper 250	50	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68532	Lead 250	0	01CF028 ROOM 72	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68475	Lead 250	0	01CF029 ROOM 61	PRE	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68504	Lead 250	0	01CF029 ROOM 61	3S1	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68533	Lead 250	2	01CF029 ROOM 61	3S2	Copper 250	50	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68476	Lead 250	0	01CF030 ROOM 59	PRE	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68505	Lead 250	2	01CF030 ROOM 59	3S1	Copper 250	50	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68534	Lead 250	0	01CF030 ROOM 59	3S2	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68477	Lead 250	0	01CF031 ROOM 75	PRE	Copper 250	140	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68506	Lead 250	1	01CF031 ROOM 75	3S1	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68535	Lead 250	0	01CF031 ROOM 75	3S2	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68478	Lead 250	8	01CF033 ROOM 58	PRE	Copper 250	260	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68507	Lead 250	0	01CF033 ROOM 58	3S1	Copper 250	70	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68536	Lead 250	0	01CF033 ROOM 58	3S2	Copper 250	70	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68479	Lead 250	0	01CF034 ROOM 76	PRE	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68508	Lead 250	2	01CF034 ROOM 76	3S1	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68537	Lead 250	0	01CF034 ROOM 76	3S2	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68480	Lead 250	0	01CF035 ROOM 77	PRE	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68509	Lead 250	7	01CF035 ROOM 77	3S1	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68538	Lead 250	16	01CF035 ROOM 77	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68481	Lead 250	0	01CF037 ROOM 78	PRE	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68510	Lead 250	1	01CF037 ROOM 78	3S1	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68539	Lead 250	0	01CF037 ROOM 78	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68482	Lead 250	0	01CF039 ROOM 79	PRE	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68511	Lead 250	2	01CF039 ROOM 79	3S1	Copper 250	80	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	

Flint Community Schools
Round 3, Week 1
3/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH68540	Lead 250	0	01CF039 ROOM 79	3S2	Copper 250	70	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68457	Lead 250	6	01KC004 KITCHEN	PRE	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68486	Lead 250	0	01KC004 KITCHEN	3S1	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	Water felt luke warm.
LH68515	Lead 250	1	01KC004 KITCHEN	3S2	Copper 250	60	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68460	Lead 250	0	01KC008 LOUNGE	PRE	Copper 250	50	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68489	Lead 250	15	01KC008 LOUNGE	3S1	Copper 250	110	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	Water felt luke warm.
LH68518	Lead 250	0	01KC008 LOUNGE	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68463	Lead 250	0	01KC015 MAIN OFFICE	PRE	Copper 250	290	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68492	Lead 250	0	01KC015 MAIN OFFICE	3S1	Copper 250	180	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68521	Lead 250	0	01KC015 MAIN OFFICE	3S2	Copper 250	180	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68483	Lead 250	0	01KC040 ROOM 53	PRE	Copper 250	120	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68512	Lead 250	0	01KC040 ROOM 53	3S1	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68541	Lead 250	0	01KC040 ROOM 53	3S2	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68484	Lead 250	0	01KC041 ROOM 53	PRE	Copper 250	120	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68513	Lead 250	0	01KC041 ROOM 53	3S1	Copper 250	70	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68542	Lead 250	0	01KC041 ROOM 53	3S2	Copper 250	90	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68470	Lead 250	94	01KC049 ROOM 13	PRE	Copper 250	350	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	Water felt warm and was discolored.
LH68499	Lead 250	9	01KC049 ROOM 13	3S1	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	Water felt warm.
LH68528	Lead 250	13	01KC049 ROOM 13	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68467	Lead 250	75	BCF042 ROOM 2 BASEMENT	PRE	Copper 250	80	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	Very low pressure. Yellow, cloudy water.
LH68496	Lead 250	4	BCF042 ROOM 2 BASEMENT	3S1	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68525	Lead 250	2	BCF042 ROOM 2 BASEMENT	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68468	Lead 250	4	BCF045 ROOM 3 BASEMENT	PRE	Copper 250	100	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68497	Lead 250	7	BCF045 ROOM 3 BASEMENT	3S1	Copper 250	50	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68526	Lead 250	4	BCF045 ROOM 3 BASEMENT	3S2	Copper 250	0	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68469	Lead 250	0	BCF048 ROOM 7 BASEMENT	PRE	Copper 250	170	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68498	Lead 250	0	BCF048 ROOM 7 BASEMENT	3S1	Copper 250	110	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68527	Lead 250	0	BCF048 ROOM 7 BASEMENT	3S2	Copper 250	130	UNIVERSITY AVE	FLINT	48504	DURANT TUURI MOTT	
LH68544	Lead 250	0	01CF004 ROOM 109	PRE	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68568	Lead 250	1	01CF004 ROOM 109	3S1	Copper 250	80	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68592	Lead 250	1	01CF004 ROOM 109	3S2	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68545	Lead 250	11	01CF006 CLINIC	PRE	Copper 250	260	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	No filter unit present.
LH68569	Lead 250	2	01CF006 CLINIC	3S1	Copper 250	210	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68593	Lead 250	3	01CF006 CLINIC	3S2	Copper 250	210	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68546	Lead 250	0	01CF008 ROOM 101	PRE	Copper 250	50	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68570	Lead 250	2	01CF008 ROOM 101	3S1	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68594	Lead 250	2	01CF008 ROOM 101	3S2	Copper 250	0	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68547	Lead 250	0	01CF010 ROOM 102	PRE	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68571	Lead 250	1	01CF010 ROOM 102	3S1	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68595	Lead 250	0	01CF010 ROOM 102	3S2	Copper 250	0	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68550	Lead 250	4	01CF012 ROOM 103	PRE	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68574	Lead 250	4	01CF012 ROOM 103	3S1	Copper 250	80	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68598	Lead 250	3	01CF012 ROOM 103	3S2	Copper 250	50	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68551	Lead 250	0	01CF014 ROOM 104	PRE	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68575	Lead 250	9	01CF014 ROOM 104	3S1	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68599	Lead 250	3	01CF014 ROOM 104	3S2	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68557	Lead 250	2	01CF016 ROOM 106	PRE	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68581	Lead 250	4	01CF016 ROOM 106	3S1	Copper 250	100	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68605	Lead 250	3	01CF016 ROOM 106	3S2	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68558	Lead 250	0	01CF018 ROOM 107	PRE	Copper 250	70	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68582	Lead 250	2	01CF018 ROOM 107	3S1	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68606	Lead 250	2	01CF018 ROOM 107	3S2	Copper 250	0	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68556	Lead 250	104	01CF046 LIBRARY MIC	PRE	Copper 250	230	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68580	Lead 250	16	01CF046 LIBRARY MIC	3S1	Copper 250	100	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68604	Lead 250	12	01CF046 LIBRARY MIC	3S2	Copper 250	110	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	Low pressure.
LH68543	Lead 250	0	01KC005 COMMUNITY ROOM KITCHEN	PRE	Copper 250	50	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68567	Lead 250	1	01KC005 COMMUNITY ROOM KITCHEN	3S1	Copper 250	50	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68591	Lead 250	2	01KC005 COMMUNITY ROOM KITCHEN	3S2	Copper 250	0	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68561	Lead 250	0	01KC019 ROOM 108	PRE	Copper 250	70	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	

Flint Community Schools
Round 3, Week 1
3/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH68585	Lead 250	3	01KC019 ROOM 108	3S1	Copper 250	70	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68609	Lead 250	6	01KC019 ROOM 108	3S2	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68548	Lead 250	0	02CF021 ROOM 201	PRE	Copper 250	70	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68572	Lead 250	9	02CF021 ROOM 201	3S1	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68596	Lead 250	5	02CF021 ROOM 201	3S2	Copper 250	50	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68549	Lead 250	0	02CF022 ROOM 202	PRE	Copper 250	50	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68573	Lead 250	2	02CF022 ROOM 202	3S1	Copper 250	70	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68597	Lead 250	1	02CF022 ROOM 202	3S2	Copper 250	50	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68552	Lead 250	3	02CF024 ROOM 203	PRE	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68576	Lead 250	2	02CF024 ROOM 203	3S1	Copper 250	80	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68600	Lead 250	2	02CF024 ROOM 203	3S2	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68553	Lead 250	0	02CF026 ROOM 204	PRE	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68577	Lead 250	3	02CF026 ROOM 204	3S1	Copper 250	70	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68601	Lead 250	1	02CF026 ROOM 204	3S2	Copper 250	0	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68554	Lead 250	0	02CF028 ROOM 205	PRE	Copper 250	80	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68578	Lead 250	2	02CF028 ROOM 205	3S1	Copper 250	80	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68602	Lead 250	2	02CF028 ROOM 205	3S2	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68555	Lead 250	2	02CF030 ROOM 206	PRE	Copper 250	150	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68579	Lead 250	3	02CF030 ROOM 206	3S1	Copper 250	120	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68603	Lead 250	2	02CF030 ROOM 206	3S2	Copper 250	80	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68559	Lead 250	1	02CF032 ROOM 207	PRE	Copper 250	80	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68583	Lead 250	4	02CF032 ROOM 207	3S1	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68607	Lead 250	3	02CF032 ROOM 207	3S2	Copper 250	60	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68560	Lead 250	10	02CF034 ROOM 208	PRE	Copper 250	220	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68584	Lead 250	3	02CF034 ROOM 208	3S1	Copper 250	110	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68608	Lead 250	3	02CF034 ROOM 208	3S2	Copper 250	70	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68562	Lead 250	2	02CF036 ROOM 209	PRE	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68586	Lead 250	6	02CF036 ROOM 209	3S1	Copper 250	120	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68610	Lead 250	10	02CF036 ROOM 209	3S2	Copper 250	90	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68563	Lead 250	0	03KC040 UNIT 1 OUTBUILDING	PRE	Copper 250	160	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68587	Lead 250	0	03KC040 UNIT 1 OUTBUILDING	3S1	Copper 250	130	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68611	Lead 250	0	03KC040 UNIT 1 OUTBUILDING	3S2	Copper 250	120	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68564	Lead 250	0	03KC041 UNIT 1 OUTBUILDING	PRE	Copper 250	150	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	No filter unit present.
LH68588	Lead 250	0	03KC041 UNIT 1 OUTBUILDING	3S1	Copper 250	110	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68612	Lead 250	0	03KC041 UNIT 1 OUTBUILDING	3S2	Copper 250	100	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68565	Lead 250	0	04KC043 UNIT 2 OUTBUILDING	PRE	Copper 250	200	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68589	Lead 250	0	04KC043 UNIT 2 OUTBUILDING	3S1	Copper 250	140	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68613	Lead 250	0	04KC043 UNIT 2 OUTBUILDING	3S2	Copper 250	120	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68566	Lead 250	0	04KC044 UNIT 2 OUTBUILDING	PRE	Copper 250	140	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68590	Lead 250	0	04KC044 UNIT 2 OUTBUILDING	3S1	Copper 250	120	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68614	Lead 250	0	04KC044 UNIT 2 OUTBUILDING	3S2	Copper 250	120	PERSHING ST	FLINT	48503	EISENHOWER ELEMENTARY	
LH68616	Lead 250	0	CF004 ROOM 1	PRE	Copper 250	130	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68636	Lead 250	0	CF004 ROOM 1	3S1	Copper 250	100	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68656	Lead 250	0	CF004 ROOM 1	3S2	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68619	Lead 250	0	CF006A ROOM 2	PRE	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68639	Lead 250	0	CF006A ROOM 2	3S1	Copper 250	80	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68659	Lead 250	0	CF006A ROOM 2	3S2	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68618	Lead 250	0	CF007A ROOM 3	PRE	Copper 250	120	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68638	Lead 250	0	CF007A ROOM 3	3S1	Copper 250	100	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68658	Lead 250	0	CF007A ROOM 3	3S2	Copper 250	100	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68621	Lead 250	0	CF008A ROOM 4	PRE	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68641	Lead 250	0	CF008A ROOM 4	3S1	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68661	Lead 250	0	CF008A ROOM 4	3S2	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68620	Lead 250	0	CF009A ROOM 5	PRE	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68640	Lead 250	0	CF009A ROOM 5	3S1	Copper 250	100	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68660	Lead 250	0	CF009A ROOM 5	3S2	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68623	Lead 250	0	CF010A ROOM 6	PRE	Copper 250	0	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68643	Lead 250	0	CF010A ROOM 6	3S1	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68663	Lead 250	0	CF010A ROOM 6	3S2	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	

Flint Community Schools
Round 3, Week 1
3/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH68622	Lead 250	0	CF011A ROOM 7	PRE	Copper 250	0	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	No filter unit present.
LH68642	Lead 250	0	CF011A ROOM 7	3S1	Copper 250	70	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68662	Lead 250	0	CF011A ROOM 7	3S2	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68624	Lead 250	0	CF012A ROOM 9	PRE	Copper 250	120	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68644	Lead 250	0	CF012A ROOM 9	3S1	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68664	Lead 250	0	CF012A ROOM 9	3S2	Copper 250	100	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68625	Lead 250	1	CF013 ROOM 10	PRE	Copper 250	150	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68645	Lead 250	0	CF013 ROOM 10	3S1	Copper 250	200	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68665	Lead 250	1	CF013 ROOM 10	3S2	Copper 250	220	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68626	Lead 250	3	CF015 ROOM 11	PRE	Copper 250	210	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68646	Lead 250	2	CF015 ROOM 11	3S1	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68666	Lead 250	1	CF015 ROOM 11	3S2	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68627	Lead 250	0	CF016 ROOM 11	PRE	Copper 250	260	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68647	Lead 250	0	CF016 ROOM 11	3S1	Copper 250	190	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68667	Lead 250	0	CF016 ROOM 11	3S2	Copper 250	200	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68628	Lead 250	0	CF017 ROOM 15	PRE	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68648	Lead 250	2	CF017 ROOM 15	3S1	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68668	Lead 250	1	CF017 ROOM 15	3S2	Copper 250	70	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68629	Lead 250	0	CF020 ROOM 17	PRE	Copper 250	0	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68649	Lead 250	0	CF020 ROOM 17	3S1	Copper 250	70	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68669	Lead 250	0	CF020 ROOM 17	3S2	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68630	Lead 250	0	CF022 ROOM 12	PRE	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68650	Lead 250	0	CF022 ROOM 12	3S1	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68670	Lead 250	0	CF022 ROOM 12	3S2	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68631	Lead 250	0	CF024 ROOM 19	PRE	Copper 250	70	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68651	Lead 250	0	CF024 ROOM 19	3S1	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68671	Lead 250	0	CF024 ROOM 19	3S2	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68632	Lead 250	0	CF025 ROOM 14	PRE	Copper 250	50	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68652	Lead 250	0	CF025 ROOM 14	3S1	Copper 250	80	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68672	Lead 250	0	CF025 ROOM 14	3S2	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68633	Lead 250	0	CF027 ROOM 21	PRE	Copper 250	50	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68653	Lead 250	0	CF027 ROOM 21	3S1	Copper 250	70	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68673	Lead 250	0	CF027 ROOM 21	3S2	Copper 250	60	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68615	Lead 250	18	CF029 DHHS OFFICE	PRE	Copper 250	490	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68635	Lead 250	1	CF029 DHHS OFFICE	3S1	Copper 250	140	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68655	Lead 250	0	CF029 DHHS OFFICE	3S2	Copper 250	140	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68634	Lead 250	0	CF030 RAINBOW PRE K	PRE	Copper 250	140	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68654	Lead 250	1	CF030 RAINBOW PRE K	3S1	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68674	Lead 250	0	CF030 RAINBOW PRE K	3S2	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68617	Lead 250	0	KC003 COMMUNITY ROOM	PRE	Copper 250	110	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68637	Lead 250	0	KC003 COMMUNITY ROOM	3S1	Copper 250	70	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68657	Lead 250	0	KC003 COMMUNITY ROOM	3S2	Copper 250	90	OGEMA AVE	FLINT	48507	FREEMAN ELEMENTARY	
LH68677	Lead 250	1	01CF007 ROOM 101	PRE	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68698	Lead 250	1	01CF007 ROOM 101	3S1	Copper 250	80	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68719	Lead 250	1	01CF007 ROOM 101	3S2	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68678	Lead 250	0	01CF010 ROOM 100	PRE	Copper 250	140	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68699	Lead 250	0	01CF010 ROOM 100	3S1	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68720	Lead 250	0	01CF010 ROOM 100	3S2	Copper 250	50	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68679	Lead 250	5	01CF011 LIBRARY	PRE	Copper 250	140	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68700	Lead 250	2	01CF011 LIBRARY	3S1	Copper 250	90	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68721	Lead 250	2	01CF011 LIBRARY	3S2	Copper 250	80	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68680	Lead 250	0	01CF013 ROOM 105	PRE	Copper 250	90	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68701	Lead 250	0	01CF013 ROOM 105	3S1	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68722	Lead 250	0	01CF013 ROOM 105	3S2	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68681	Lead 250	3	01CF016 ROOM 104	PRE	Copper 250	130	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68702	Lead 250	0	01CF016 ROOM 104	3S1	Copper 250	80	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68723	Lead 250	0	01CF016 ROOM 104	3S2	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68682	Lead 250	2	01CF018 ROOM 106	PRE	Copper 250	80	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68703	Lead 250	0	01CF018 ROOM 106	3S1	Copper 250	50	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	

Flint Community Schools
Round 3, Week 1
3/2/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH68724	Lead 250	0	01CF018 ROOM 106	3S2	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68683	Lead 250	0	01CF019 ROOM 107	PRE	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68704	Lead 250	0	01CF019 ROOM 107	3S1	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68725	Lead 250	0	01CF019 ROOM 107	3S2	Copper 250	50	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68684	Lead 250	16	01CF022 ROOM 109	PRE	Copper 250	140	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68705	Lead 250	1	01CF022 ROOM 109	3S1	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68726	Lead 250	1	01CF022 ROOM 109	3S2	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68685	Lead 250	1	01CF024 ROOM 108	PRE	Copper 250	110	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68706	Lead 250	1	01CF024 ROOM 108	3S1	Copper 250	80	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68727	Lead 250	0	01CF024 ROOM 108	3S2	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68686	Lead 250	0	01CF025 ROOM 110	PRE	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68707	Lead 250	0	01CF025 ROOM 110	3S1	Copper 250	80	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68728	Lead 250	0	01CF025 ROOM 110	3S2	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68687	Lead 250	2	01CF027 COPY ROOM	PRE	Copper 250	170	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68708	Lead 250	2	01CF027 COPY ROOM	3S1	Copper 250	100	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68729	Lead 250	1	01CF027 COPY ROOM	3S2	Copper 250	100	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68688	Lead 250	3	01CF028 ROOM 112	PRE	Copper 250	150	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68709	Lead 250	2	01CF028 ROOM 112	3S1	Copper 250	130	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68730	Lead 250	3	01CF028 ROOM 112	3S2	Copper 250	140	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68689	Lead 250	85	01CF031 ROOM 112	PRE	Copper 250	190	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68710	Lead 250	2	01CF031 ROOM 112	3S1	Copper 250	110	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68731	Lead 250	2	01CF031 ROOM 112	3S2	Copper 250	100	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68690	Lead 250	0	01CF032 ROOM 113	PRE	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68711	Lead 250	0	01CF032 ROOM 113	3S1	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	Low flow.
LH68732	Lead 250	0	01CF032 ROOM 113	3S2	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68691	Lead 250	2	01CF035 ROOM 115	PRE	Copper 250	160	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68712	Lead 250	1	01CF035 ROOM 115	3S1	Copper 250	80	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68733	Lead 250	1	01CF035 ROOM 115	3S2	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68692	Lead 250	0	01CF037 ROOM 114	PRE	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68713	Lead 250	20	01CF037 ROOM 114	3S1	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68734	Lead 250	0	01CF037 ROOM 114	3S2	Copper 250	850	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68693	Lead 250	7	01CF039 ROOM 116	PRE	Copper 250	90	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68714	Lead 250	1	01CF039 ROOM 116	3S1	Copper 250	50	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68735	Lead 250	1	01CF039 ROOM 116	3S2	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68676	Lead 250	16	01KC006 LOUNGE	PRE	Copper 250	180	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68697	Lead 250	1	01KC006 LOUNGE	3S1	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68718	Lead 250	1	01KC006 LOUNGE	3S2	Copper 250	50	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68675	Lead 250	2	01KC040 KITCHEN	PRE	Copper 250	70	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68696	Lead 250	0	01KC040 KITCHEN	3S1	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68717	Lead 250	0	01KC040 KITCHEN	3S2	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68694	Lead 250	0	02KC001 DHHS OFFICE	PRE	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68715	Lead 250	0	02KC001 DHHS OFFICE	3S1	Copper 250	0	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68736	Lead 250	0	02KC001 DHHS OFFICE	3S2	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68695	Lead 250	1	02KC002 DHHS OFFICE	PRE	Copper 250	60	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68716	Lead 250	0	02KC002 DHHS OFFICE	3S1	Copper 250	110	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	
LH68737	Lead 250	0	02KC002 DHHS OFFICE	3S2	Copper 250	100	CRESTBROOK LN	FLINT	48507	NEITHERCUT ELEMENTARY	