

Flint Community Schools
Round 3, Week 3
3/16/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH71145	Lead 250	0	01KC001 EMPLOYEE LOUNGE	PRE	Copper 250	90	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71152	Lead 250	0	01KC001 EMPLOYEE LOUNGE	351	Copper 250	60	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71159	Lead 250	0	01KC001 EMPLOYEE LOUNGE	352	Copper 250	60	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71146	Lead 250	22	01KC002 ROOM 10A OFF EMPLOYEE LOUNGE	PRE	Copper 250	430	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	Water was discolored
LH71153	Lead 250	0	01KC002 ROOM 10A OFF EMPLOYEE LOUNGE	351	Copper 250	50	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71160	Lead 250	0	01KC002 ROOM 10A OFF EMPLOYEE LOUNGE	352	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71147	Lead 250	15	01KC005 ROOM 3	PRE	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71154	Lead 250	10	01KC005 ROOM 3	351	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71161	Lead 250	0	01KC005 ROOM 3	352	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71144	Lead 250	0	01KC013 ROOM 13 PRINT SHOP	PRE	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	Meeting being held in room during sampling
LH71151	Lead 250	0	01KC013 ROOM 13 PRINT SHOP	351	Copper 250	140	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71158	Lead 250	0	01KC013 ROOM 13 PRINT SHOP	352	Copper 250	140	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71148	Lead 250	68	01KC014 ROOM 2 MIS OFFICE	PRE	Copper 250	140	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71155	Lead 250	1	01KC014 ROOM 2 MIS OFFICE	351	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71162	Lead 250	0	01KC014 ROOM 2 MIS OFFICE	352	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71143	Lead 250	0	02KC006 ROOM 119	PRE	Copper 250	50	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	Sample was warm
LH71150	Lead 250	0	02KC006 ROOM 119	351	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71157	Lead 250	0	02KC006 ROOM 119	352	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71149	Lead 250	0	03BF012 WOMENS REST ROOM	PRE	Copper 250	60	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	Hand washing sink only, no filter unit present
LH71156	Lead 250	0	03BF012 WOMENS REST ROOM	351	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71163	Lead 250	0	03BF012 WOMENS REST ROOM	352	Copper 250	0	E KEARSLEY ST	FLINT	####	ADMINISTRATION BUILDING	
LH71164	Lead 250	4	KC001 BREAK ROOM	PRE	Copper 250	170	WALNUT ST	FLINT	####	CENTRAL KITCHEN	Sample was warm
LH71167	Lead 250	0	KC001 BREAK ROOM	351	Copper 250	60	WALNUT ST	FLINT	####	CENTRAL KITCHEN	
LH71170	Lead 250	0	KC001 BREAK ROOM	352	Copper 250	60	WALNUT ST	FLINT	####	CENTRAL KITCHEN	
LH71165	Lead 250	0	KC004 NEXT TO ICE MACHINE	PRE	Copper 250	110	WALNUT ST	FLINT	####	CENTRAL KITCHEN	No filter unit present
LH71168	Lead 250	0	KC004 NEXT TO ICE MACHINE	351	Copper 250	130	WALNUT ST	FLINT	####	CENTRAL KITCHEN	Staff working in kitchen, dishwasher was running
LH71171	Lead 250	0	KC004 NEXT TO ICE MACHINE	352	Copper 250	130	WALNUT ST	FLINT	####	CENTRAL KITCHEN	
LH71166	Lead 250	0	KC005 NEXT TO ICE MACHINE	PRE	Copper 250	250	WALNUT ST	FLINT	####	CENTRAL KITCHEN	No filter unit present
LH71169	Lead 250	0	KC005 NEXT TO ICE MACHINE	351	Copper 250	150	WALNUT ST	FLINT	####	CENTRAL KITCHEN	Staff working in kitchen, dishwasher was running
LH71172	Lead 250	0	KC005 NEXT TO ICE MACHINE	352	Copper 250	140	WALNUT ST	FLINT	####	CENTRAL KITCHEN	
LH71183	Lead 250	2	CF006 CHILD TODDLER CARE	PRE	Copper 250	460	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	No filter unit present
LH71214	Lead 250	0	CF006 CHILD/ TODDLER CARE	351	Copper 250	170	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	No filter unit present
LH71245	Lead 250	0	CF006 CHILD/ TODDLER CARE	352	Copper 250	180	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	No filter unit present
LH71184	Lead 250	3	CF007 INFANT ROOM	PRE	Copper 250	570	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71215	Lead 250	0	CF007 INFANT ROOM	351	Copper 250	190	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71246	Lead 250	0	CF007 INFANT ROOM	352	Copper 250	210	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71185	Lead 250	1	CF013 ROOM 310	PRE	Copper 250	210	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71216	Lead 250	1	CF013 ROOM 310	351	Copper 250	190	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71247	Lead 250	6	CF013 ROOM 310	352	Copper 250	350	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71186	Lead 250	9	CF014 NEXT TO ROOM 427	PRE	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Facility installed filter
LH71217	Lead 250	6	CF014 NEXT TO ROOM 427	351	Copper 250	110	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Facility installed filter
LH71248	Lead 250	6	CF014 NEXT TO ROOM 427	352	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Facility installed filter
LH71191	Lead 250	4	CF016 ROOM 415A	PRE	Copper 250	170	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	No filter unit present
LH71222	Lead 250	0	CF016 ROOM 415A	351	Copper 250	110	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	No filter unit present
LH71253	Lead 250	0	CF016 ROOM 415A	352	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	No filter unit present
LH71198	Lead 250	0	CF023 ROOM 414	PRE	Copper 250	260	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71229	Lead 250	0	CF023 ROOM 414	351	Copper 250	170	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71260	Lead 250	0	CF023 ROOM 414	352	Copper 250	830	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71199	Lead 250	28	CF024 ROOM 216A	PRE	Copper 250	370	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71230	Lead 250	6	CF024 ROOM 216A	351	Copper 250	190	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71261	Lead 250	6	CF024 ROOM 216A	352	Copper 250	270	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71200	Lead 250	2	CF025 ROOM 217	PRE	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71231	Lead 250	1	CF025 ROOM 217	351	Copper 250	70	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71262	Lead 250	2	CF025 ROOM 217	352	Copper 250	80	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71201	Lead 250	38	CF035 ROOM 207	PRE	Copper 250	530	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71232	Lead 250	5	CF035 ROOM 207	351	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71263	Lead 250	9	CF035 ROOM 207	352	Copper 250	170	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71202	Lead 250	15	CF036 ROOM 214	PRE	Copper 250	310	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71233	Lead 250	2	CF036 ROOM 214	351	Copper 250	140	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71264	Lead 250	5	CF036 ROOM 214	352	Copper 250	180	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Hand washing sink only, no filter unit present
LH71177	Lead 250	2	CF060 ROOM 304	PRE	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71208	Lead 250	3	CF060 ROOM 304	351	Copper 250	150	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71239	Lead 250	2	CF060 ROOM 304	325	Copper 250	130	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71176	Lead 250	1	CF061 ROOM 305	PRE	Copper 250	100	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71207	Lead 250	2	CF061 ROOM 305	351	Copper 250	80	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	

Flint Community Schools
Round 3, Week 3
3/16/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH71238	Lead 250	1	CF061 ROOM 305	352	Copper 250	90	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71179	Lead 250	0	CF062 ROOM 308	PRE	Copper 250	80	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71210	Lead 250	28	CF062 ROOM 308	351	Copper 250	2440	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71241	Lead 250	19	CF062 ROOM 308	352	Copper 250	1740	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71175	Lead 250	1	CF063 ROOM 307	PRE	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71206	Lead 250	2	CF063 ROOM 307	351	Copper 250	110	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71237	Lead 250	1	CF063 ROOM 307	352	Copper 250	110	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71174	Lead 250	20	CF064 ROOM 313	PRE	Copper 250	100	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71205	Lead 250	6	CF064 ROOM 313	351	Copper 250	80	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71236	Lead 250	8	CF064 ROOM 313	352	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71192	Lead 250	1	CF071 ROOM 413A	PRE	Copper 250	90	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71223	Lead 250	0	CF071 ROOM 413A	351	Copper 250	50	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71254	Lead 250	0	CF071 ROOM 413A	352	Copper 250	60	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71193	Lead 250	1	CF072 ROOM 413A	PRE	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71224	Lead 250	0	CF072 ROOM 413A	351	Copper 250	80	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71255	Lead 250	0	CF072 ROOM 413A	352	Copper 250	70	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71194	Lead 250	2	CF073 ROOM 413A	PRE	Copper 250	90	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71225	Lead 250	2	CF073 ROOM 413A	351	Copper 250	70	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71256	Lead 250	0	CF073 ROOM 413A	352	Copper 250	60	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71197	Lead 250	1	CF074 ROOM 413A	PRE	Copper 250	150	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71228	Lead 250	0	CF074 ROOM 413A	351	Copper 250	90	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71259	Lead 250	0	CF074 ROOM 413A	352	Copper 250	100	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71196	Lead 250	2	CF075 ROOM 413A	PRE	Copper 250	170	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71227	Lead 250	2	CF075 ROOM 413A	351	Copper 250	130	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71258	Lead 250	1	CF075 ROOM 413A	352	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71195	Lead 250	1	CF076 ROOM 413A	PRE	Copper 250	190	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71226	Lead 250	1	CF076 ROOM 413A	351	Copper 250	170	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71257	Lead 250	1	CF076 ROOM 413A	352	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71178	Lead 250	3	CF080 ROOM 303	PRE	Copper 250	110	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71209	Lead 250	13	CF080 ROOM 303	351	Copper 250	80	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71240	Lead 250	4	CF080 ROOM 303	352	Copper 250	110	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71173	Lead 250	58	KC001 CUSTODIAN BREAK ROOM	PRE	Copper 250	80	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71204	Lead 250	0	KC001 CUSTODIAN BREAK ROOM	351	Copper 250	0	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71235	Lead 250	0	KC001 CUSTODIAN BREAK ROOM	352	Copper 250	0	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71187	Lead 250	3	KC015 ROOM 415B	PRE	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71218	Lead 250	2	KC015 ROOM 415B	351	Copper 250	140	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71249	Lead 250	2	KC015 ROOM 415B	352	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71188	Lead 250	5	KC015A ROOM 415B	PRE	Copper 250	260	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	No filter unit present
LH71219	Lead 250	2	KC015A ROOM 415B	351	Copper 250	150	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	New filter unit installed before flushing
LH71250	Lead 250	1	KC015A ROOM 415B	352	Copper 250	190	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	New filter unit installed before flushing
LH71189	Lead 250	3	KC015B ROOM 415B	PRE	Copper 250	260	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71220	Lead 250	1	KC015B ROOM 415B	351	Copper 250	180	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71251	Lead 250	0	KC015B ROOM 415B	352	Copper 250	190	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71190	Lead 250	10	KC015C ROOM 415B	PRE	Copper 250	200	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71221	Lead 250	4	KC015C ROOM 415B	351	Copper 250	140	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71252	Lead 250	3	KC015C ROOM 415B	352	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71203	Lead 250	0	KC037 ROOM 411	PRE	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71234	Lead 250	0	KC037 ROOM 411	351	Copper 250	70	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71265	Lead 250	0	KC037 ROOM 411	352	Copper 250	60	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71266	Lead 250	2	KC039 COMMUNITY ROOM	352	Copper 250	190	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	Only had access for 352 sampling, not flushed
LH71180	Lead 250	2	NS003 WELLNESS CLINIC	PRE	Copper 250	220	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71211	Lead 250	0	NS003 WELLNESS CLINIC	351	Copper 250	130	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71242	Lead 250	0	NS003 WELLNESS CLINIC	352	Copper 250	140	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71181	Lead 250	1	NS004 WELLNESS CLINIC ROOM 1	PRE	Copper 250	420	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71212	Lead 250	0	NS004 WELLNESS CLINIC/ ROOM 1	351	Copper 250	120	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71243	Lead 250	0	NS004 WELLNESS CLINIC/ ROOM 1	352	Copper 250	140	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71182	Lead 250	0	NS005 WELLNESS CLINIC ROOM 2	PRE	Copper 250	460	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71213	Lead 250	0	NS005 WELLNESS CLINIC/ ROOM 2	351	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71244	Lead 250	0	NS005 WELLNESS CLINIC/ ROOM 2	352	Copper 250	160	W CARPENTER ROAD	FLINT	####	NORTHWESTERN HIGH SCHOOL	
LH71275	Lead 250	0	CF024 ROOM 59	PRE	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Water drips from faucet
LH71304	Lead 250	0	CF024 ROOM 59	351	Copper 250	60	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71333	Lead 250	0	CF024 ROOM 59	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71278	Lead 250	1	CF025 ROOM 57	PRE	Copper 250	220	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	No filter unit present
LH71307	Lead 250	0	CF025 ROOM 57	351	Copper 250	280	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71336	Lead 250	2	CF025 ROOM 57	352	Copper 250	160	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	

Flint Community Schools
Round 3, Week 3
3/16/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH71284	Lead 250	2	CF031 ROOM 88	PRE	Copper 250	90	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71313	Lead 250	1	CF031 ROOM 88	351	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71342	Lead 250	2	CF031 ROOM 88	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71285	Lead 250	1	CF032 ROOM 89	PRE	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71314	Lead 250	0	CF032 ROOM 89	351	Copper 250	50	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71343	Lead 250	0	CF032 ROOM 89	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71286	Lead 250	1	CF033 ROOM 87	PRE	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71315	Lead 250	1	CF033 ROOM 87	351	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71344	Lead 250	0	CF033 ROOM 87	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71287	Lead 250	2	CF034 ROOM 85	PRE	Copper 250	140	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71316	Lead 250	1	CF034 ROOM 85	351	Copper 250	140	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71345	Lead 250	0	CF034 ROOM 85	352	Copper 250	150	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71288	Lead 250	0	CF035 ROOM 84	PRE	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71317	Lead 250	0	CF035 ROOM 84	351	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71346	Lead 250	0	CF035 ROOM 84	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71290	Lead 250	0	CF037 ROOM 30	PRE	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71319	Lead 250	0	CF037 ROOM 30	351	Copper 250	90	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71348	Lead 250	0	CF037 ROOM 30	352	Copper 250	50	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71292	Lead 250	3	CF041 ROOM 4	PRE	Copper 250	440	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71321	Lead 250	2	CF041 ROOM 4	351	Copper 250	330	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71350	Lead 250	1	CF041 ROOM 4	352	Copper 250	140	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71294	Lead 250	0	CF042 ROOM 8	PRE	Copper 250	60	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71323	Lead 250	0	CF042 ROOM 8	351	Copper 250	140	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71352	Lead 250	0	CF042 ROOM 8	352	Copper 250	90	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71295	Lead 250	0	CF044 ROOM 20	PRE	Copper 250	230	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71324	Lead 250	0	CF044 ROOM 20	351	Copper 250	160	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71353	Lead 250	0	CF044 ROOM 20	352	Copper 250	180	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71293	Lead 250	0	CF047 ROOM 24	PRE	Copper 250	80	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71322	Lead 250	6	CF047 ROOM 24	351	Copper 250	440	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71351	Lead 250	3	CF047 ROOM 24	352	Copper 250	380	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71276	Lead 250	0	CF050 ROOM 59	PRE	Copper 250	60	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71305	Lead 250	0	CF050 ROOM 59	351	Copper 250	80	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71334	Lead 250	0	CF050 ROOM 59	352	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71277	Lead 250	0	CF051 ROOM 59	PRE	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71306	Lead 250	0	CF051 ROOM 59	351	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71335	Lead 250	0	CF051 ROOM 59	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71267	Lead 250	0	KC001A ROOM 97 TRAINING ROOM	PRE	Copper 250	110	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Access issues, taken out of sequence
LH71296	Lead 250	0	KC001A ROOM 97 TRAINING ROOM	351	Copper 250	90	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71325	Lead 250	0	KC001A ROOM 97 TRAINING ROOM	352	Copper 250	80	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71268	Lead 250	0	KC009A SERVING LINE WEST	PRE	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	No filter unit present
LH71297	Lead 250	0	KC009A SERVING LINE WEST	351	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71326	Lead 250	0	KC009A SERVING LINE WEST	352	Copper 250	60	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71269	Lead 250	2	KC009B SERVING LINE EAST	PRE	Copper 250	90	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	No filter unit present
LH71298	Lead 250	1	KC009B SERVING LINE EAST	351	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71327	Lead 250	2	KC009B SERVING LINE EAST	352	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71270	Lead 250	6	KC018 MAIN OFFICE	PRE	Copper 250	100	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Sample was hot, air temperature was >90 degrees F
LH71299	Lead 250	3	KC018 MAIN OFFICE	351	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Sample was warm
LH71328	Lead 250	4	KC018 MAIN OFFICE	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71272	Lead 250	1	KC023A ROOM 64	PRE	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71301	Lead 250	2	KC023A ROOM 64	351	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71330	Lead 250	1	KC023A ROOM 64	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71273	Lead 250	2	KC023C ROOM 64	PRE	Copper 250	200	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71302	Lead 250	2	KC023C ROOM 64	351	Copper 250	140	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71331	Lead 250	2	KC023C ROOM 64	352	Copper 250	120	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71274	Lead 250	0	KC023D ROOM 64	PRE	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71303	Lead 250	0	KC023D ROOM 64	351	Copper 250	60	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71332	Lead 250	0	KC023D ROOM 64	352	Copper 250	50	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71279	Lead 250	3	KC027 ROOM 65	PRE	Copper 250	80	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71308	Lead 250	0	KC027 ROOM 65	351	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71337	Lead 250	0	KC027 ROOM 65	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71280	Lead 250	1	KC028A ROOM 65	PRE	Copper 250	60	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Sample was warm
LH71309	Lead 250	1	KC028A ROOM 65	351	Copper 250	50	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71338	Lead 250	1	KC028A ROOM 65	352	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71281	Lead 250	1	KC028B ROOM 65	PRE	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Sample was warm
LH71310	Lead 250	0	KC028B ROOM 65	351	Copper 250	80	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	

Flint Community Schools
Round 3, Week 3
3/16/18

Sample Number	Lead	Lead (PPB)	Sample Description	Site Code	Copper	Copper (PPB)	Street Name	City	Zip	School	Comments
LH71339	Lead 250	1	KC028B ROOM 65	3S2	Copper 250	60	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71282	Lead 250	2	KC028C ROOM 65	PRE	Copper 250	140	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71311	Lead 250	0	KC028C ROOM 65	3S1	Copper 250	80	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71340	Lead 250	0	KC028C ROOM 65	3S2	Copper 250	80	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71291	Lead 250	2	KC038 ROOM 33	PRE	Copper 250	70	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71320	Lead 250	1	KC038 ROOM 33	3S1	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71349	Lead 250	0	KC038 ROOM 33	3S2	Copper 250	0	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71283	Lead 250	55	KC046 CLOSET TO ROOM 50	PRE	Copper 250	290	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	No filter unit present
LH71312	Lead 250	13	KC046 CLOSET TO ROOM 50	3S1	Copper 250	280	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Sample was discolored, milky
LH71341	Lead 250	11	KC046 CLOSET TO ROOM 50	3S2	Copper 250	230	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71271	Lead 250	5	KC052 ROOM 81	PRE	Copper 250	320	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Access issues, taken out of sequence, sample discolored, milky
LH71300	Lead 250	3	KC052 ROOM 81	3S1	Copper 250	180	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	Sample was warm
LH71329	Lead 250	3	KC052 ROOM 81	3S2	Copper 250	190	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71289	Lead 250	3	KC053 ROOM 83	PRE	Copper 250	200	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71318	Lead 250	2	KC053 ROOM 83	3S1	Copper 250	220	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	
LH71347	Lead 250	1	KC053 ROOM 83	3S2	Copper 250	180	W 12TH STREET	FLINT	####	SOUTHWESTERN CLASSICAL ACADEMY	