

City of Flint
Tap Sampling Results
January 1-June 30, 2019
UPDATED: 9/26/19

Sample Number	Date Submitted	Result Lead	Result Copper	Address	Liter Number	Status	Sample Description	SLE Date	SLR Date	Public	Private	Comments
LI42287	11-Jun-19	0	0	1920 LEVERN ST	5TH LITER	Invalid	KITCHEN SINK 5TH DRAW			Copper	Copper	8/16/17 Hydrovac revealed Unknown-Unknown
LI42288	11-Jun-19	0	0	1920 LEVERN ST	1ST LITER	Invalid	KITCHEN SINK 1ST DRAW			Copper	Copper	8/16/17 Hydrovac revealed Unknown-Unknown
LI46516	27-Jun-19	0	0	2305 W COURT ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	No Record				Form does not have date/time of when faucet was last used
LI46517	27-Jun-19	0	0	2305 W COURT ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	No Record				Form does not have date/time of when faucet was last used
LI48133	08-Jul-19	0	0	713 WESTCOMBE AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW		6/28/2019	Lead	Galvanized	Form has same time for last use and when the bottle was filled
LI48134	08-Jul-19	0	0	713 WESTCOMBE AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW		6/28/2019	Lead	Galvanized	Form has same time for last use and when the bottle was filled
LI44833	20-Jun-19	0	0	1502 BROOKWOOD AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW		11/7/2017	Unknown	Unknown	Form states faucet connected to whole house filtration
LI44834	20-Jun-19	0	0	1502 BROOKWOOD AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW		11/7/2017	Unknown	Unknown	Form states faucet connected to whole house filtration
LI46512	27-Jun-19	0	0	2112 BROWN ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW		6/21/2019	Lead	Copper	Form states filter was NOT bypassed
LI46513	27-Jun-19	0	0	2112 BROWN ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW		6/21/2019	Lead	Copper	Form states filter was NOT bypassed
LI46472	27-Jun-19	0	0	323 WESTCOMBE AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW		6/27/2019	Lead	Copper	Form states filter was NOT bypassed
LI46473	27-Jun-19	0	0	323 WESTCOMBE AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW		6/27/2019	Lead	Copper	Form states filter was NOT bypassed
LI44825	20-Jun-19	0	0	988 BARNEY AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW		6/25/2019	Lead	Copper	Form states less than 6 hour stagnation
LI44826	20-Jun-19	0	0	988 BARNEY AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW		6/25/2019	Lead	Copper	Form states less than 6 hour stagnation
LI46482	27-Jun-19	0	0	729 WESTCOMBE AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	No Record				Form states less than 6 hours of stagnation
LI46483	27-Jun-19	0	0	729 WESTCOMBE AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	No Record				Form states less than 6 hours of stagnation
LI45098	21-Jun-19	0	70	1023 LYON ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	4/30/2018	7/15/2019	Lead	Copper	Form states resident only let water stagnate for 15 minutes
LI45099	21-Jun-19	0	70	1023 LYON ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	4/30/2018	7/15/2019	Lead	Copper	Form states resident only let water stagnate for 15 minutes
LI41838	10-Jun-19	0	0	1203 LYON ST	1ST LITER	Invalid	BATHROOM SINK 1ST DRAW		7/12/2019	Lead	Copper	Form states resident took sample from bathroom tub
LI41839	10-Jun-19	0	0	1203 LYON ST	5TH LITER	Invalid	BATHROOM SINK 5TH DRAW		7/12/2019	Lead	Copper	Form states resident took sample from bathroom tub
LI46490	27-Jun-19	0	0	1616 CALUMET ST	5TH LITER	Invalid	BATHROOM SINK FIFTH DRAW	8/5/2019		Copper	Copper	Form states taken from a basement faucet and POU NOT bypassed
LI46491	27-Jun-19	0	0	1616 CALUMET ST	1ST LITER	Invalid	BATHROOM SINK FIRST DRAW	8/5/2019		Copper	Copper	Form states taken from a basement faucet and POU NOT bypassed
LI38342	16-May-19	0	0	2540 ORCHARD LN	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	No Record	8/22/2019	Copper	Copper	From WT Stevens Report to Bincsik 9-6-19
LI38343	16-May-19	0	0	2540 ORCHARD LN	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	No Record	8/22/2019	Copper	Copper	From WT Stevens Report to Bincsik 9-6-19
LI45092	21-Jun-19	0	0	2921 MALLERY ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	12/12/2018	8/22/2019	Copper	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI45093	21-Jun-19	0	0	2921 MALLERY ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	12/12/2018	8/22/2019	Copper	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI42293	11-Jun-19	0	0	4429 PENGELLY RD	5TH LITER	Invalid	KITCHEN SINK 5TH DRAW	No Record	8/8/2019	Galvanized	Copper	Identified through email from R. Jones 9-9-19
LI42294	11-Jun-19	0	0	4429 PENGELLY RD	1ST LITER	Invalid	KITCHEN SINK 1ST DRAW	No Record	8/8/2019	Galvanized	Copper	Identified through email from R. Jones 9-9-19
LI41844	10-Jun-19	0	0	2406 PIERCE ST	1ST LITER	Invalid	BATHROOM SINK 1ST DRAW	8/5/2019		Copper	Copper	Not on Phase 6
LI41845	10-Jun-19	0	0	2406 PIERCE ST	5TH LITER	Invalid	BATHROOM SINK 5TH DRAW	8/5/2019		Copper	Copper	Not on Phase 6
LI45086	21-Jun-19	0	140	705 WOLCOTT ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW		5/29/2019	Lead	Copper	SLR 5/29/19 - Sample taken 6/12/19
LI45087	21-Jun-19	0	100	705 WOLCOTT ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW		5/29/2019	Lead	Copper	SLR 5/29/19 - Sample taken 6/12/19
LI44849	20-Jun-19	0	0	2605 W COURT ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	No Record	9/23/2019	Copper	Copper	
LI44850	20-Jun-19	0	0	2605 W COURT ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	No Record	9/23/2019	Copper	Copper	
LI46496	27-Jun-19	0	0	3806 W COURT ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	No Record	9/25/2019	Copper	Copper	
LI46497	27-Jun-19	0	0	3806 W COURT ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	No Record	9/25/2019	Copper	Copper	
LI44853	20-Jun-19	0	0	109 E HOME AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	8/19/2019		Copper	Copper	
LI44854	20-Jun-19	3	0	109 E HOME AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	8/19/2019		Copper	Copper	
LI46470	27-Jun-19	3	0	1410 BRADLEY AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/21/2019		Copper	Copper	
LI46471	27-Jun-19	0	0	1410 BRADLEY AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/21/2019		Copper	Copper	
LI44865	20-Jun-19	8	0	1537 BRADLEY AVE	1ST LITER	Invalid	BATHROOM SINK FIRST DRAW	6/24/2019		Copper	Copper	
LI44866	20-Jun-19	0	0	1537 BRADLEY AVE	5TH LITER	Invalid	BATHROOM SINK FIFTH DRAW	6/24/2019		Copper	Copper	
LI46484	27-Jun-19	0	0	1559 BRADLEY AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/21/2019		Copper	Copper	
LI46485	27-Jun-19	0	0	1559 BRADLEY AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/21/2019		Copper	Copper	
LI46514	27-Jun-19	0	0	1563 BRADLEY AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/21/2019		Copper	Copper	
LI46515	27-Jun-19	0	0	1563 BRADLEY AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/21/2019		Copper	Copper	
LI46476	27-Jun-19	0	0	1567 BRADLEY AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/21/2019		Copper	Copper	
LI46477	27-Jun-19	20	170	1567 BRADLEY AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/21/2019		Copper	Copper	
LI38571	20-May-19	0	0	1647 MISSOURI AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/12/2019		Copper	Copper	
LI38572	20-May-19	0	0	1647 MISSOURI AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/12/2019		Copper	Copper	
LI38555	20-May-19	6	0	2006 MISSOURI AVE	1ST LITER	Invalid	BATHROOM SINK FIRST DRAW	6/12/2019		Copper	Copper	
LI38556	20-May-19	1	0	2006 MISSOURI AVE	5TH LITER	Invalid	BATHROOM SINK FIFTH DRAW	6/12/2019		Copper	Copper	

City of Flint
Tap Sampling Results
January 1-June 30, 2019
UPDATED: 9/26/19

Sample Number	Date Submitted	Result Lead	Result Copper	Address	Liter Number	Status	Sample Description	SLE Date	SLR Date	Public	Private	Comments
LI38565	20-May-19	0	0	2132 MISSOURI AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/12/2019		Copper	Copper	
LI38566	20-May-19	0	0	2132 MISSOURI AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/12/2019		Copper	Copper	
LI38577	20-May-19	0	0	2306 PENNSYLVANIA AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/12/2019		Copper	Copper	
LI38578	20-May-19	0	0	2306 PENNSYLVANIA AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/12/2019		Copper	Copper	
LI38551	20-May-19	0	0	2422 WISCONSIN AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/14/2019		Copper	Copper	
LI38552	20-May-19	0	0	2422 WISCONSIN AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/14/2019		Copper	Copper	
LI46530	27-Jun-19	0	0	2518 CUMINGS AVE	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	6/24/2019		Copper	Copper	
LI46531	27-Jun-19	0	0	2518 CUMINGS AVE	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	6/24/2019		Copper	Copper	
LI38553	20-May-19	1	0	2520 ORCHARD LN	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	5/16/2019		Copper	Copper	
LI38554	20-May-19	3	160	2520 ORCHARD LN	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	5/16/2019		Copper	Copper	
LI38340	16-May-19	0	0	2526 ORCHARD LN	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	5/13/2019		Copper	Copper	
LI38341	16-May-19	0	0	2526 ORCHARD LN	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	5/13/2019		Copper	Copper	
LI38344	16-May-19	0	110	2538 ORCHARD LN	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	5/10/2019		Copper	Copper	
LI38345	16-May-19	0	0	2538 ORCHARD LN	5TH LITER	Invalid	KITCHEN SINK FIFTH LITER	5/10/2019		Copper	Copper	
LI35903	02-May-19	0	0	2617 PROSPECT ST	5TH LITER	Invalid	KITCHEN SINK FIFTH DRAW	12/13/2018		Copper	Copper	
LI35904	02-May-19	0	0	2617 PROSPECT ST	1ST LITER	Invalid	KITCHEN SINK FIRST DRAW	12/13/2018		Copper	Copper	
LI46492	27-Jun-19	0	0	3018 BRANDON ST	5TH LITER	Invalid	FIFTH DRAW	6/25/2019		Copper	Copper	
LI46493	27-Jun-19	0	0	3018 BRANDON ST	1ST LITER	Invalid	FIRST DRAW	6/25/2019		Copper	Copper	
LI46488	27-Jun-19	1	0	425 W FIRST ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record	9/6/2019	Lead	Copper	Email from Dean Oparka 9/17/19- Database has 425 FIRST AVE
LI46489	27-Jun-19	1	100	425 W FIRST ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record	9/6/2019	Lead	Copper	Email from Dean Oparka 9/17/19- Database has 425 FIRST AVE
LI41836	10-Jun-19	1	0	1016 GARLAND ST	1ST LITER	Not Confirmed	KITCHEN SINK 1ST DRAW	No Record	9/16/2019			Not on Phase 6
LI41837	10-Jun-19	0	0	1016 GARLAND ST	5TH LITER	Not Confirmed	KITCHEN SINK 5TH DRAW	No Record	9/16/2019			Not on Phase 6
LI48127	08-Jul-19	0	0	1309 IDA ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				Not on Phase 6
LI48128	08-Jul-19	0	0	1309 IDA ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				Not on Phase 6
LI44843	20-Jun-19	0	80	1617 BROOKWOOD AVE	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				Not on Phase 6
LI44844	20-Jun-19	0	0	1617 BROOKWOOD AVE	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				Not on Phase 6
LI46462	27-Jun-19	0	0	405 BARTLETT PL	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				Not on Phase 6
LI46463	27-Jun-19	0	0	405 BARTLETT PL	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				Not on Phase 6
LI44869	20-Jun-19	0	70	1105 NEUBERT AVE	1ST LITER	Not Confirmed	BATHROOM SINK FIRST DRAW	9/5/2017		Copper	Unknown	
LI44870	20-Jun-19	0	0	1105 NEUBERT AVE	5TH LITER	Not Confirmed	BATHROOM SINK FIFTH DRAW	9/5/2017		Copper	Unknown	
LI46500	27-Jun-19	0	0	1317 BRADLEY AVE	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI46501	27-Jun-19	0	0	1317 BRADLEY AVE	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI43208	13-Jun-19	0	0	1402 E COURT ST	1ST LITER	Not Confirmed	BATHROOM SINK FIRST DRAW	No Record				
LI43209	13-Jun-19	0	0	1402 E COURT ST	5TH LITER	Not Confirmed	BATHROOM SINK FIFTH DRAW	No Record				
LI46466	27-Jun-19	2	0	142 E EDDINGTON AVE	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46467	27-Jun-19	1	0	142 E EDDINGTON AVE	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI38547	20-May-19	1	0	1505 W SECOND ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI38548	20-May-19	4	0	1505 W SECOND ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI46478	27-Jun-19	0	0	1525 BRADLEY AVE	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46479	27-Jun-19	0	0	1525 BRADLEY AVE	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI46480	27-Jun-19	0	0	2023 CLIFFORD ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46481	27-Jun-19	0	0	2023 CLIFFORD ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI43210	13-Jun-19	0	0	2116 CORUNNA RD	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI43211	13-Jun-19	1	0	2116 CORUNNA RD	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI45100	21-Jun-19	1	0	2410 E COURT ST	5TH LITER	Not Confirmed	BATHROOM SINK FIFTH DRAW	6/25/2018				
LI45101	21-Jun-19	2	0	2410 E COURT ST	1ST LITER	Not Confirmed	BATHROOM SINK FIRST DRAW	6/25/2018				
LI44835	20-Jun-19	0	0	2621 BROWN ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI44836	20-Jun-19	0	0	2621 BROWN ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46494	27-Jun-19	0	0	2906 FIELDING ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46495	27-Jun-19	4	0	2906 FIELDING ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI46502	27-Jun-19	2	0	2912 GIBSON ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46503	27-Jun-19	3	50	2912 GIBSON ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				

City of Flint
Tap Sampling Results
January 1-June 30, 2019
UPDATED: 9/26/19

Sample Number	Date Submitted	Result Lead	Result Copper	Address	Liter Number	Status	Sample Description	SLE Date	SLR Date	Public	Private	Comments
LI46506	27-Jun-19	1	0	3017 W COURT ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46507	27-Jun-19	0	0	3017 W COURT ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI46486	27-Jun-19	0	0	3109 BEECHER RD	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI46487	27-Jun-19	0	0	3109 BEECHER RD	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI46508	27-Jun-19	0	70	3209 W COURT ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI46509	27-Jun-19	1	0	3209 W COURT ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI44837	20-Jun-19	0	0	3926 W COURT ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI44838	20-Jun-19	1	0	3926 W COURT ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI44841	20-Jun-19	2	0	4009 W COURT ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI44842	20-Jun-19	2	0	4009 W COURT ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI42299	11-Jun-19	0	0	403 W SIXTH ST	5TH LITER	Not Confirmed	KITCHEN SINK 5TH DRAW	No Record				
LI42300	11-Jun-19	0	0	403 W SIXTH ST	1ST LITER	Not Confirmed	KITCHEN SINK 1ST DRAW	No Record				
LI44821	20-Jun-19	0	0	434 W FIRST AVE	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI44822	20-Jun-19	1	0	434 W FIRST AVE	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI48129	08-Jul-19	2	0	952 HUBBARD AVE	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI48130	08-Jul-19	2	0	952 HUBBARD AVE	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI45094	21-Jun-19	1	60	960 ERIE ST	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI45095	21-Jun-19	2	90	960 ERIE ST	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI44827	20-Jun-19	0	0	967 BARNEY AVE	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI44828	20-Jun-19	0	0	967 BARNEY AVE	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI44863	20-Jun-19	0	0	975 S BALLENGER HWY	1ST LITER	Not Confirmed	KITCHEN SINK FIRST DRAW	No Record				
LI44864	20-Jun-19	0	0	975 S BALLENGER HWY	5TH LITER	Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record				
LI44847	20-Jun-19	0	0	2020 W COURT ST	1ST LITER	SLM Not Confirmed	BATHROOM SINK FIRST DRAW	No Record	9/19/2019			
LI44848	20-Jun-19	0	0	2020 W COURT ST	5TH LITER	SLM Not Confirmed	BATHROOM SINK FIFTH DRAW	No Record	9/19/2019			
LI44839	20-Jun-19	2	0	2609 W COURT ST	1ST LITER	SLM Not Confirmed	KITCHEN SINK FIRST DRAW	No Record	9/19/2019			
LI44840	20-Jun-19	0	0	2609 W COURT ST	5TH LITER	SLM Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record	9/19/2019			
LI46468	27-Jun-19	0	0	2489 W COURT ST	5TH LITER	SLM Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record	9/23/2019			
LI46469	27-Jun-19	0	0	2489 W COURT ST	1ST LITER	SLM Not Confirmed	KITCHEN SINK FIRST DRAW	No Record	9/23/2019			
LI44867	20-Jun-19	0	0	3912 W COURT ST	1ST LITER	SLM Not Confirmed	KITCHEN SINK FIRST DRAW	No Record	9/25/2019			
LI44868	20-Jun-19	0	0	3912 W COURT ST	5TH LITER	SLM Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record	9/25/2019			
LI44855	20-Jun-19	0	0	3922 W COURT ST	1ST LITER	SLM Not Confirmed	KITCHEN SINK FIRST DRAW	No Record	9/25/2019			
LI44856	20-Jun-19	0	0	3922 W COURT ST	5TH LITER	SLM Not Confirmed	KITCHEN SINK FIFTH DRAW	No Record	9/25/2019			
LI41830	10-Jun-19	0	0	4301 RED ARROW RD	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	10/16/2017	7/16/2019	Lead	Galvanized	10/16/17 Hydrovac revealed Unknown-Lead
LI41831	10-Jun-19	0	0	4301 RED ARROW RD	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	10/16/2017	7/16/2019	Lead	Galvanized	10/16/17 Hydrovac revealed Unknown-Lead
LI41834	10-Jun-19	1	0	735 VICTORIA AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	7/7/2017	7/31/2019	Lead	Galvanized	7/7/17 Hydrovac revealed Unknown-Unknown
LI41835	10-Jun-19	2	0	735 VICTORIA AVE	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	7/7/2017	7/31/2019	Lead	Galvanized	7/7/17 Hydrovac revealed Unknown-Unknown
LI41828	10-Jun-19	6	0	2120 MONTEITH ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	8/11/2017		Lead	Galvanized	8/11/17 Hyrdovac revealed Unknown-Unknown
LI41829	10-Jun-19	6	0	2120 MONTEITH ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	8/11/2017		Lead	Galvanized	8/11/17 Hyrdovac revealed Unknown-Unknown
LI43204	13-Jun-19	0	0	710 DICKINSON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/8/2017		Lead	Galvanized	DECLINED SLR- From WT Stevens Report to Bincsik 9-6-19
LI43205	13-Jun-19	0	0	710 DICKINSON ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	9/8/2017		Lead	Galvanized	DECLINED SLR- From WT Stevens Report to Bincsik 9-6-19
LI44861	20-Jun-19	0	0	1239 BOSTON AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/19/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI44862	20-Jun-19	0	0	1239 BOSTON AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	No Record	8/19/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI46504	27-Jun-19	0	0	3311 BEECHER RD	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	No Record	8/26/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI46505	27-Jun-19	0	0	3311 BEECHER RD	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/26/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI46474	27-Jun-19	1	0	3617 BEECHER RD	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	No Record	8/26/2019	Lead	Lead	Email from Dean Oparka 9/17/19
LI46475	27-Jun-19	0	0	3617 BEECHER RD	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/26/2019	Lead	Lead	Email from Dean Oparka 9/17/19
LI44823	20-Jun-19	0	0	415 W FOURTH AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	9/11/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI44824	20-Jun-19	0	0	415 W FOURTH AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	No Record	9/11/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI38563	20-May-19	34	130	1406 ROOSEVELT AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/12/2017	7/31/2019	Lead	Copper	Form states replaced hot water heater 1 week before sample
LI38564	20-May-19	2	0	1406 ROOSEVELT AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	9/12/2017	7/31/2019	Lead	Copper	Form states replaced hot water heater 1 week before sample
LI41492	06-Jun-19	41	0	2025 BONBRIGHT ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	10/10/2017	8/13/2019	Lead	Galvanized	Form states some pipes replaced because of leaks
LI41493	06-Jun-19	0	0	2025 BONBRIGHT ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	10/10/2017	8/13/2019	Lead	Galvanized	Form states some pipes replaced because of leaks

City of Flint
Tap Sampling Results
January 1-June 30, 2019
UPDATED: 9/26/19

Sample Number	Date Submitted	Result Lead	Result Copper	Address	Liter Number	Status	Sample Description	SLE Date	SLR Date	Public	Private	Comments
LI38567	20-May-19	0	0	2210 MISSOURI AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST LITER	7/17/2017	6/13/2019	Lead	Galvanized	From ROWE List to F&V
LI38568	20-May-19	0	0	2210 MISSOURI AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH LITER	7/17/2017	6/13/2019	Lead	Galvanized	From ROWE List to F&V
LI38543	20-May-19	0	0	2601 WISCONSIN AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	9/7/2017	6/14/2019	Lead	Copper	From ROWE List to F&V
LI38544	20-May-19	0	60	2601 WISCONSIN AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/7/2017	6/14/2019	Lead	Copper	From ROWE List to F&V
LI41842	10-Jun-19	0	0	711 WELCH BLVD	1ST LITER	Tier 1	BATHROOM SINK 1ST DRAW		6/18/2019	Lead	Galvanized	From ROWE List to F&V
LI41843	10-Jun-19	0	0	711 WELCH BLVD	5TH LITER	Tier 1	BATHROOM SINK 5TH DRAW		6/18/2019	Lead	Galvanized	From ROWE List to F&V
LI45096	21-Jun-19	0	0	109 E BISHOP AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	7/17/2019	6/19/2019	Lead	Galvanized	From ROWE List to F&V
LI45097	21-Jun-19	0	0	109 E BISHOP AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	7/17/2019	6/19/2019	Lead	Galvanized	From ROWE List to F&V
LI38573	20-May-19	0	0	1314 ROOSEVELT AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		6/21/2019	Lead	Galvanized	From ROWE List to F&V
LI38574	20-May-19	0	0	1314 ROOSEVELT AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		6/21/2019	Lead	Galvanized	From ROWE List to F&V
LI43206	13-Jun-19	1	0	1222 HUGHES AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		6/27/2019	Lead	Copper	From ROWE List to F&V
LI43207	13-Jun-19	0	0	1222 HUGHES AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		6/27/2019	Lead	Copper	From ROWE List to F&V
LI43200	13-Jun-19	0	0	1406 MANN AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/2/2019	Lead	Galvanized	From ROWE List to F&V
LI43201	13-Jun-19	0	0	1406 MANN AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		7/2/2019	Lead	Galvanized	From ROWE List to F&V
LI43214	13-Jun-19	0	0	1710 CHELSEA CIR	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	8/31/2017	7/8/2019	Lead	Galvanized	From ROWE List to F&V
LI43215	13-Jun-19	0	0	1710 CHELSEA CIR	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	8/31/2017	7/8/2019	Lead	Galvanized	From ROWE List to F&V
LI43212	13-Jun-19	0	0	2023 CARTIER ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	8/4/2017	8/22/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI43213	13-Jun-19	0	0	2023 CARTIER ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	8/4/2017	8/22/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI43202	13-Jun-19	0	0	2222 ADAMS AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	7/11/2017	8/22/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI43203	13-Jun-19	0	0	2222 ADAMS AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	7/11/2017	8/22/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI41494	06-Jun-19	3	0	4018 OGEMA AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	7/6/2017	8/26/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI41495	06-Jun-19	1	0	4018 OGEMA AVE	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	7/6/2017	8/26/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI44829	20-Jun-19	3	0	1109 NEUBERT AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/5/2017	8/29/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI44830	20-Jun-19	2	0	1109 NEUBERT AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	9/5/2017	8/29/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI42295	11-Jun-19	0	0	906 SPENCER ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	10/4/2017	8/29/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI42296	11-Jun-19	0	0	906 SPENCER ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	10/4/2017	8/29/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI41504	06-Jun-19	0	0	1107 OAK ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	No Record	8/21/2019	Lead	Copper	Identified through email from R. Jones 9-9-19
LI41505	06-Jun-19	0	0	1107 OAK ST	5TH LITER	Tier 1	KITCHEN SINK 1ST DRAW	No Record	8/21/2019	Lead	Copper	Identified through email from R. Jones 9-9-19
LI38545	20-May-19	1	0	1209 ANN ARBOR ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	10/3/2017	9/4/2019	Lead	Copper	Identified through email from R. Jones 9-9-19-SLE was L-G
LI38546	20-May-19	35	120	1209 ANN ARBOR ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	10/3/2017	9/4/2019	Lead	Copper	Identified through email from R. Jones 9-9-19-SLE was L-G
LI41840	10-Jun-19	0	0	1619 LYON ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		7/12/2019	Lead	Galvanized	Not on Phase 6
LI41841	10-Jun-19	0	0	1619 LYON ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW		7/12/2019	Lead	Galvanized	Not on Phase 6
LI44859	20-Jun-19	15	0	1412 BROOKWOOD AVE	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW	No Record	8/2/2019	Lead	Copper	Not on Phase 6
LI44860	20-Jun-19	5	0	1412 BROOKWOOD AVE	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW	No Record	8/2/2019	Lead	Copper	Not on Phase 6
LI41502	06-Jun-19	0	0	1208 HUGHES AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		6/26/2019	Lead	Copper	Not on Phase 6-From ROWE List to F&V
LI41503	06-Jun-19	0	0	1208 HUGHES AVE	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW		6/26/2019	Lead	Copper	Not on Phase 6-From ROWE List to F&V
LI41496	06-Jun-19	1	0	3305 HERRICK ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		6/7/2018	Lead	Galvanized	
LI41497	06-Jun-19	0	0	3305 HERRICK ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW		6/7/2018	Lead	Galvanized	
LI38569	20-May-19	0	0	720 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI38570	20-May-19	0	0	720 STOCKTON ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		5/28/2019	Lead	Galvanized	
LI38549	20-May-19	0	0	725 STOCKTON ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		5/28/2019	Lead	Galvanized	
LI38550	20-May-19	3	0	725 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI38557	20-May-19	0	0	726 STOCKTON ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		5/28/2019	Lead	Galvanized	
LI38558	20-May-19	0	0	726 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI38561	20-May-19	0	0	727 STOCKTON ST	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW		5/28/2019	Lead	Copper	
LI38562	20-May-19	0	110	727 STOCKTON ST	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW		5/28/2019	Lead	Copper	
LI38575	20-May-19	0	0	801 STOCKTON ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		5/28/2019	Lead	Galvanized	
LI38576	20-May-19	0	80	801 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI38559	20-May-19	0	0	717 OAK ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		5/29/2019	Lead	Copper	
LI38560	20-May-19	0	130	717 OAK ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/29/2019	Lead	Copper	
LI39331	23-May-19	0	0	723 OAK ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		5/29/2019	Lead	Galvanized	
LI39332	23-May-19	0	0	723 OAK ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW		5/29/2019	Lead	Galvanized	

City of Flint
Tap Sampling Results
January 1-June 30, 2019
UPDATED: 9/26/19

Sample Number	Date Submitted	Result Lead	Result Copper	Address	Liter Number	Status	Sample Description	SLE Date	SLR Date	Public	Private	Comments
LI44831	20-Jun-19	1	0	105 E GENESEE ST	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW	9/5/2017	6/28/2019	Lead	Copper	
LI44832	20-Jun-19	1	0	105 E GENESEE ST	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW	9/5/2017	6/28/2019	Lead	Copper	
LI48123	08-Jul-19	1	0	314 WESTCOMBE AVE	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW		6/28/2019	Lead	Galvanized	
LI48124	08-Jul-19	0	90	314 WESTCOMBE AVE	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW		6/28/2019	Lead	Galvanized	
LI46464	27-Jun-19	0	0	311 WESTCOMBE AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		7/1/2019	Lead	Lead	
LI46465	27-Jun-19	0	0	311 WESTCOMBE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/1/2019	Lead	Lead	
LI48121	08-Jul-19	4	0	336 WESTCOMBE AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		7/2/2019	Lead	Copper	
LI48122	08-Jul-19	6	50	336 WESTCOMBE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/2/2019	Lead	Copper	
LI48135	08-Jul-19	2	0	331 WESTCOMBE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	10/24/2016	7/9/2019	Lead	Copper	
LI48136	08-Jul-19	0	0	331 WESTCOMBE AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	10/24/2016	7/9/2019	Lead	Copper	
LI41498	06-Jun-19	0	0	1325 KIRK AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		7/11/2019	Lead	Lead	
LI41499	06-Jun-19	0	0	1325 KIRK AVE	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW		7/11/2019	Lead	Lead	
LI42297	11-Jun-19	0	0	1413 CRONK AVE	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	9/11/2017	7/12/2019	Lead	Galvanized	
LI42298	11-Jun-19	0	0	1413 CRONK AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	9/11/2017	7/12/2019	Lead	Galvanized	
LI42291	11-Jun-19	0	0	1729 NEBRASKA AVE	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	7/5/2017	7/15/2019	Lead	Copper	
LI42292	11-Jun-19	0	0	1729 NEBRASKA AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	7/5/2017	7/15/2019	Lead	Copper	
LI41500	06-Jun-19	0	0	116 E TOBIAS ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	7/24/2017	7/17/2019	Lead	Galvanized	
LI41501	06-Jun-19	0	0	116 E TOBIAS ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	7/24/2017	7/17/2019	Lead	Galvanized	
LI44857	20-Jun-19	0	0	1021 BLANCHARD AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/18/2019	Lead	Copper	
LI44858	20-Jun-19	0	0	1021 BLANCHARD AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		7/18/2019	Lead	Copper	
LI48125	08-Jul-19	0	0	213 E EDDINGTON AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/18/2019	Lead	Copper	
LI48126	08-Jul-19	0	0	213 E EDDINGTON AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		7/18/2019	Lead	Copper	
LI42285	11-Jun-19	0	0	242 E LIVINGSTON DR	5TH LITER	Tier 1	BATHROOM SINK 5TH DRAW	8/10/2017	7/18/2019	Lead	Copper	
LI42286	11-Jun-19	0	0	242 E LIVINGSTON DR	1ST LITER	Tier 1	BATHROOM SINK 1ST LITER	8/10/2017	7/18/2019	Lead	Copper	
LI45090	21-Jun-19	1	0	1240 LELAND ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		7/22/2019	Lead	Galvanized	
LI45091	21-Jun-19	3	0	1240 LELAND ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/22/2019	Lead	Galvanized	
LI46510	27-Jun-19	0	0	1306 BLANCHARD AVE	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW		7/23/2019	Lead	Galvanized	
LI46511	27-Jun-19	0	0	1306 BLANCHARD AVE	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW		7/23/2019	Lead	Galvanized	
LI39333	23-May-19	1	0	909 STOCKTON ST	1ST LITER	Tier 1	BATHROOM SINK 1ST DRAW		7/24/2019	Lead	Galvanized	
LI39334	23-May-19	0	0	909 STOCKTON ST	5TH LITER	Tier 1	BATHROOM SINK 5TH DRAW		7/24/2019	Lead	Galvanized	
LI44815	20-Jun-19	2	0	1209 BLANCHARD AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/25/2019	Lead	Galvanized	
LI44816	20-Jun-19	0	0	1209 BLANCHARD AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW		7/25/2019	Lead	Galvanized	
LI41832	10-Jun-19	0	0	728 THOMSON ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	No Record	7/31/2019	Lead	Galvanized	
LI41833	10-Jun-19	7	0	728 THOMSON ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	No Record	7/31/2019	Lead	Galvanized	
LI44851	20-Jun-19	2	0	1016 INGLESIDE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	8/14/2017	8/7/2019	Lead	Copper	
LI44852	20-Jun-19	2	70	1016 INGLESIDE AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	8/14/2017	8/7/2019	Lead	Copper	
LI46498	27-Jun-19	0	0	1549 JANE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/14/2019	Lead	Galvanized	
LI46499	27-Jun-19	0	0	1549 JANE AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	No Record	8/14/2019	Lead	Galvanized	
LI48131	08-Jul-19	2	100	1112 BEARD ST	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW	No Record	8/15/2019	Lead	Copper	
LI48132	08-Jul-19	3	0	1112 BEARD ST	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW	No Record	8/15/2019	Lead	Copper	
LI44817	20-Jun-19	0	0	1233 MARKHAM ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/22/2019	Lead	Copper	
LI44818	20-Jun-19	0	0	1233 MARKHAM ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	No Record	8/22/2019	Lead	Copper	
LI44819	20-Jun-19	0	0	539 LETA AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	12/10/2018	8/27/2019	Lead	Galvanized	
LI44820	20-Jun-19	0	0	539 LETA AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	12/10/2018	8/27/2019	Lead	Galvanized	
LI44845	20-Jun-19	7	100	132 W TAYLOR ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	8/24/2017		Lead	Lead	
LI44846	20-Jun-19	3	0	132 W TAYLOR ST	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	8/24/2017		Lead	Lead	
LI42289	11-Jun-19	0	0	1919 LEVERN ST	5TH LITER	Tier 1	KITCHEN SINK 1ST DRAW	8/16/2017		Lead	Galvanized	
LI42290	11-Jun-19	3	0	1919 LEVERN ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	8/16/2017		Lead	Galvanized	
LI45088	21-Jun-19	0	0	834 LINCOLN AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	9/9/2017		Lead	Galvanized	
LI45089	21-Jun-19	0	0	834 LINCOLN AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/9/2017		Lead	Galvanized	

City of Flint
LCR Tier 1 Tap Samples by Concentration
January 1-June 30, 2019

Sample Number	Date Submitted	Result Lead	Result Copper	Address	Liter Number	Status	Sample_Description	SLE Date	SLR Date	Public	Private	Extra Info
LI44857	20-Jun-19	0	0	1021 BLANCHARD AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/18/2019	Lead	Copper	
LI45097	21-Jun-19	0	0	109 E BISHOP AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	7/17/2019	6/19/2019	Lead	Galvanized	From ROWE List to F&V
LI41504	06-Jun-19	0	0	1107 OAK ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	No Record	8/21/2019	Lead	Copper	Identified through email from R. Jones 9-9-19
LI41500	06-Jun-19	0	0	116 E TOBIAS ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	7/24/2017	7/17/2019	Lead	Galvanized	
LI41502	06-Jun-19	0	0	1208 HUGHES AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		6/26/2019	Lead	Copper	Not on Phase 6-From ROWE List to F&V
LI44817	20-Jun-19	0	0	1233 MARKHAM ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record		Lead	Copper	
LI44861	20-Jun-19	0	0	1239 BOSTON AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/19/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI46511	27-Jun-19	0	0	1306 BLANCHARD AVE	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW		7/23/2019	Lead	Galvanized	
LI38573	20-May-19	0	0	1314 ROOSEVELT AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		6/21/2019	Lead	Galvanized	From ROWE List to F&V
LI41498	06-Jun-19	0	0	1325 KIRK AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		7/11/2019	Lead	Lead	
LI43200	13-Jun-19	0	0	1406 MANN AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/2/2019	Lead	Galvanized	From ROWE List to F&V
LI42298	11-Jun-19	0	0	1413 CRONK AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	9/11/2017	7/12/2019	Lead	Galvanized	
LI46498	27-Jun-19	0	0	1549 JANE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/14/2019	Lead	Galvanized	
LI41840	10-Jun-19	0	0	1619 LYON ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		7/12/2019	Lead	Galvanized	Not on Phase 6
LI43214	13-Jun-19	0	0	1710 CHELSEA CIR	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	8/31/2017	7/8/2019	Lead	Galvanized	From ROWE List to F&V
LI42292	11-Jun-19	0	0	1729 NEBRASKA AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	7/5/2017	7/15/2019	Lead	Copper	
LI43212	13-Jun-19	0	0	2023 CARTIER ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	8/4/2017		Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI48125	08-Jul-19	0	0	213 E EDDINGTON AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/18/2019	Lead	Copper	
LI38567	20-May-19	0	0	2210 MISSOURI AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST LITER	7/17/2017	6/13/2019	Lead	Galvanized	From ROWE List to F&V
LI43202	13-Jun-19	0	0	2222 ADAMS AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	7/11/2017		Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI42286	11-Jun-19	0	0	242 E LIVINGSTON DR	1ST LITER	Tier 1	BATHROOM SINK 1ST LITER	8/10/2017	7/18/2019	Lead	Copper	
LI38544	20-May-19	0	60	2601 WISCONSIN AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/7/2017	6/14/2019	Lead	Copper	From ROWE List to F&V
LI46465	27-Jun-19	0	0	311 WESTCOMBE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/1/2019	Lead	Lead	
LI46505	27-Jun-19	0	0	3311 BEECHER RD	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	8/26/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI44823	20-Jun-19	0	0	415 W FOURTH AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	No Record	9/11/2019	Lead	Copper	Email from Dean Oparka 9/17/19
LI41830	10-Jun-19	0	0	4301 RED ARROW RD	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	10/16/2017	7/16/2019	Lead	Galvanized	10/16/17 Hydrovac revealed Unknown-Lead
LI44819	20-Jun-19	0	0	539 LETA AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	12/10/2018	8/27/2019	Lead	Galvanized	
LI43204	13-Jun-19	0	0	710 DICKINSON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/8/2017		Lead	Galvanized	
LI41842	10-Jun-19	0	0	711 WELCH BLVD	1ST LITER	Tier 1	BATHROOM SINK 1ST DRAW		6/18/2019	Lead	Galvanized	From ROWE List to F&V
LI38560	20-May-19	0	130	717 OAK ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/29/2019	Lead	Copper	
LI38569	20-May-19	0	0	720 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI39331	23-May-19	0	0	723 OAK ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		5/29/2019	Lead	Galvanized	
LI38558	20-May-19	0	0	726 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI38562	20-May-19	0	110	727 STOCKTON ST	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW		5/28/2019	Lead	Copper	
LI38576	20-May-19	0	80	801 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI45089	21-Jun-19	0	0	834 LINCOLN AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/9/2017		Lead	Galvanized	
LI42296	11-Jun-19	0	0	906 SPENCER ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	10/4/2017	8/28/2019	Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI44831	20-Jun-19	1	0	105 E GENESEE ST	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW	9/5/2017	6/28/2019	Lead	Copper	
LI43206	13-Jun-19	1	0	1222 HUGHES AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		6/27/2019	Lead	Copper	From ROWE List to F&V
LI48123	08-Jul-19	1	90	314 WESTCOMBE AVE	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW		6/28/2019	Lead	Galvanized	
LI41496	06-Jun-19	1	0	3305 HERRICK ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW		6/7/2018	Lead	Galvanized	
LI46474	27-Jun-19	1	0	3617 BEECHER RD	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	No Record	8/26/2019	Lead	Lead	Email from Dean Oparka 9/17/19
LI39333	23-May-19	1	0	909 STOCKTON ST	1ST LITER	Tier 1	BATHROOM SINK 1ST DRAW		7/24/2019	Lead	Galvanized	
LI44852	20-Jun-19	2	70	1016 INGLESIDE AVE	5TH LITER	Tier 1	KITCHEN SINK FIFTH DRAW	8/14/2017	8/7/2019	Lead	Copper	
LI44815	20-Jun-19	2	0	1209 BLANCHARD AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/25/2019	Lead	Galvanized	
LI48135	08-Jul-19	2	0	331 WESTCOMBE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	10/24/2016	7/9/2019	Lead	Copper	
LI41835	10-Jun-19	2	0	735 VICTORIA AVE	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	7/7/2017	7/31/2019	Lead	Galvanized	
LI44829	20-Jun-19	3	0	1109 NEUBERT AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/5/2017		Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI48132	08-Jul-19	3	100	1112 BEARD ST	5TH LITER	Tier 1	BATHROOM SINK FIFTH DRAW	No Record	8/15/2019	Lead	Copper	
LI45091	21-Jun-19	3	0	1240 LELAND ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/22/2019	Lead	Galvanized	
LI42290	11-Jun-19	3	0	1919 LEVERN ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	8/16/2017		Lead	Galvanized	
LI41494	06-Jun-19	3	0	4018 OGEMA AVE	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	7/6/2017		Lead	Galvanized	From WT Stevens Report to Bincsik 9-6-19
LI38550	20-May-19	3	0	725 STOCKTON ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		5/28/2019	Lead	Galvanized	
LI41828	10-Jun-19	6	0	2120 MONTEITH ST	1ST LITER	Tier 1	KITCHEN SINK 1ST DRAW	8/11/2017		Lead	Galvanized	8/11/17 Hyrdovac revealed Unknown-Unknown
LI48122	08-Jul-19	6	50	336 WESTCOMBE AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW		7/2/2019	Lead	Copper	
LI44845	20-Jun-19	7	100	132 W TAYLOR ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	8/24/2017		Lead	Lead	
LI41833	10-Jun-19	7	0	728 THOMSON ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	No Record	7/31/2019	Lead	Galvanized	
LI44859	20-Jun-19	15	0	1412 BROOKWOOD AVE	1ST LITER	Tier 1	BATHROOM SINK FIRST DRAW	No Record	8/2/2019	Lead	Copper	Not on Phase 6
LI38563	20-May-19	34	130	1406 ROOSEVELT AVE	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	9/12/2017	7/31/2019	Lead	Copper	Form states replaced hot water heater 1 week before sample
LI38546	20-May-19	35	120	1209 ANN ARBOR ST	1ST LITER	Tier 1	KITCHEN SINK FIRST DRAW	10/3/2017		Lead	Galvanized	
LI41492	06-Jun-19	41	0	2025 BONBRIGHT ST	5TH LITER	Tier 1	KITCHEN SINK 5TH DRAW	10/10/2017	8/13/2019	Lead	Galvanized	Form states some pipes replaced because of leaks