

STATE OF MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY

LANSING



C. HEIDI GRETHER DIRECTOR

October 22, 2018

VIA E-MAIL

The Honorable Karen Williams Weaver Mayor of Flint 1101 South Saginaw Street Flint, Michigan 48502

Dear Mayor Weaver:

SUBJECT: Order Under MCL 325.1015(2) of Michigan's Safe Drinking Water Act

An Order under MCL 325.1015(2) of Michigan's Safe Drinking Water Act, 1976 PA 399, as amended, is enclosed with this letter. The Michigan Department of Environmental Quality (MDEQ) does not often issue orders unilaterally because the MDEQ and the entity in question nearly always agree to the content of a stipulated order entered with the consent of both parties. The MDEQ has been unable to reach a stipulated order with the city of Flint (City).

I strongly emphasize that the quality of the City's water is high. The City's water system is perhaps the most monitored system in the country. For more than two years, that monitoring has proven that the City's water system is stable. From the perspective of lead and copper control, the quality of the City's water matches or exceeds that of comparable water systems in Michigan.

The enclosed Order addresses long-term technical and managerial issues with the City's water system, not the current quality of the City's water. The City relies heavily on state and federal technical support to manage its water system. The reliance on outside entities for long-term technical support is not the preference of either the City or the MDEQ. The MDEQ shares the City's goal that the City achieve long-term self-reliance. The purpose of the enclosed Order is to establish firm deadlines that chart the path toward achieving that goal.

On August 11, 2017, the MDEQ identified several deficiencies in the City's water system related primarily to its technical, managerial, and financial capacity to sustainably produce high-quality water on a long-term basis without significant outside support. The MDEQ and the City have worked informally since that time to address the outstanding deficiencies, with some success. For example, the City has strengthened its existing contract with a private firm to ensure there is a qualified operator in charge of the City's water plant; has designated an employee to be a cross connection control manager; has updated its emergency response plan; and has adopted several recommended standard operating procedures.

The Honorable Karen Williams Weaver Page 2 October 22, 2018

Notwithstanding those improvements, some deficiencies remain outstanding. The MDEQ has attempted to negotiate a consent order with the City that contains enforceable deadlines by which the City will resolve those outstanding deficiencies. For example, the City still needs to adopt several standard operating procedures; fill vacant positions; and implement its plan to fully achieve technical, managerial, and financial capacity. The City has repeatedly committed informally to resolve the outstanding deficiencies, but it has been unwilling to agree to enforceable deadlines. Experience has shown that enforceable deadlines are necessary to ensure that the City's water system can provide adequate and healthful water to the City's residents, in compliance with state and federal law, on a sustainable, long-term basis.

Under MCL 325.1015(2), the Order will be effective 30 days from the date of this letter. Within those 30 days, the City can request a public hearing [not a contested case hearing because this Order is not issued under MCL 325.1015(3)], but the request must comply with Rule 325.10202 of the Michigan Administrative Code. If the City requests a public hearing, then the Order will not be effective until the public hearing is complete, at which time the MDEQ will notify the City by letter of the effective date of the Order.

Once the Order is effective, the City can appeal it to either the Genesee County Circuit Court or the Ingham County Circuit Court, if it so chooses. Michigan's Safe Drinking Water Act does not contain a method of judicial review specific to the Order, and the Order is not the result of a contested case hearing under the Administrative Procedures Act, 1969 PA 306, as amended, so any appeal by the City would be under MCL 600.631. Note that an appeal under MCL 600.631 would not automatically stay the Order, and the procedure for filing the appeal would be governed by MCR 7.123, including a strict 21-day deadline to file a claim of appeal.

Again, I strongly emphasize that the quality of the City's water is high. The enclosed Order is intended to enable the City to reach the shared goal of the City and the MDEQ that the City achieve long-term self-reliance.

If you have any questions regarding this matter, please contact Mr. Eric J. Oswald, Director, Drinking Water and Municipal Assistance Division, at 517-284-6544; oswalde1@michigan.gov; or MDEQ, P.O. Box 30817, Lansing, Michigan 48909-8311; or you may contact me.

Sincerely,

leide Grether

C. Heidi Grether Director 517-284-6700

Enclosure

The Honorable Karen Williams Weaver Page 3 October 22, 2018

cc/enc: Ms. Cathy Stepp, Regional Administrator, United States Environmental Protection Agency (USEPA), Region 5

Ms. Linda Holst, Acting Director, Water Division, USEPA, Region 5

Mr. Keith Creagh, Director, Michigan Department of Natural Resources

Mr. Richard Baird, Governor's Office

Mr. S. Peter Manning, Michigan Department of Attorney General

Mr. Aaron B. Keatley, Chief Deputy Director, MDEQ

Mr. Eric J. Oswald, MDEQ

STATE OF MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY

DWMAD Order No. 399-09-2018

In the matter of: City of Flint 1101 South Saginaw Street Flint, Michigan 48502

ORDER

This document results from findings by the Department of Environmental Quality (DEQ), Drinking Water and Municipal Assistance Division (DWMAD). The DEQ found that the city of Flint (City) located at 1101 South Saginaw Street, Flint, Michigan, is in violation of the Michigan Safe Drinking Water Act, 1976 PA 399, as amended (Act 399), and the administrative rules promulgated thereunder, being 2009 ACS, R 325.10101 *et seq.* and Title XIV of the Public Health Service Act: Safety of Public Water Systems (Safe Drinking Water Act), Title 42 of the United States Code (USC), §300f *et seq.* (SDWA). The City is a supplier of water as defined under Act 399 and the SDWA through the City's ownership and operation of a Class D1 water treatment system and S1 water distribution system. The DEQ orders the City to resolve the violations set forth herein.

I. BACKGROUND

- 1.1 The SDWA establishes national primary drinking water regulations that apply to each public water system in each state.
- 1.2 Section 1420 of the SDWA establishes that a State must develop a program to ensure that all new community water systems demonstrate technical, managerial, and financial capacity to comply with all national primary drinking water regulations in effect on the date of commencement of operations and that a State shall develop and implement a strategy to assist public water systems in acquiring and maintaining technical, managerial, and financial capacity. 42 USC, §300g-9.

1.3 Section 1452(a)(3) of the SDWA provides:

(A) In General - Except as provided in subparagraph (B), no assistance under this section shall be provided to a public water system that--

(i) does not have the technical, managerial, and financial capability to ensure compliance with the requirements of this title; or

(ii) is in significant noncompliance with any requirement of a national primary drinking water regulation or variance.

(B) Restructuring - A public water system described in subparagraph (A) may receive assistance under this section if--

(i) the use of the assistance will ensure compliance; and

(ii) if subparagraph (A)(i) applies to the system, the owner or operator of the system agrees to undertake feasible and appropriate changes in operations (including ownership, management, accounting, rates, maintenance, consolidation, alternative water supply, or other procedures) if the State determines that the measures are necessary to ensure that the system has the technical, managerial, and financial capability to comply with the requirements of this title over the long term. 42 USC, §300j-12(a)(3).

- 1.4 The DEQ has been delegated primary responsibility for the implementation and enforcement of the public water system program in Michigan by the United States Environmental Protection Agency. The DEQ has regulatory power over public water supplies and suppliers of water under MCL 325.1003 and 42 USC, §300g-2.
- 1.5 Act 399 and its corresponding rules, along with the SDWA and its corresponding rules, are pertinent to providing safe and reliable public drinking water.
- 1.6 MCL 325.1003b and MCL 325.1004(2)(b) authorize the DEQ to conduct capacity assessments and determine if a water system has technical, financial, and managerial capacity to meet all the requirements of Act 399 and the SDWA.
- 1.7 MCL 325.1015(2) provides that the DEQ "may order the supplier of water to make alterations in the waterworks system or its method of operation as may be required or considered advisable by the department [DEQ] to ensure the public water supply is adequate, healthful, and in conformance with state drinking water standards."
- 1.8 Section 1431(a) of the SDWA provides that "the Administrator, upon receipt of information that a contaminant which is present in or is likely to enter a public water system or an underground source of drinking water may present an imminent and substantial endangerment to the health of persons, and that appropriate State and local

-2-

authorities have not acted to protect the health of such persons, may take such actions as he may deem necessary in order to protect the health of such persons." 42 USC, §300i(a).

- Section 1419 of the SDWA requires States to implement a program for the certification of operators of community and nontransient noncommunity public water systems.
 42 USC, §300g-8.
- 1.10 In accordance with R 325.10504 and R 325.11905, a Type I public water supply is required to obtain certified operators of treatment systems and distribution systems.
- 1.11 R 325.10504(c) provides that Type I public water supplies shall "Submit waterworks system operation reports and maintain records" and R 325.11111 provides "A public water supply shall maintain adequate records on the operation of the water distribution system, on the location and type of maintenance performed, and on the type of materials and appurtenances used."
- 1.12 Unless specifically waived by the DEQ, a Type I public water supply shall prepare, or cause to be prepared, an emergency response plan. Michigan Administrative Code (MAC), R 325.12302(1); 42 USC, §300i-2.
- 1.13 In accordance with R 325.11404(1), a water utility shall develop a comprehensive control program for the elimination and prevention of all cross connections. The plan for the program shall be submitted to the DEQ for review and approval. Public water supplies may use the Cross Connections Rules Manual prepared by the DEQ, Water Bureau, under R 325.10113 as guidance when developing a cross connection control program. When the plan is approved, the water utility shall implement the program for removal of all existing cross connections and prevention of all future cross connections.
- 1.14 This Order constitutes a final order of the DEQ pursuant to Michigan Compiled Laws (MCL) 325.1015(2), enforceable in accordance with MCL 325.1021, MCL 325.1022, 42 USC, §300g-3, and 42 USC, §300j-8. The City must achieve compliance with the aforementioned regulations in accordance with the requirements contained in Section III, Compliance Program, of this Order.

-3-

II. FINDINGS

- 2.1 On August 7, 2017, DWMAD staff conducted a sanitary survey of the City's drinking water system to evaluate the City water distribution, storage, pumping, and limited treatment systems with respect to Act 399 and the SDWA.
- 2.2 On August 11, 2017, the DWMAD issued a Significant Deficiency Violation Notice (SDVN) to the City, listing a summary of significant deficiencies, minor deficiencies, and recommendations applicable to the City's water system (Attachment A). The SDVN directed the City to either complete corrective action or be in compliance with a corrective action plan and schedule within 120 days.
- 2.3 The City failed to correct the significant deficiencies identified in the SDVN within 120 days and did not enter into a corrective action plan.
- 2.4 The City provided a written response to the SDVN on September 8, 2017 (Attachment B).
- 2.5 A follow-up letter dated March 21, 2018, was sent to the City by the DWMAD, summarizing corrective actions that had been completed and providing dates to complete other corrective actions (Attachment C).
- 2.6 <u>Correction of the significant deficiencies and deficiencies listed in the SDVN and</u> <u>March 21, 2018, letter is necessary to ensure the public water supply in Flint is</u> <u>adequate, healthful, and in compliance with state and federal drinking water</u> <u>standards, to prevent contaminants from entering the water supply, and to prevent</u> <u>imminent and substantial endangerment of public health.</u>

III. COMPLIANCE PROGRAM

IT IS, THEREFORE, ORDERED THAT the City shall undertake the following actions to ensure that Flint's water system can provide safe drinking water to the public on a long-term, sustainable basis:

-4-

- 3.1 The City shall, not later than **December 31, 2018**, select and approve one of the cross connection control model programs from the DEQ's Cross Connection Rules Manual and submit the approved model to the DEQ for review and approval.
- 3.2 If the City does not get a cross connection control program approved as required in paragraph 3.1, the City shall, not later than **December 31, 2018**, submit to the DEQ an updated list of water accounts classified as high hazard, low hazard, and other, and a schedule for conducting inspections at those accounts.
- 3.3 If the City does not get a cross connection control program approved as required in paragraph 3.1, the City shall, not later than June 30, 2019, conduct and document at least 100 cross connection inspections required in 2019 at high-hazard accounts and at least 100 cross connection inspections required in 2019 at low-hazard accounts.
- 3.4 The City shall, within **five days** of entry of this Order, submit a time line indicating when it will approve of those Standard Operating Procedures submitted by the Arcadis Group on June 4, 2018, that the City has not already approved as of the date this Order is entered.
- 3.5 The City provided a July 25, 2018, Technical, Management, and Financial Capacity proposal in which it explains its plan to achieve its technical, managerial, and financial (TMF) capacity by fiscal year (FY) 2023 (Attachment D). The City acknowledges that the revenue generated by the City's Water Department is not sufficient to support the operating costs of the City's water system but does not believe it would be politically or financially possible to increase customer rates until several years from now. So the proposal describes several steps the City plans to take leading up to FY 2023 to achieve TMF capacity without raising customer rates. Beginning on the date this Order is effective, and every six months thereafter until the City achieves TMF capacity, the City shall provide a signed certification to the DEQ that demonstrates the City's progress towards completing its plan to achieve TMF capacity (Certified Progress Report). Beginning on the date 12 months from the date this Order is effective, and every 12 months thereafter, the City's Certified Progress Report must include an evaluation showing that the City can still achieve TMF capacity by FY 2023 without increasing customer rates.

-5-

- 3.6 By no later than March 31, 2019, the City shall complete a preliminary inspection of the Cedar Street Reservoir using a remotely operated vehicle (which does not require taking the reservoir out of service) or, preferably, a method by which the City can inspect one chamber of the reservoir at a time without taking the reservoir completely out of service. The City shall then submit to the DEQ, for review and approval, an inspection report and plan for promptly completing any necessary improvements of the Cedar Street Reservoir identified by the preliminary inspection. The City shall then complete a full inspection of the Cedar Street Reservoir within 45 days of the date the Dort Reservoir is brought into service. The City shall then submit to the DEQ, for review and approval, an inspection of service. The City shall then submit to the DEQ, for review and approval, an inspection of service. The City shall then submit to the DEQ, for review and approval, an inspection report and plan for completing any necessary improvements of the Cedar Street Reservoir is brought into service. The City shall then submit to the DEQ, for review and approval, an inspection report and plan for completing any necessary improvements of the Cedar Street Reservoir identified by the full inspection.
- 3.7 On October 15, 2018, the City produced an updated organizational chart for its Utilities Water Division (Attachment E). Within 30 days of the effective date of this Order, the City shall produce a plan that (1) identifies which position is filled by which specific F&V contractor; (2) specifically identifies how many vacant spots remain for each position, if any;(3) a schedule for filling each open spot that requires all spots to be filled no later than December 31, 2018; and (4) a written commitment that the City's contractor who serves as the operator in charge of the City's water plant is fully authorized to direct city employees not employed by that contractor to make any changes to plant operations required by the contractor.
- 3.8 The City shall complete and submit the design of chemical feed system improvements by no later than March 31, 2019, for DEQ review and approval and complete construction of the chemical feed system improvements by no later than December 31, 2019.
- 3.9 By no later than **December 31, 2018**, the City shall purchase a generator that is compatible with the Cedar Street Reservoir's electrical system or execute a contract for emergency services at that reservoir that will guarantee the provision of a generator that is compatible with the reservoir's electrical system. The DEQ recognizes that if the City successfully implements its redundancy plan involving the Dort Reservoir and Genesee County, the requirement in this paragraph will likely not be necessary. But the DEQ

-6-

remains concerned about the potential impact a significant emergency would have on the City's water system in the interim period before the City's redundancy plan is implemented. The City has acknowledged the risk during the interim period but has declined to mitigate that risk because it considers mitigating the risk to be too expensive.

- 3.10 By no later than December 31, 2018, the City shall install pumps at Torrey Road and complete design of upgrades to the Cedar Street Reservoir pumps for DEQ review and approval. Upgrades to the Cedar Street Reservoir pumps shall be completed by March 31, 2020.
- 3.11 By no later than **December 31, 2018**, the City shall produce a plan explaining how it will have the TMF capacity necessary to consistently operate its water system once the State-funded contracts for technical assistance (John Young) and training assistance (Nick Pizzi) expire. Also by that date, the City shall submit a detailed plan containing an implementation schedule for the items listed in the plan previously provided to the City by Arcadis Group in the June 4, 2018, Flint Drinking Water Distribution System Optimization Plan.
- 3.12 The City shall submit all reports, work plans, specifications, schedules, or any other writing required by this section to the DWMAD Director at DEQ, DWMAD,
 P.O. Box 30817, Lansing, Michigan 48909-8311. The cover letter with each submittal shall identify the specific paragraph and requirement of this Order that the submittal is intended to satisfy.

IV. DEQ APPROVAL OF SUBMITTALS

- 4.1 For any work plan, proposal, or other document, excluding applications for permits or licenses, that are required by this Order to be submitted to the DEQ by the City for DEQ review and approval, the following process and terms of approval shall apply.
- 4.2 All work plans, proposals, and other documents required to be submitted by this Order shall include all of the information required by the applicable statute and/or rule and all of the information required by the applicable paragraph(s) of this Order.

-7-

- 4.3 In the event the DEQ disapproves a work plan, proposal, or other document, it will notify the City, in writing, specifying the reasons for such disapproval. The City shall submit, within 30 days of the date of such disapproval, a revised work plan, proposal, or other document that adequately addresses the reasons for the DEQ's disapproval. If the revised work plan, proposal, or other document is still not acceptable to the DEQ, the DEQ will notify the City of this disapproval.
- 4.4 In the event the DEQ approves with specific modifications, a work plan, proposal, or other document, it will notify the City, in writing, specifying the modifications required to be made to such work plan, proposal, or other document prior to its implementation and the specific reasons for such modifications. The DEQ may require the City to submit, prior to implementation and within 30 days of the date of such approval with specific modifications, a revised work plan, proposal, or other document that adequately addresses such modifications. If the revised work plan, proposal, or other document is still not acceptable to the DEQ, the DEQ will notify the City of this disapproval.
- 4.5 Upon DEQ approval, or approval with modifications, of a work plan, proposal, or other document, such work plan, proposal, or other document shall be incorporated by reference into this Order and shall be enforceable in accordance with the provisions of this Order.
- 4.6 Failure by the City to submit an approvable work plan, proposal, or other document within the applicable time periods specified above, constitutes a violation of this Order and shall subject the City to the enforcement provisions of this Order.
- 4.7 Any delays caused by the City's failure to submit an approvable work plan, proposal, or other document when due shall in no way affect or alter the City's responsibility to comply with any other deadline(s) specified in this Order.
- 4.8 No informal advice, guidance, suggestions, or comments by the DEQ regarding reports, work plans, plans, specifications, schedules, or any other writing submitted by the City will be construed as relieving the City of its obligation to obtain written approval, if and when required by this Order.

-8-

V. EXTENSIONS

5.1 The City and the DEQ agree that the DEQ may grant the City a reasonable extension of the specified deadlines set forth in this Order. Any extension shall be preceded by a written request to the DWMAD Director at the address in paragraph 3.12 no later than ten (10) business days prior to the pertinent deadline, and shall include:

- a. Identification of the specific deadline(s) of this Order that will not be met.
- b. A detailed description of the circumstances that will prevent the City from meeting the deadline(s).
- c. A description of the measures the City has taken and/or intends to take to meet the required deadline(s).
- d. The length of the extension requested and the specific date on which the obligation will be met.

The DWMAD Director shall respond in writing to such requests. No change or modification to this Order shall be valid unless in writing from the DEQ and, if applicable, signed by both Parties.

VI. <u>REPORTING</u>

6.1 The City shall verbally report any violation(s) of the terms and conditions of this Order to the DWMAD Director by no later than the close of the next business day following detection of such violation(s) and shall send a written report to the DWMAD Director within five (5) business days following detection of such violation(s). The written report shall include a detailed description of the violation(s), as well as a description of any actions proposed or taken to correct the violation(s). The City shall report any anticipated violation(s) of this Order to the DWMAD Director in advance of the relevant deadlines whenever possible.

VII. RETENTION OF RECORDS

7.1 Upon request by an authorized representative of the DEQ, the City shall make available to the DEQ all records, plans, logs, and other documents required to be maintained

-9-

under this Order or pursuant to Act 399, the SDWA, or their respective rules. All such documents shall be retained by the City for at least a period of three (3) years from the date of generation of the record unless a longer period of record retention is required by Act 399, the SDWA, or their respective rules.

VIII. RIGHT OF ENTRY

8.1 The City shall allow any authorized representative or contractor of the DEQ, upon presentation of proper credentials, to enter upon the premises of the facility at all reasonable times for the purpose of monitoring compliance with the provisions of this Order. This paragraph in no way limits the authority of the DEQ to conduct tests and inspections pursuant to the SDWA or any other applicable statutory provision.

IX. ENFORCEMENT

9.1 This Order is enforceable under both the criminal provisions of MCL 325.1021 and the civil provisions of MCL 325.1022.

X. GENERAL PROVISIONS

- 10.1 This Order in no way affects the City's responsibility to comply with any other applicable local, state, or federal laws or regulations.
- 10.2 Nothing in this Order is or shall be considered to affect any liability the City may have for natural resource damages caused by the City's ownership and/or operation of the facility. The State of Michigan does not waive any rights to bring an appropriate action to recover such damages to the natural resources.
- 10.3 In the event the City sells or transfers the facility, it shall advise any purchaser or transferee of the existence of this Order in connection with such sale or transfer and condition the sale or transfer of the facility on the agreement of the purchaser or transferee to comply with this Order. Within 30 calendar days, the City shall also notify the DWMAD Director, in writing, of such sale or transfer, the identity and address of any purchaser or transferee, and confirm the fact that notice of this Order has been given to

the purchaser and/or transferee. The purchaser and/or transferee of this Order must agree, in writing, to assume all of the obligations of this Order. A copy of that agreement shall be forwarded to the DWMAD Director within 30 days of assuming the obligations of this Order.

10.4 This Order does not resolve any criminal action that may result from the violations identified in this Order.

XI. TERMINATION

- 11.1 This Order shall remain in full force and effect until terminated by a written Termination Notice (TN) issued by the DEQ. Prior to issuance of a written TN, the City shall submit a request consisting of a written certification that the City has fully complied with the requirements of this Order. Specifically, this certification shall include:
 - a. The date of compliance with each provision of the compliance program in Section III and the date any fines or penalties were paid.
 - b. A statement that all required information has been reported to the DWMAD Director.
 - c. Confirmation that all records required to be maintained pursuant to this Order are being maintained at the facility.

The DEQ may request additional relevant information after receiving the City's certification and request but before issuing a TN.

{Remainder of page intentionally left blank}

This ORDER is hereby issued against the city of Flint under MCL 325.1015(2).

By: C. Heidi Grether, Director Michigan Department of Environmental Quality

27

Date

APPROVED AS TO FORM:

By: Nathan Gambill (P75506) Assistant Attorney General Environment, Natural Resources, and Agriculture Division Department of Attorney General P.O. Box 30755 Lansing, Michigan 48909

-2012 October 72

Date

Attachment A



STATE OF MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY SAGINAW BAY DISTRICT OFFICE



C. HEIDI GRETHER DIRECTOR

August 11, 2017

SIGNIFICANT DEFICIENCY VIOLATION NOTICE

Mr. Sylvester Jones, Administrator City of Flint 1101 South Saginaw Street Flint, Michigan 48502

Dear Mr. Jones:

SUBJECT: Water System Sanitary Survey, WSSN: 2310 Significant Deficiency Violation Notice

The Department of Environmental Quality (DEQ) has completed a sanitary survey of the city of Flint (City) drinking water system. The purpose of the survey is to evaluate the water system with respect to the requirements of the Michigan Safe Drinking Water Act, 1976 PA 399, as amended (Act 399). In addition, the enclosed sanitary survey form was updated to gather information on the City water distribution, storage, pumping, and limited treatment systems. The sanitary survey <u>does not</u> include an evaluation of the water filtration plant. A complete engineering evaluation of the water filtration plant was recently completed by CDM Smith and others, and would form the basis of any future recommendations if the City elects to operate the water filtration plant.

The following table summarizes our findings from our survey of the water system:

Survey Element	Findings
Source	Significant Deficiencies noted
Treatment	Recommendations made
Distribution System	Significant Deficiencies noted
Finished Water Storage	Deficiencies noted
Pumps	Recommendations made
Monitoring & Reporting	Recommendations made
Management & Operations	Significant Deficiencies noted
Operator Compliance	Deficiencies noted
Security	Deficiencies noted
Financial	Significant Deficiencies noted
Other	

Mr. Sylvester Jones

A summary of the significant deficiencies, minor deficiencies, and recommendations applicable to your water system is enclosed for your information.

Our investigation is considered complete. This significant deficiency begins as of the date of receipt of this letter and will continue until you complete corrective action. You must complete corrective action within 120 days of receipt of this letter or be in compliance with a corrective action plan and schedule approved by this office. You are directed to contact us within 30 days of receipt of this letter to discuss appropriate corrective action. You must also notify us in writing within 30 days of correcting the significant deficiency.

If you have any factual information you would like us to consider regarding the significant deficiencies identified in this Significant Deficiency Violation Notice please provide it in a written response by September 8, 2017.

If you have any questions or wish to discuss the sanitary survey or Significant Deficiency Violation Notice, please contact me at the phone number listed below or by email to londonr@michigan.gov.

Sincerely, Robert a Sondon

Robert A. London, P.E. Surface Water Treatment Engineer Engineering Unit Drinking Water and Municipal Assistance Division 989-450-7834

bl/snh

Enclosures

cc/enc: Mr. Robert Jones, F&V Operations Mr. Mark Adas, City of Flint Mr. Rob Bincsik, City of Flint cc: Mr. Eric Oswald, DEQ Ms. Sue Maul, DEQ

Community Water Supply Section Engineering Unit Phone: 989-450-7834 Fax: 989-891-9213

WSSN: 02310

Drinking Water and Municipal Assistance Division

Water System Sanitary Survey

City of Flint Water System (Distribution System, Limited Treatment, Storage, and Pumping) August 7, 2017



Sanitary Survey of Community Water Supply - Review Summary

Water Supply: City of Flint	an a	•		N N	SSN:	02	310
Evaluator: Bob London				D	Date:	8/7	92
	Comment	N/A	Notev	NOD/R	Rec	Def	SigDef
Source							X
Construction & Maintenance	No long-term decision on primary/backup sources			all shi tang kanala sa			Х
Standby Power	Appropriate level of standby power is dependent on source selection			N.C.N.	X	44135	
Isolation	No concerns with current GLWA or potential KWA/GCDC sources			Х			
Source Water Protection	No formal source water protection program, but no concerns	0.333		X		111, 27, 27	1. No. (
Capacity	Lack of decision on source affects planning, finances, staffing, etc.						X
Treatment	Survey does not include filtration facilities (use is to be determined)				X		
Disinfection	Permanent facilities and Improved SCADA if GLWA water used	V 15		1 W. Lum	Х	a	We bearing
		X	1999 (J	7 69 FT		한다고	States ())
Phosphate Addition	Permanent facilities and improved SCADA if GLWA water used		1,47,711	7	X	en an an	en a D. Paul *
Sonening			ang sa	de Al	170/%	a geographicae	194, ang 173
Araspis Removal	- Ale bas 1966, Alfal - Alfae - en l'Alfabilité Alfae en le combine de	l âve	8.54%	district of	5.58	Acres	
Arsenic Removal	an o berek sina perinti sukur direkti sati badi u bila "la sun sur interna		- gan 1 1973	1.1.1.1944	24.2		14 1.13
Filtration (gravity or membranes)	And a first inflation. All the Walter's State of the memory and defined as for the Walter and in	Ŷ.	2.828.3	a dige of	.e. 2860.	1 3.375	S. Same
C*T	ىرىيە جويور بايغۇرىڭ بەركەت ئۆكەمىرىكى مىرۇسۇرسۇ يەركەر ئۆكۈرىد. بىلار بەرچە بايار 19	Ŷ	14.55	1.1626.2	1. 2.7	1	
Other	Permanent facilities and improved SCADA if GLWA water used				X	mada (C.17	4949 an 197
Distribution System			-				X
Interconnections w/ Other WS	A mutual aid agreement is recommended with nearby utilities	The second second	<u>MARANUS CENT</u>	AND AN ADDRESS	X		
Hydrants & Valves	Recent efforts very good, but formal long-term program needed	1728	2,3,13	14278		121.63	STAX 10
Service Lines & Metering	Programs for meter and galvanized service replacement are needed	340	n in the second	ees anns - s	17 80		X
General Plan	Prepared through State contract - City needs to assume responsibility	1120			X		
Cross Connections	No inspections conducted, inadequate administration			2000		* 0. 000000000	X
Construction & Maintenance	Age of system, water accountability, number of breaks	10.00			State of	10 C (4)	X
Capacity	Water age is a concern due to oversized mains/reduced demands				Х		
Finished Water Storage	Does not include Dort Reservoir and CW#4 (use is to be determined)					X	
Construction & Maintenance	Cedar St. needs Inspection, West Side off line due to condition					X	
Controls	[1.525		X			
Capacity	Backup Power rec. at Cedar Street; Arcadis evaluating volumes			Toth two productions	X		North Constitution and the
Pumps (All Pumping Facilities)	Does not include pumps at water plent site (use is to be determined)	A CONTRACTOR OF THE OWNER OWNER OF THE OWNER	No. Contractor		X		
Construction & Maintenance	Torrey Road pump upgrade has been delayed	- may		8.07.000		tan (1999	307777775
Controls	Electrical gear/control upgrades recommended/VFDs recommended	199	ali anisari 14 Tatani			umraid	1 . S. 1. 18
				<u>^</u>	Y		
Bacteriological Monitoring				X		100.000	
Chemical Monitoring	Completed with State assistance - City needs to assume responibility	1.193	. 7782.59 9	le cana	X	manged	a - 1997 - 1995
MOR or Annual Pumpage Repor		10.00.00	na Arraita	X		- 1.946.0	1 N 838,999
Consumer Confidence Report	Prepared with State assistance - City needs to assume responibility	1.1.1		mi king	X	<u></u>	1. <u>1</u> . 1997
Analytical Capabilities	ter i transmu na standar i stan		1999 S. C.	X	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	1 - 1 - 5 - 5 - 5 1	10000 - 1013
System Management & Operation							X
Owner Responsibility	Lack of decision on source affects planning, finances, staffing, etc.		Contraction Contraction		1.	2000-02030-0200-0200	X
Capacity Development	Concerns with long-term source, budget, staffing/cert., plans/studies					X	
Reliability Study	Prepared with State assistance - City needs to assume responibility				X		
Operations Oversight	Treatment - contract w/F&V Operation; Distribution - In-house staff				X		
Permits				X			
Operator Compliance						X	
Operator Certification	Difficulty hiring/retaining certified operators					X	
Technical Knowledge & Training	Training		i n alt		X		
Security						X	
Emergency Response Plan	Status of ERP is unknown		a states			X	
Site Security (Fences, Alarms)		and the second	a contraction				
Financial							X
Kates	Rattelis Study predicts a revenue vs. expenses gap		n		X		
Cither	Lack of decsion on source affects budget, planning, financing	- ground and	a la for total source		1.2.2. A 1.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2	to the test of the second	×
N/A Not Applicable	NotEx - Not Evaluated	NoD/E	- No Defi	ciencies/0	PCOMMO	ndations M	Aade .
NIA - NULAPPICADE		CieDe			Sconnie Scientific	-uctions P	auc.

Rec - Recommendations Made

Def - Deficiencies Identified

SigDef - Significant Deficiencies Identified

WATER SYSTEM SANITARY SURVEY

GENERAL

		Bas	ic Inform	nation			
WSSN: 02	310 Sup	ply:		City of Flint	County	Ge	nesee
Date: 8/7/	2017 Rev	lewed by:		Bob London	District	RAL	_/North
Primary Contact:	Sylvester Jones		-	Copy To:	Mark Ad	as	
JUWIO KOIE.	City Administrator		-		City Eng	ineer	
	810-766-73/6 v 2	025		Telephone			
Cell Phone:	010-700-7040 X 2	020	-	Cell Phone.	810-610	-7771	
Fax:			-	Fax:			
e-mail,	sjones@cityofflint	.com	-	e-mail:	madas@	cityofflint.com	
Address:	1101 S. Saginaw	Street	_	Address:	<u>1101 S.</u>	Saginaw Stree	1
	Flint, MI 48502				Flint, Mi	48502	
Population: 98,310	Year	2015	Basis.	Census update			
	Operat	or Training	and Cer	rtification - Tre	atment		
Treatment Capacity:	_	18 MGD					
Treatment Classification	:	D-1	_	Certification		Op. #	Exp. Date
Operator in Charge:	Robert Jones (F&	V Operations)		D-1, F-2, S-1		5026	7/15/2018
Backup Operators:	Catherine Garnha	am (F&V)		F-1, S-1		5194	7/15/2019
	Stewart Beach (F	&V)		F-1, S-1		2273	1/15/2019
Operations Supervisor:	Vacant	· · · · · · · · · · · · · · · · · · ·	<u> </u>				
Operations Foreman (4)	: Scott Dungee			F-3, S-4		5550	7/15/2019
	Chris Wilcox			F-4		18586	1/15/2018
	Dominic Smoot			D-3		20034	1/15/2020
	Vacant				_ ·	10004	4/45/0040
Operator/iviaintainer (4):	Scoll Ball		 ,	<u> </u>		20022	1/15/2016
	Jen Waksymowski	M	<u>-</u>	None		20033	
	Robert Stinson			None			
Maintenance Supy (2)	Mike Beckley		-	F-4 S-4		13782-	7/15/2018
Mainenance oupv. (2).	Chris Korvciak		-	F-4, S-4		4653	1/15/2020
Maintainer/Operator (2):	Vacant		-	,			
	Vacant						
Instrument Technician:	Vacant						
Lab Supervisor:	Will Bradley			F-3		11941	7/15/2017
Lab Technicians:	Heather Kot			D-4		20031	1/15/2020
	Vacant						
Do the operators receive If not, explain:	e adequate technic	al training?		Yes			
Comments on Training The City entered into a Certified Backup Opera certification of contract	and Certification: contractual agreer ator services for the operations staff.	nent with Fleis treatment sys	and Vand tem on Ju	enbrink Operations ne 22, 2017. F&V	s (F&V) for is respons	Operator-In-C ible for providia	harge and ng training and
The City is investigating Instrument Techncian p assistance.	g a contract service position. The instru	e agreeement v ument technicia	with Hach an at the w	for analytical equip vastewater plant ma	ment main ay also be a	tenance due to available to pro	o the vacant ovide limited

The State of Michigan has entered into several agreements for training and technical assistance for City of Flint personnel, and has provided training on several occasions at the water treatment plant for City personnel. A comprehensive list of training is contained in Appendix A. The City is responsible for providing adequate training in the future to maintain a competent and properly-certified staff.

WATER SYSTEM SANITARY SURVEY

GENERAL

	Operator Training and	Certification - Distribution	on	
Distribution Classification	1: S-1	Certification	Op. #	Exp. Date
Operator in Charge:	Robert Bincsik	F-4, S-1	13784	1/15/2020
Backup Operator				
Water Dist. Formen:	Howard Swickard	S-2	5091	1/15/2019
	Paul Simpson	S-2	4849	1/15/2018
	Jeff Church	S-3	12559	4/15/2020
	Curtis Brooks	None		
Senior Water Dist.				
Operators:	Jason Bradley	None	·	
	Dave Hurt	None	17277	
	Rich Johnson	None		
	Jeremy Keefer	None	16060	
	Chris Kennedy	None		
	Phil Kuczera	None		
	Brandon McNiel	None		
	Jon Mochty	None		
	Mark Pavwoski	None	13288	
	Keith Ross	None		
	Juan Sattiewhite	None		
	Don Thompson	None		
	Dan Wells	None	18922	
Water Dist. Operators:	Clarence Scott	None		
	Greg Sumner	None		
	Fabian Villareal	None		
	Nancy Prieur	None		
	Lester Muma	None	14567	
Water Dist. Op. Trainee:	Marc Arter	None		
	Jason Gutierrez	None		
5	Ben Gutierrez	None	4366	
	Mark May	None		
	Vacant (8 positions)			
Do the operators receive	adequate technical training?	Yes		
If not, explain:				· ·····
1-2-2-2-2-2-2-2-2-2-2-2-2-2-2-2-2-2-2-2		n (n - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	a and a set of a construction of the state o	1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 - 1919 -
Comments on Training	and Certification:			
The State of Michigan h	as entered into several agreements	for training and technical assista	nce for City of Flir	t personnel, and
has provided training or	several occasions at the water treat	ment plant for City personnel. A	comprehensive li	ist of training is
contained in Appendix A	 The City is responsible for providir 	ng adequate training in the future	e to maintain a cor	mpetent and
properly-certified staff.				
	On	nership		
Ownershin:	City			
Consent Agreement	NA			
Escrow Account	NA			
	Activo			
Comments:	Active .			
continionte.				

SOURCE

1

....

Vear Demand (MGD) Max/Avg Population GC/D unacctHg 2007 26.4 17.0 112.50 1.56 1.56 1.56 1.56 1.56 1.56 1.56 1.57 1.51 1.52 1.51 1.54 1.52 1.51 1.54 1.52 1.51 1.54 1.52 1.51 1					Capac	ity		r ha shearfa		
Max. Day Date Avg. Day Min. Day Date Max. Day History	Year	Par Demand (MG		emand (MGD)		Max/Avg	Population	G/C/D	%
2007 26.4 17.0 12.50 1.65 2008 18.7 15.2 10.10 1.23 2009 21.6 14.0 9.30 1.64 2010 17.5 14.1 11.00 1.24 .43% 2011 20.4 13.9 9.00 1.47 .39% 2012 17.8 12.1 7.10 1.47 .40% 2013 17.4 13.4 10.00 1.30 .50% 2014 24.5 18.3 Data from 2014/2015 includes WTP operation .000 2016 15.8 12.6 7.54 1.25 30.00		Max. Day	Date	Avg, Day	Min. Day	Date	maxirity	History	0,0,0	unacct.H ₂ O
2009 16.7 15.2 10.10 1.23 2009 21.6 14.0 9.30 1.54 2010 17.5 14.1 11.00 1.24 43% 2011 20.4 13.9 9.00 1.47 39% 2013 17.4 13.4 10.00 1.30 50% 2014 24.5 18.3 10.0 1.47 40% 2016 15.8 12.8 7.64 1.25 50% 2016 15.8 12.8 7.64 1.25 2016 2017 2000 2000 2001 2011 2012 2013 2016 2017 2000 2000 2009 2010 2011 2013 2014 2015 2016 2017 2000 2000 2009 2010 2011 2013 2014 2015 2016 2017 2000 2000 2009 2010 2011 2012 2013 2016	2007	26.4		17.0	12.50		1.55			
2000 21.6 14.0 9.30 1.54 2010 17.5 14.1 11.00 12.4 43% 2011 20.4 13.9 9.00 1.47 39% 2012 17.6 12.1 7.10 1.47 39% 2013 17.4 13.4 13.0 50% 2014 24.5 19.3 Data from 2014/2015 includes WTP operator 2015 25.4 16.3 8.10 Do not use for capacity determination. 2016 15.8 12.6 7.64 1.25 30.00 20.00 20.00 20.00 20.00 20.00 25.00 20.00 20.00 20.00 20.00 20.00 26.00 20.00 20.00 20.00 20.1 20.2 20.3 20.4 20.5 20.7 7 17.5 14.1 15.0 12.6 7.64 1.25 20.7 8 10.00 20.00 20.00 20.1 20.12 20.3 20.16 20.7 8 20.00 20.00 20.1 </td <td>2008</td> <td>18.7</td> <td></td> <td>15.2</td> <td>10.10</td> <td></td> <td>1.23</td> <td></td> <td></td> <td></td>	2008	18.7		15.2	10.10		1.23			
2010 17.5 14.1 110.00 1.24 43% 2011 20.4 13.9 9.00 1.47 33% 2012 17.8 12.1 7.10 1.47 33% 2013 17.4 13.4 10.00 1.30 50% 2014 24.5 18.3 8.10 Do not use for capacity determination. 1.25 2016 15.8 12.6 7.64 1.25 1.25 1.25 1.25 30.00 20.05 2007 2008 2009 2011 2012 2013 2014 2015 2015 2017 9 15.00 12.6 7.64 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.25 2016 2017 1.26 1.26 2.21	2009	21.6		14.0	9.30		1.54			
2011 20.4 13.9 9.00 1.47 39% 2012 17.8 12.1 7.10 1.47 49% 2013 17.4 13.4 10.00 1.30 50% 2014 24.5 18.3 Data from 2014/2015 Includes WTP operation Do not use for capacity determination. 2016 15.8 12.6 7.54 1.25 30.00 25.00 0 0 0.00 1.25 41.50 15.8 12.6 7.54 1.25 30.00 0 0.00 0.00 20.00 0.00 20.00 0 0.00 0.00 20.00 0.00 0.00 30.00 0.00 20.00 0.00 20.00 0.00 20.00 0.00 20.00 0.00 20.00 0.00 20.00 0.00 20.00 0.00 20.00 0.01 20.12 20.13 20.14 20.15 20.17 Five Year Max. Day 17.8 (Excludes 2014 and 2015, which reflects WTP operation) 18.0 (Based on onginal raw water contract Wth KNA and anticipated reduction in Iost water from DWRF project	2010	17.5		14.1	11.00		1.24			43%
2012 17.8 12.1 7.10 1.47 40% 2013 17.4 13.4 10.00 1.30 50% 2014 24.5 18.3 Date from 2014/2015 includes WTP operation Do not use for capacity determination. 2016 15.8 12.6 7.64 1.25 30.00	2011	20.4		13.9	9.00		1.47			39%
2013 17.4 13.4 10.00 1.30 200 207 206 18.3 10.00 1.25 12.5	2012	17.8		12.1	7.10		1.47			40%
2014 24.5 18.3 Data from 2014/2015 includes WTP operation. 2015 25.4 16.3 8.10 Do not use for capacity determination. 2016 15.8 12.6 7.54 12.5 30.00 25.00 12.6 7.54 12.5 9 0.00 25.00 12.5 12.5 9 10.00 12.5 12.5 12.5 9 0.00 2007 2008 2009 2011 2012 2013 2014 2015 2016 2017 Five Year Max. Day 17.8 (Excludes 2014 and 2015, which reflects WTP operation) 12.7 (Excludes 2014 and 2015, which reflects WTP operation) Ten year Max. Day 12.7 (Excludes 2014 and 2015, which reflects WTP operation) 13.0 (Based on original raw water contract with KWA and antichter was officially extended July 11, 2016 28.4 28.4 28.3 29.00 14.7 (Excludes 2014 and 2015, which reflects WTP operation) Max Day for capacity requirements 13.0 (Based on original raw water contract with KWA and antichter was officially extended July 11, 2016 28.4 28.4 24.4 MACOP 24.4 MACOP 24.4	2013	17.4		13.4	10.00		1.30			50%
2016 15.8 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 12.6 7.54 1.25 30.00 10.00 12.6 7.54 30.00 10.00 12.6 7.54 30.00 10.00 12.7 12.8 10.00 2006 2007 2008 2009 2010 2011 2012 2013 2014 2015 2017 Five Year Max. Day 17.8 (Excludes 2014 and 2015, which reflects WTP operation) Ten year Max. Day 12.7 (Excludes 2014 and 2015, which reflects WTP operation) Max Day for capacity requirements 18.0 (Based on original ray water contract wavefor contract: 10/16/2015 Expiration Date: 9 mo	2014	24.5		18.3			Data from	2014/2015 ii	ncludes W	TP operation.
2016 15.8 12.6 7.54 1.25 25.00 25.00 25.00 25.00 25.00 25.00 9 15.00 25.00 20.00 20.00 20.00 20.00 9 15.00 20.00 20.00 20.00 20.01 20.12 20.13 20.14 20.15 20.16 20.17 Five Year Max. Day 17.8 (Excludes 2014 and 2015, which reflects WTP operation) Ten year Max. Day 12.7 (Excludes 2014 and 2015, which reflects WTP operation) Max Day for capacity requirements 12.7 (Excludes 2014 and 2015, which reflects WTP operation) Max Day for capacity requirements 12.7 (Excludes 2014 and 2015, which reflects WTP operation) Max Day for capacity requirements 10.0 (Based on original raw water contract with KWA and anticipated reduction, but extendable based on circumstances Frincipal Parties of Contract: GLWA, City of Flint 1016/2015 Date of Contract: 101/16/2015 9 months from execution, but extendable based on circumstances The contract was officially extended July 11, 2016 11.4 MGD Maximum Dativery Pressure Cited in Contract: 40 PSI	2015	25.4		16.3	8.10		Do no	ot use for cap	acity deter	mination.
30.00 25.00 25.00 20	2016	15.8		12.6	7.54		1.25			
anticipated reduction in lost water from DWRF project). Purchase Contract: Principal Parties of Contract: GLWA, City of Flint Date of Contract: 10/16/2015 Expiration Date: 9 months from execution, but extendable based on circumstances The contract was officially extended July 11, 2016 Annual Volume Available by Contract: 593,000 Mcf (= 4.436 Bgal) Maximum Day Available by Contract: 22.4 MGD measured over one hour Maximum Delivery Pressure Cited in Contract: 22.4 MGD measured over one hour Maximum Delivery Pressure Cited in Contract: 22.4 MGD measured over one hour Maximum Delivery Pressure Cited in Contract: 20 PSI Comments on the Purchase Contract: A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed	25 (g) 20 (g) 20	.00 .00 .00 .00 .00 2006 2007 ar Max. Day ar Avg. Day for capacity rec	2008	2009 2010	2011 20 In. Day Av 17.8 (26.4 12.7 (18.0 (12 2013 g. Day Excludes 2 Excludes 2 Based on o	2014 2 Max. Day 014 and 2015 014 and 2015 014 and 2015	015 2016 5, which reflect ater contract	2017 2017 cts WTP o cts WTP o with KWA	peration) peration) and
Principal Parties of Contract: GLWA, City of Flint Date of Contract: 10/16/2015 Expiration Date: 9 months from execution, but extendable based on circumstances The contract was officially extended July 11, 2016 Annual Volume Available by Contract: 593,000 Maximum Day Available by Contract: 593,000 Maximum Hour Available by Contract: 21.4 Maximum Delivery Pressure Cited in Contract: 60 Maximum Delivery Pressure Cited in Contract: 60 Minimum Delivery Pressure Cited in Contract: 40 PSI PSI Comments on the Purchase Contract: A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of thi date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.			and the second second		Durchase	Contract	Teduction in			projecty
Date of Contract: 10/16/2015 Expiration Date: 9 months from execution, but extendable based on circumstances The contract was officially extended July 11, 2016 Annual Volume Available by Contract: 593,000 Maximum Day Available by Contract: 21.4 Maximum Hour Available by Contract: 21.4 Maximum Delivery Pressure Cited in Contract: 60 PSI PSI Comments on the Purchase Contract: 40 A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Dringing	Darties of Cost	root:	GLIMA CIL	of Elint	contract			Brand, and Article	
Date of Contract: 10/16/2015 Expiration Date: 9 months from execution, but extendable based on circumstances Annual Volume Available by Contract: 593,000 Maximum Day Available by Contract: 21.4 Maximum Hour Available by Contract: 22.4 Maximum Delivery Pressure Cited in Contract: 60 Minimum Delivery Pressure Cited in Contract: 40 PSI PSI Comments on the Purchase Contract: 40 A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Fincipal	Farties of COND	aul.	GLWA, GRY	OFTIN			-		
Expiration Date: 9 months from execution, but extendable based on circumstances Annual Volume Available by Contract: The contract was officially extended July 11, 2016 Maximum Day Available by Contract: 593,000 Mcf (= 4.436 Bgal) Maximum Hour Available by Contract: 21.4 MGD Maximum Delivery Pressure Cited in Contract: 60 PSI Minimum Delivery Pressure Cited in Contract: 40 PSI Comments on the Purchase Contract: 40 PSI A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Date of 0	Contract:			10/16/2015					
Annual Volume Available by Contract: 593,000 Mcf (= 4.436 Bgal) Maximum Day Available by Contract: 21.4 MGD Maximum Delivery Pressure Cited in Contract: 22.4 MGD measured over one hour Maximum Delivery Pressure Cited in Contract: 60 PSI Minimum Delivery Pressure Cited in Contract: 40 PSI Comments on the Purchase Contract: Ashort-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Expiratio	n Date:			9 months from	n execution	i, out extenda	ple based on	circumsta	ances
Annual Volume Available by Contract: 593,000 Mcf (= 4.436 Bgal) Maximum Day Available by Contract: 21.4 MGD Maximum Hour Available by Contract: 22.4 MGD measured over one hour Maximum Delivery Pressure Cited in Contract: 60 PSI Minimum Delivery Pressure Cited in Contract: 40 PSI Comments on the Purchase Contract: 40 PSI Comments on the Purchase Contract: A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.					The contract	was official	y extended J	uly 11, 2016		
Maximum Day Available by Contract: 21.4 MGD Maximum Hour Available by Contract: 22.4 MGD measured over one hour Maximum Delivery Pressure Cited in Contract: 60 PSI Minimum Delivery Pressure Cited in Contract: 40 PSI Comments on the Purchase Contract: 40 PSI Comments on the Purchase Contract: Ashort-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Annual V	/olume Available	e by Contract	:	593,000	Mcf (= 4.43	6 Bgal)			
Maximum Hour Available by Contract: 22.4 MGD measured over one hour Maximum Delivery Pressure Cited in Contract: 60 PSI Minimum Delivery Pressure Cited in Contract: 40 PSI Comments on the Purchase Contract: 40 PSI Department was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Maximur	m Day Available	by Contract:		21.4	MGD				
Maximum Delivery Pressure Cited in Contract: 60 PSI Minimum Delivery Pressure Cited in Contract: 40 PSI Comments on the Purchase Contract: A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Maximur	m Hour Available	e by Contract	:	22.4	MGD measu	ured over one	hour		
Minimum Delivery Pressure Cited in Contract: <u>40</u> PSI Comments on the Purchase Contract: A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Maximur	n Delivery Press	sure Cited in	Contract:	60 I	PSI				
Comments on the Purchase Contract: A short-term agreement was reached with the Great Lakes Water Authority (GLWA) in 2015 to allow the City of Flint to discontinue routine use of its water treatment plant. The agreement with GLWA was based on the previous agreement with the Detroit Water and Sewerage Department (DWSD). The agreement was set to expire within 9 months of execution, but included provisions to extend it as necessary based on local circumstances. A 30-year purchase agreement was proposed by GLWA, but Flint City Council has not approved it as of the date of this survey. The City was required to approve the proposed agreement or propose a reasonable alternative that was protective of public health by June 26, 2017, and failed to do so. The DEQ has determined that the City's failure to act presents an immediate threat to public health. The City does not have a secure, long-term source agreement at this time.	Minimun	n Delivery Press	ure Cited in 0	Contract:	40	PSI				
	Comme A short-t use of its Departm based or date of ti public he public he	ents on the Purch term agreement w s water treatment ent (DWSD). The n local circumstan his survey. The C ealth by June 26, 2 ealth. The City do	hase Contrac as reached wit plant. The agr agreement w ces. A 30-yea ity was require 2017, and faile es not have a	t: the the Great Lal eement with Gl as set to expire in purchase agri- ed to approve the d to do so. The secure, long-te	tes Water Autho LWA was based within 9 months eement was pro e proposed agr DEQ has dete rm source agree	prity (GLWA) on the previ s of execution posed by GL eement or pr rmined that t ement at this	in 2015 to allo ous agreemen n, but included WA, but Flint (opose a reaso he City's failure time.	w the City of F t with the Detr provisions to o City Council ha nable alternati to act presen	lint to disco oit Water ar extend it as is not appro ve that was ts an imme	ontinue routine nd Sewerage necessary wed it as of the protective of diate threat to

STORAGE

dentification	Dort Reservoir	Clearwell No. 4
Location	Water Treatment Plant	Water Treatment Plan
Function	Finished Water Storage	High Service Pump
	(currently off line but is	Suction
	intended for routine use)	
Type	Concrete 2-cell	Concrete
Nominal Volume (Gallons)	20,000,000	3,000,000
Calculated Lisable Volume (Gallons)	20,000,000	0,000,000
Date Constructed	1952	1954
Date Inspected	1002	1004
Buried/At Grade	At grade	Ruried
Floor Slab Elevation	Ar grade	Duneu
Floor Relief Valves-Float Prevention (V/N)	10	parameter and a second s
Sumn Area (Y/N)		for the state of the
Eloor Slopes to Sump (Y/N)	· · · · · · · · · · · · · · · · · · ·	
Sumn Floor Elevation	and the second s	
Sump Dimensions		
Date Painted/Coated Inside		
Paint/Coating System		
NSF Std 61 Compliant (Y/N)		
Cathodic Protection		
Leaks (Y/N)		•·····
Reservoir Isolation Valve		
Basin Drain (Hydrant/Pumps)		
High Alarm		
low Alarm		
Alarm Type		
Normal High Water Level		
Normal Low Water level	· · · · · · · · · · · · · · · · · · ·	
Range of Operation	······································	·····
Chart recorder	t the same second se	
Telemetering System	Wireless/SCADA	Wireless/SCADA
Vents Screened		
Overflow Screened		Mar I caller game a caller
Access Hatches Locked		
Hatches Watertight and Overlap		
Overflow Splash Pad		
Site Fenced/Locked	Locked - at WTP	Locked - at WTP
Usable Storage	0	0

Comments on Ground Level Storage: At present, and as GLWA water is currently being received, the City is not capable of using the Dort Reservoir or Clearwell No. 4. A thorough inspection, and completion of any necessary maintenance/repairs, would be necessary before returning these reservoirs to service.

STORAGE

Ground Level Storage -	Construction, Controls &	Maintenance
Identification	Cedar Street Reservoir	West Side Reservoir
location	Cedar St /Fenton Rd	Dupont St / Jean Ave
Eurotion	Distribution Storage	Distribution Storage
- unotori	Distribution Otorage	
Туре	Concrete 2-cell	Concrete 2-cell
Nominal Volume (Gallons)	20,000,000	12 000 000
Calculated Usable Volume (Gallers)	14,000,000	O (off line at this time)
Date Constructed	1948	1070
Date Inspected	~2000	2017
Date Inspected	~2000	At grada
Fleer Sleh, Flevetien	Algrade	ALGIAGE
Floor Slab, Elevation		
Floor Relief Valves-Float Prevention (Y/N)	<u> </u>	
Sump Area (Y/N)		
Floor Slopes to Sump (Y/N)		
Sump Floor Elevation		
Sump Dimensions		
Date Painted/Coated Inside	N/A (concrete)	N/A (concrete)
Paint/Coating System		
NSF Std 61 Compliant (Y/N)		
Cathodic Protection	No	No
Leaks (Y/N)	<u>No</u>	Yes
Reservoir Isolation Valve	Yes	Yes
Basin Drain (Hydrant/Pumps)		
High Alarm	Yes	Yes
Low Alarm	Yes	Yes
Alarm Type	Noted on SCADA	Noted on SCADA
Normal High Water Level	20')
Normal Low Water level	6'/16' (summer/winter)	
Range of Operation	Depends on season	Depends on season
Chart recorder	SCADA at WTP	SCADA at WTP
Telemetering System	Wireless/SCADA	Wireless/SCADA
Vents Screened	Yes	Yes
Overflow Screened		Yes
Access Hatches Locked		Yes
Hatches Watertight and Overlap	Yes	
Overflow Splash Pad	Storm drain w/air gap	Storm drain w/air gap
Site Fenced/Locked	Yes	Yes
Usable Storage	14,000,000	0

Comments on Ground Level Storage:

The West Side Reservoir (WSR) was inspected in 2017. The reservoir was shut down several months ago due to a leaking link seal/coupling through the wall on the influent line. The inspection report recommends approximately \$90,000 of miscellaneous repairs such as brick work and tuck pointing, repainting of pipes and metal surfaces, replacement of downspouts, replacement of the influent line link seal, etc., to prevent the reservoir from deteriorating. There were no other major structural or sanitary concerns. The Arcadis Group will be providing a recommendation on the long-term need for the WSR. Until that recommendation is received, the City will not make a decision on whether to proceed with the repairs. The City has experienced a significant drop in the number of water main breaks since the West Side Reservoir was removed from service. Several sources have recommended that Soft Starts or VFDs be installed on the West Side booster pumps to reduce or eliminate pressure spikes within the distribution system, which may be related to main breaks.

STORAGE

Eleva	ated Storage - Cor	struction, Co	ontrols & Maint	enance	
Location	WTP (elevated)				
SDWIS Facility ID (Site Code)					
Volume	2,000,000				
Туре	Elevated, multi-leg				
Material	Steel				
O.F. Elevation					
Date Constructed	1952	B			
Date Inspected	2009				
Date Painted Inside	2009				
Paint System					
NSF Std 61 Compliant (Y/N)	Yes				
Date Painted Outside					
Cathodic Protection	Yes	B			
Tank Isolation Valve	Yes			Andrich Barren	
Tank Drain (Hydrant)	Yes	Al-			
Altitude Valve	Yes	L	and the second sec		
Mud Valve	Yes				
High Alarm	Yes				
Low Alarm	Yes	L			
Alarms Received By	Operations center	<u> </u>			
Total Head Range (Feet)			····		
Normal High Water Level					
Normal Low Water level		<u></u>			
Normal/Average Pressure	74				
Data Recording System	SCADA			· · · · · · · · · · · · · · · · · · ·	
Control Signal Type	Wireless/SCADA				
Auxiliary Power for Controls?	.,				
Control System Adequate?	Yes				
Vents Screened					
Overflow Screened					
Access Hatches Locked					
Expansion Collar Lubricated		,			
Mixing System	None				
Overflow Splash Pad					
Adequate Security?	Yes - at WTP				
Operator Visit Frequency	Daily - at WTP				
Comments:					
	A . I. U I. I	0			
	otal Usable Storag	je capacity -	Ground + Eleva	area)	
Usable Storage	2,000,000				
Total Usable Storage (gal)	16,000,000	16.0	Mgal		
Total Usable Storage/Max Day	61%				
Total Usable Storage/Avg. Day	126%				

Comments:

Pumping

.

Pumping St	ations - C	onstructio	n, Control	s & Mainte	nance	
Location:	Pump Station 4 (Water Treatment Plant)					
Function:	Pum	Pumping water from the Dort Reservoir and the 3 MG reservoir				
			to the Distrib	ution System		
Pump Number	1	2	7	8	9	
Year Installed				-		
Туре	Horiz. Cent.	Horiz. Cent.	Horiz. Cent.	Horiz. Cent.	Horiz. Cent.	
Current Capacity (MGD)	0	0	20	20	6	
Current Capacity (GPM)	0	0				
Basis	Inoperable	Inoperable				
Current TDH (FT)						
HP	800	1000	800	800		
Original Name Plate GPM						
Corresponding MGD					-	
Original Name Plate TDH (FT)						
Pump NPSH (FT)						
Centerline of Pump Intake Elev.						
Floor Elevation						
Electrical Controls Elevation						
Pumps/Motors Subject to Flood	?		· · · · · · · · · · · · · · · · · · ·			
Pump Efficiency						
Motor Efficiency	**************************************					
Min. Reservoir WL						
Cavitation Problems (Y/N)				• · · · · · · · · · · · · · · · · · · ·		-
VFDs (Y/N)						
Maintenance History	Refer	to next page	for maintena	nce history of	pumps and n	otors
Comments on Booster Pumping A number of improvements wor to routinely use the Dort Resen on the Water Treatment Plant.	g: uld be require voir. The imp	ed if the water provements a	r plant is retur re included in	ned to operat the CDM Sm	tion or if the C ith Engineerin	ity elects g Report
AUXILIARY POWER			· · ·			
Power Type	Dua	primary feed	s with auto-tra	ansfer		
Fuel Type		Starting Fre	equency		.8	
Capacity (gpm)		Load Testir	ng Frequency			
		20110222000000000000000000000000	a an			
Total Pump Capacity (gpm) Firm Pump Capacity (gpm) Auxiliary Power Capacity (gpm)			mgd mgd mgd			
Max Day Demand @ this location	n		mad			
Peak Hour @ this location	20		anm (Hydr	onneumatic S	stations)	
Avg Day Demand @ this location	n		mgd	oprieumatic c	nations)	
Firm Pump Capacity/Max Day Peak Hour/Firm Pumping Capa Aux. Power Capacity/Avg Day Comments:	city		% % (Hydr %	opneumatic S	Stations)	
Dual primary electrical feeds are auxiliary power is recommended	e not truly ind 1.	ependent. If	routine use o	f Control Stati	on 4 is desire	d, on-site

Pumping

ocation:		Pump Station 4 (Wa	ter Treatment Plant)	
unction:	Pumpina	water from the Dort Re	eservoir and the 3 MG	reservoir
		to the Distribu	ution System	
·				
Pump Station 4	Pump Station 4	Pump Station 4	Pump Station 4	Pump Station 4
Pump 1	Pump 2	Pump 7	Pump 8	Pump 9

<u>Pumping</u>

.

Pumping St	ations - C	onstructio	n, Controls	s & Maintenance	
Location:	Cedar Street Reservoir				
Function:	Pump f	rom the Ceda	r Street Rese	ervoir to supply the south and west	
			areas of	the City	
Pump Number	1	2	3		
Year Installed	1948	1948	1948		
Туре	Horiz. Cent.	Horiz. Cent.	Horiz. Cent.		
Current Capacity (MGD)					
Current Capacity (GPM)	12	9	9		
Basis					
Current TDH (FT)	160'	160'	160'		
HP	500	350	350		
Original Name Plate GPM					
Corresponding MGD					
Original Name Plate TDH (FT)					
Pump NPSH (FT)			-		
Centerline of Pump Intake Elev.					
Floor Elevation					
Electrical Controls Elevation		<u></u>			
Pumps/Motors Subject to Flood?	No	No	No		
Pump Efficiency					
Motor Efficiency					
Min. Reservoir WL					
Cavitation Problems (Y/N)					
VFDs (Y/N)	No	No	No		
Maintenance History	Refer	to next page	for maintena	nce history of pumps and motors	
Comments on Booster Pumping Some electrical components are fro replacement were recently complet portable generator feed, but the wo Center at the water plant. Filling ar staff to manage flow patterns, press	: m the 1940's ed. A permit rk was not co id emptying th sures, chloring	and an upgrad was issued in 2 mpleted. The j ne Cedar Stree e residuals, and	le is needed. S 2012 to upgrad oumps are con t and West Sid d water age.	SCADA improvements and switchgear e the pumping station to accept a trolled remotely from the Operations e Reservoirs is controlled by Operations	
AUXILIARY POWER			5 ° a a		
Powerlyge	None			· · · · · · · · · · · · · · · · · · ·	
		Starting Fre	duency		
Capacity (gpm)		Load Testin	ig Frequency		
Total Pump Capacity (gpm)			mgd		
Firm Pump Capacity (gpm)			mgd		
Auxiliary Power Capacity (gpm)			mgd		
Max Day Demand @ this location	n		mgd		
Peak Hour @ this location			gpm (Hydr	opneumatic Stations)	
Avg Day Demand @ this location	1		mgd		
Firm Pump Canaaitu/May Day			9/		
Peak Hour/Firm Pumping Capac	ity		% (Hydr	conneumatic Stations)	
Aux Power Capacity/Avg Day	ity		%	ophedinate stations)	
Comments			70		
In case of interruption of the GIN	MA supply t	he Cedar Stre	et Reservoir	and booster numping station is	
currently the primary source of w strongly recommended.	ater. Auxilia	ary power or,	as a minimum	n, portable generator compatibility is	

Pumping

Location:		Cedar Street Reservoir						
Function:	Pump from the	Pump from the Cedar Street Reservoir to supply the south and west						
		areas o	f the City					
Pun visu bas wor	Pumps and motors are on a visual inspection, checking basis, oil is changed, packir work is shown below:	Pumps and motors are on a routine Preventive Maintenance (PM) schedule consisting of visual inspection, checking oil levels, and greasing bearings and fittings. On an as-needed basis, oil is changed, packing is adjusted, bearings are replaced, etc. Recent, non-routine work is shown below:						
	Cedar Street Station Cec Pump 1	lar Street Station Pump 2	Cedar Street Station Pump 3					
	10/30/13 - installed 2/1/	10 - rebuilt motor						
	and packing, 1/20 rebalanced impeller pun	6/16 - uncoupled np and motor for						
	12/5/16 - serviced	motor testing						
12/5/16 - service discharge valve control cylinder	discharge valve control cylinder s reco	I/16/16 - tested witchgear and pupled pump and motor						
	12 d c plac	/5/16 - serviced ischarge valve ontrol cylinder, ced pump back in service						

	Disinfectio	n (sodium hypochlo	orite addition)		
Point of Treatment		Cedar St. Booster Sta.			
Injection Point:	-	Reservoir inlet line	-		
Stowers (Street) (Street)					
Purpose:	-	See comments	-		
Year Initiated	-	2016	-		
Product:		Havasan LB-12	-		
Manufacturer:		Haviland	_		
Chemical Strength:		14-15% (12.5% nominal)			
Dilution:		N/A	_		
ANSI/NSF Standard 60 Approval? (Y	/N)	Yes	NSF max dose:	84	mg/L
Normal Feed Rate/Dosage		See comments	_mg/L		
Avg Residual (Plant Tap) (mg/L)	free:	1.5	(goal)		
Avg Distribution Residual (mg/L)	free:		-		
Frequency of Residual testing	Plant Tap:	Continuous	_ Distribution:	Weekly	_
Analytical Method Used	ä	Hach CL-17 (DPD)	_		
Any Overfeed Instances? (Y/N) Any Low Feed Instances? (Y/N)	,	No No	Date(s): _ Date(s): _		
Pump Type		Diaphragm	Model	I MI C721-71ES	
Number of Pumps:		1		LINI OF LITTING	
Pump Capacity		4 aph	apd min:		
	psi:	100			
Chemical Storage Tank Type	•	55 gallon drums	Volume:		
Weight/Level Reading Method		None (relies on expected	usage and visual in	spection)	
SAFETY	1. COLORD		and the second		*
Separate Room	Yes		Cylinder Repair Kit	N/A	and the second
Exhaust fan		Extra Chlo	rinator or repair kit	N/A	
Fresh Air Vent		A	Ammonia Bottle	N/A	
Door Opens Out With Panic Bar		Self C	ontained Air Packs	N/A	
More than 1500 # Cl ₂ onsite	N/A	-	Training Programs		_
Electrical Protected from Gas?	N/A	-	Shower/Eve Wash		
		•			

Comments:

The free chlorine residual of water entering and leaving the Cedar Street Reservoir (CSR) is monitored continuously and is visible on the SCADA display in the Operations Center. Chlorine is added to the water when filling the CSR as appropriate to help meet the City's distribution system free chlorine residual goals. As of July 11, 2017, the chlorine feed system has flow-pacing capability, which will reduce the operational burden on City staff.

Pumping

Pumping Sta	tions - C	onstructio	n, Control	s & Maintenance
Location:			West Side	e Reservoir
Function:	Pump fi	rom the West	Side Reserv	oir to supply areas on the west side
		of the	City during p	eak demand periods
Pump Number	1	2	3	4
Year Installed	1970	1970	1970	1970
lype	VT		VT	<u></u>
Current Capacity (MGD)	4	4	8	8
Current Capacity (GPM)			,	
Basis	· · · · · · · · · · · · · · · · · · ·			
	400			
	100	100	200	200
Corresponding MGD				
Original Name Plate TDH (FT)	142'	142'	142'	142'
Pump NPSH (FT)				
Centerline of Pump Intake Elev.				
Floor Elevation				
Electrical Controls Elevation				
Pumps/Motors Subject to Flood?		-		
Pump Efficiency		·		
Motor Efficiency				
Min. Reservoir WL				
Cavitation Problems (Y/N)			<u></u>	
VFDs (Y/N)				
Maintenance History	Refei	r to next page	for maintena	ance history of pumps and motors
Comments on Booster Pumping: water main breaks since the Wes suggested that Soft Starts or VFI pressure spikes within the distrib	The City has st Side Reso Ds be instal ution syster	as experience ervoir was ren led on the We n, which may	d a significar noved from s est Side boos be related to	nt significant drop in the number of service. Several sources have ster pumps to reduce or eliminate o main breaks.
AUXILIARY POWER	,	1		
Power Type	None			
Fuel Type		Starting Fre	quency	
Capacity (gpm)		Load Testin	g Frequency	
			an an the stand and a stand of the second stand of the stand stand and stand stand stand stand stand stand stan	
Total Pump Capacity (gpm)			mgd	
Firm Pump Capacity (gpm)			mgd	
Auxiliary Power Capacity (gpm)			mgd	
Max Day Demand @ this location			mgd	
Peak Hour @ this location			gpm (Hydr	ropneumatic Stations)
Avg Day Demand @ this location			mgd	
Firm Pump Capacity/Max Day		. <u> </u>	%	
Peak Hour/Firm Pumping Capaci	ty	······	% (Hydr	ropneumatic Stations)
Aux. Power Capacity/Avg Day			%	
Comments:				

Pumping

.

amping stations				
Location:		West Side	Reservoir	
Function:	Pump from	the West Side reserve	oir to supply area of the	west side
		of the City during pe	eak demand periods	
	Pumps and motors are	on a routine Preventive	e Maintenance (PM) sc	hedule consisting of
	visual inspection, check	king oil levels, and grea	asing bearings and fitting	os. On an as-needed
	basis, oil is changed, p	acking is adjusted, bea	rings are replaced, etc.	Recent. non-routine
	work is shown below.		unige alle teleficient etci	
West Side Station	West Side Station	West Side Station	West Side Station	1
Dumn 1	Pump 2	Dump 3	Pump /	
	Fullp 2	Fullip 3	Fullp 4	
6//105 - replaced	9/1/11 - replaced	4/28/15 - rebuilt	5/26/16 - replaced 4-	
motor bearings	upper and lower	discharge valve	way valve	
	motor bearings	control cylinder		
	4/9/12 - rebuilt motor,		-	
	installed new upper			
	shaft and coupling			
		I		

Disinfection	on (sodium hypochle	orite addition)		- Aller Aller
Point of Treatment	West Side Booster Sta.	-	,	
Injection Point:		_		
SINGLE FEIGHTS HE HALL COMPLETE		_		
Purpose:	See comments	_		
Year Initiated	2016	_		
Product:	NaOCI	_		
Manufacturer:	~14-15%	_		
Chemical Strength:		_		
Dilution:	NA	_		
ANSI/NSF Standard 60 Approval? (Y/N)	Yes	NSF max dose:	84	mg/L
Normal Feed Rate/Dosage		_mg/L		
Avg Plant Tap Residual (mg/L) total	;	free:		
Avg Distribution Residual (mg/L) total		free:		
Frequency of Residual testing Plant Tap	:	Distribution:		
Analytical Method Used		_		
Instrument:		_		
Any Overfeed Instances? (Y/N)	No	_ Date(s): _		
Any Low Feed Instances? (Y/N)	No	_ Date(s):		
Pump Type:	• • • • • • • • • • • • • • • • • • •	Model:		
Number of Pumps:				
Pump Capacity gpd max	· · · · · · · · · · · · · · · · · · ·	gpd min:		
psi	:			
Chemical Storage Tank Type		Volume:	220 gallons	
Weight/Level Reading Method				
SAFETY	· · · · · · · · · · · · · · · · · · ·	а. Э., *	· · · ·	e. ¹⁶
Separate Room No		Cylinder Repair Kit	NA	
Exhaust fan No	 Extra Chic 	rinator or repair kit	NA	
Fresh Air Vent No		Ammonia Bottle	NA	
Door Opens Out With Panic Bar Roll-up door	- Self C	ontained Air Packs	NA	
More than 1500 # Cl ₂ onsite NA		Training Programs	NA	
Electrical Protected from Gas? NA		Shower/Eye Wash	Eye wash	
Commonte	· · · · · · · · · · · · · · · · · · ·	<		
Comments:			285	

Pumping

-

Booster Pumping	Stations	is - Construction, Controls & Maintenance
Location:		Torrey Road Booster Station
Function:	Boo	ost pressure to the southwest portion of the City, including
-		the Hospital area
Pump Number	1	<u> </u>
Year Installed	1954	
lype		
Current Capacity (MGD)		
Current Capacity (GPM)		
Basis		
Current IDH (FT)		
HP -	40	125
Original Name Plate GPM		
Corresponding MGD	2.8	
Original Name Plate TDH (FT) Pump NPSH (FT)	65'	<u> 100' </u>
Centerline of Pump Intake Elev.		
Floor Elevation		
Electrical Controls Elevation		
Pumps/Motors Subject to Flood?		
Pump Efficiency		
Motor Efficiency		
Min. Reservoir WL		
Cavitation Problems (Y/N)		
VFDs (Y/N)	No	No
Maintenance History	Refer	er to next page for maintenance history of pumps and motors
Permit 120173 was issued in 20 upgrades have been completed. will reportedly move forward with	12 for signfi New pump pump insta	ficant upgrades to the Torrey Road Booster Station. Electrical ups were purchased but were not installed as planned. The City tallation in the near future.
PowerType	None	Power Rating (kWh)
Fuel Type	None	Starting Frequency
Capacity (gpm)		Load Testing Frequency
Total Pumo Gapacity (gpm)		mad
Firm Pump Capacity (gpm)		mad
Auxiliary Power Capacity (opm)		mad
Max Day Demand @ this location		mad
Peak Hour @ this location		dpm (Hydropneumatic Stations)
Avg Day Demand @ this location		mgd
Firm Pump Capacity/Max Day		%
Peak Hour/Firm Pumping Canaci	tv	(Hydropneumatic Stations)
Aux, Power Capacity/Avg Day	-7	%
Comments:		<u> </u>

Pumping

Bo	oster Pumping Stations - Construction, Controls & Maintenance
Location:	Torrey Road Booster Pumping Station
Function:	Boost pressure to the southwest portion of the City, including
	the Hospital area
	Pumps and motors are on a routine Preventive Maintenance (PM) schedule consisting of visual inspection, checking oil levels, and greasing bearings and fittings. On an as-needed basis, oil is changed, packing is adjusted, bearings are replaced, etc. Recent, non-routine work is shown below:
	Torrey Road Station Torrey Road Station
	2000 gpm pump

s water purchased from other sup f yes, list WSSN number (s): No. of Emergency Connections: Location Are valves at the interconnections Are the interconnected mains rout Comments: Water is sold to the to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2)) Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	S? Main Size rcised annually? flushed? of Flint by the Great La WA or to upgrade the Currently, water is trar CS-2, the City adds Ni Distrib	Capacity Capacity akes Water Au water treatme mitted from Gi aOH, orthopho	Metered? Status WS Metered? (Regular/Emergency) Con thority (GLWA). Flint is making a decision wh nt plant and treat raw water purchased from th WA to the water plant site, and is master-me sphate, and sodium hypochlorite.	SSN of inectio
Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	Main Size rcised annually? rflushed? of Flint by the Great Li .WA or to upgrade the Currently, water is trar CS-2, the City adds Ni	Capacity Capacity akes Water Au water treatme imitted from Gl aOH, orthopho	Metered? Status WS (Regular/Emergency) Con thority (GLWA). Flint is making a decision wh nt plant and treat raw water purchased from th WA to the water plant site, and is master-me sphate, and sodium hypochlorite.	SSN of inectio
Location Location Are valves at the interconnections Are the interconnected mains rout Comments: Water is sold to the to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2). Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	Main Size rcised annually? r flushed? of Flint by the Great L. WA or to upgrade the Currently, water is trar CS-2, the City adds Ni	Capacity akes Water Au water treatme mitted from Gi aOH, orthopho	Metered? Status WS (Regular/Emergency) Con thority (GLWA). Flint is making a decision wf nt plant and treat raw water purchased from tt WA to the water plant site, and is master-me sphate, and sodium hypochlorite.	SSN of mectio
Location Are valves at the interconnections Are the interconnected mains rout Comments: Water is sold to the to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2). Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	Main Size rcised annually? rflushed? of Flint by the Great La WA or to upgrade the Currently, water is trar CS-2, the City adds Ni	Capacity akes Water Au water treatme mitted from Gi aOH, orthopho	Metered? (Regular/Emergency) Con (Regular/Emergency) Con thority (GLWA). Flint is making a decision wh nt plant and treat raw water purchased from th WA to the water plant site, and is master-me sphate, and sodium hypochlorite.	SSN of inectio
Are valves at the interconnections Are the interconnected mains rout Comments: Water is sold to the to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2) Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	rcised annually? r flushed? of Flint by the Great Li .WA or to upgrade the Currently, water is trar CS-2, the City adds Ni Distrib	akes Water Au water treatme mitted from Gl aOH, orthopho	thority (GLWA). Flint is making a decision whether the second sec	nectio
Are valves at the interconnections Are the interconnected mains rout Comments: Water is sold to the to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2) Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	rcised annually? flushed? of Flint by the Great L WA or to upgrade the Currently, water is trar CS-2, the City adds Na Distrib	akes Water Au water treatme mitted from Gl aOH, orthopho	thority (GLWA). Flint is making a decision wh nt plant and treat raw water purchased from t LWA to the water plant site, and is master-me sphate, and sodium hypochlorite.	nether he itered
Are valves at the interconnections Are the interconnected mains rout Comments: Water is sold to the to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2) Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	rcised annually? flushed? of Flint by the Great L WA or to upgrade the Currently, water is trar CS-2, the City adds N Distrib	akes Water Au water treatme mitted from Gl aOH, orthopho pution Pipin	thority (GLWA). Flint is making a decision wh nt plant and treat raw water purchased from t LWA to the water plant site, and is master-me sphate, and sodium hypochlorite.	nether he stered
Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	of Flint by the Great L. WA or to upgrade the Currently, water is trar CS-2, the City adds N Distrib	akes Water Au water treatme mitted from Gi aOH, orthopho oution Pipin	thority (GLWA). Flint is making a decision wh nt plant and treat raw water purchased from th LWA to the water plant site, and is master-me sphate, and sodium hypochlorite.	nether he stered
Comments: Water is sold to the to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2) Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	of Flint by the Great L. WA or to upgrade the Currently, water is trar CS-2, the City adds N Distrib	akes Water Au water treatme mitted from Gl aOH, orthopho pution Pipin	thority (GLWA). Flint is making a decision wh nt plant and treat raw water purchased from th LWA to the water plant site, and is master-me sphate, and sodium hypochlorite.	hether he stered
to continue purchasing water from Karegnondi Water Authority (KW through Control Station 2 (CS-2) Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	WA or to upgrade the Currently, water is trar CS-2, the City adds Na Distrib	water treatme mitted from Gl aOH, orthopho oution Pipin	nt plant and treat raw water purchased from t LWA to the water plant site, and is master-me sphate, and sodium hypochlorite.	he stered
Karegnondi Water Authority (KW through Control Station 2 (CS-2) Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	Currently, water is trar CS-2, the City adds N Distrib	aoH, orthopho	WA to the water plant site, and is master-me sphate, and sodium hypochlorite.	
Mains by Material Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	Distrib	oution Pipin		
Mains by MaterialCast Iron96.64%Ductile Iron2.64%Steel0.46%Concrete0.22%Other0.03%Galvanized0.01%	Distrib	oution Pipin	α	
Mains by MaterialCast Iron96.64%Ductile Iron2.64%Steel0.46%Concrete0.22%Other0.03%Galvanized0.01%	Distrib	oution Pipin	α	
Mains by MaterialCast Iron96.64%Ductile Iron2.64%Steel0.46%Concrete0.22%Other0.03%Galvanized0.01%	Distrib	oution Pipin	a	ann an t-a
Mains by MaterialCast Iron96.64%Ductile Iron2.64%Steel0.46%Concrete0.22%Other0.03%Galvanized0.01%	Distrib	oution Pipin	α	Nava na seconda second
Mains by MaterialCast Iron96.64%Ductile Iron2.64%Steel0.46%Concrete0.22%Other0.03%Galvanized0.01%	DISUIK	uuon ripin	🗸 a parte establist su a su l'h a preval palas et d'hui a rische. En us stats parte prevale	a brat to mini he so the
Mains by MaterialCast Iron96.64%Ductile Iron2.64%Steel0.46%Concrete0.22%Other0.03%Galvanized0.01%				helistikky
Cast Iron 96.64% Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	Mains	s by Size	Mains by Date of Installat	ion
Ductile Iron 2.64% Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	2"	0.11%	1900 to 1910 3	1.50%
Steel 0.46% Concrete 0.22% Other 0.03% Galvanized 0.01%	3"	0.26%	1911 to 1920 25	5,90%
Concrete 0.22% Other 0.03% Galvanized 0.01%	4"	4.47%	1921 to 1930 34	4.00%
Other 0.03% Galvanized 0.01%	6"	51.59%	1931 to 1940 6	3.30%
Galvanized 0.01%	8"	23.74%	1941 to 1950 1	.20%
	10"	0.59%	1951 to 1960 25	5.00%
	12"	8.11%	1961 to 1970 2	.10%
	14"	0.81%	1971 to 1980 0).30%
	16"	3.52%	1981 to 1990 1	.70%
	18"	1.90%	1991 to 2000 0	.20%
•	20"	0.00%	2001 to Present 10	0.80%
	24"	3.88%		
	30"	0.58%		
		0.35%		
	36"			
	36" 42"	0.06%		
	36" 42" 48"	0.06%		
etimated percent of piping with a	36" 42" 48" 72"	0.06% 0.01% 0.02%		

Distribution piping data is taken from the 6/28/16 draft Asset Management Report by Rowe PSC and is based on 3,079,442 feet (583.2 miles) of water main.

Operational Concerns & Maintenance				
Are there areas where water main breaks are frequent? If yes, identify locations: See comments	Yes			
Comments: From 2010 - 2013, the City averaged about 155 breaks per year. In 2014 - 2015, which includes the period when the water plant was in full- time operation, the City averaged about 300 breaks per year. There has been a significant reduction in the number of breaks in 2017, which may be related to taking the West Side Reservoir and pumping station off line for inspection (it is believed that surges associated with operation of pumps and valves at West Side are a significant factor in water main breaks).	YearNumber of Breaks20121592013153201431620152772016138The City is working toward the Partnership for Safe Water goal of not more than 15 breaks per year per 100 miles of main, which equates to 85-90 breaks per year.			
Leak Detection and Condition Assessment:				
The City contracted with Echologics LLC in 2015 and 2016 to conduct a the distrbution system and a condition assessment on 24 miles of critic A water audit was also completed, GIS data points were collected, and The leak assessment work was divided into standard "listening" at mos mains. The "listening" portion of the leak assessment identified 82 lea "corrleation" portion of the assessment found no confirmed leaks, but sites)" that require further investigation. The condition assessment found that, of the critical pipes tested, 31% moderate condition, 8% were in poor condition, and 46% did not retur Are there areas where aesthetic water quality complaints are frequent? If yes, identify locations:	leak assessment of the majority of water main in cal mains (road, railroad, and waterway crossings). GIS training was provided. It locations and "correlation" on 15 miles of critical ks with an estimated total loss of 327 gpm. The identified four "Points of Interest (potential leak appeared to be in good condition, 15% were in in a result.			
Comments: Operators are currently doing a good job of meeting treatment goals, and distrbution maintenance practices taking place in an attempt to meet distri- distribution system water quality is improving. Many members of the publ however. Do you receive complaints alleging illness due to the water?	there is a significant amount of flushing and other ibution system water quality goals; therefore, ic have not regained confidence in the water system, Yes			
Comments: There have been complaints of lead-related and Legionella-related illness	es during and since the water crisis began.			

Operational Concerns & Maintenance				
Are there areas where customers complain of low pressure? No	-			
If yes, identify locations:				
Comments:				
What is the procedure to respond to and track these complaints? Comments: There are a number of personal and online resources available to track and addres	s complaints.			
Distribution System Capacity				
Are there areas where peak flows (including fire flow) cannot be maintained? If yes, identify locations:	<u>No</u>			
Comments:				
Last ISO report date? Rating				
Proposed distribution system improvements (Location and Estimated Completion E Several neighborhoods were identified for water main replacment in a 2016 DWRF prioritized based on several factors including occupancy, service line material, and Fundable Range, but the City must demonstrate a long-term, secure water source begin in 2017 or 2018.	Date): Project Plan. Proposed work areas were break history. The project is in the DWRF to qualify for funding. If funded, work would			
Distribution System Optimization	on			
An Assessment of Current Practices and Gap Analysis Technical Memorandum The document compares existing conditions and practices to industry best practicare not being achieved, and recommends improvements. The evaluation include integrity, and hydraulic integrity. The completed analysis is expected to provide	is being completed by Arcadis Group. ces, identifies "gaps" where best practices as water quality integrity, physical valuable operational advice.			

Number of Hydrants		the second s
Number Without Auxiliary Shut-Off Valves	3605	_(from 2013 Rowe Reliability Study)
Number that are Self-Draining		
Number of Inoperable Hydrants	See commen	ts
Frequency of Hydrant inspection:		_
Inspection Staff:		_
Are there areas where additional hydrants are needed?		_
If yes, list locations:		
Hydrant location system		Accurate?
Are hydrants color coded for capacity?	No	
Has this information been provided to the fire department?		
Frequency and seasons of hydrant flushing	Annual (fall)	
Purpose of flushing	Maintain wate	er quality
Is the public notified prior to flushing?	No	
Does flushing follow a specific format?	No, but a UDI	F program is being developed
Is the volume of water used during flushing estimated?	No	
Do hydrants receive maintenance painting?	No	
Is a record maintained of hydrant activities?	No	
Hydrant records should include: Hydrant number, location o	t the hydrant,	type of hydrant, size of barrel, size of bottom
valve, size of lead, direction of turn, operable or inoperable,	auxiliary valve	type and size, weep noies plugged or
unplugged, condition of hydrant (caps, chains, valve operation	on, operating r	nut, leakage & etc.), color coded capacity, flow
data (gpm & psi) flushing dates, inspection dates.		
Comments.	orable or page	ling repair. Recent bydrent ungredes are as
Fileway 2013 20 replaced 11 repaired; 2014 12 replaced	7 repaired: 2	119 repair. Recent hydranic upgrades are as
are very good, but a high percentage still require repair or re	, 7 repaired, 2 placement	ono - 55 replaced, 19 repaired, Necent enorts
Va	lves	
Number of Valves	8228	(From 2016 Rowe Reliability Study)
Number of inoperable valves	100	
	100	(See comments)
Are there areas where additional valves are needed?	100	(See comments)
Are there areas where additional valves are needed? If yes, list locations:	100	(See comments)
Are there areas where additional valves are needed? If yes, list locations:	100	(See comments)
Are there areas where additional valves are needed? If yes, list locations:	Man	(See comments)
Are there areas where additional valves are needed? If yes, list locations: Valve location system	Map	(See comments)
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies	Map Primary: Others:	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained?	Map Primary: Others:	(See comments)
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained?	Map Primary: Others:	(See comments) Accurate? Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valve operating status (open or closed), condition of valve (operation	Map Primary: Others: e(with witness	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valv operating status (open or closed), condition of valve (operable of operation	Map Primary: Others: e(with witness le or inoperab	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valv operating status (open or closed), condition of valve (operable of operation. Comments:	Map Primary: Others: e(with witness le or inoperab	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valv operating status (open or closed), condition of valve (operation of operation. Comments: The City has been appressively identifying and repairing or r	Map Primary: Others: e(with witness le or inoperab	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valve operating status (open or closed), condition of valve (operable of operation. Comments: The City has been aggressively identifying and repairing or reported that 57 valves were replaced in 2015, 85 were replaced in 2015, 85 were replaced in 201	Map Primary: Others: e(with witness le or inoperab eplacing inacc aced in 2016.	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valve operating status (open or closed), condition of valve (operation of operation. Comments: The City has been aggressively identifying and repairing or r reported that 57 valves were replaced in 2015, 85 were repla Valve boxes have been located and cleaned out. According	Map Primary: Others: e(with witness le or inoperab eplacing inacc aced in 2016, a to the Distribu	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valve operating status (open or closed), condition of valve (operation of operation. Comments: The City has been aggressively identifying and repairing or r reported that 57 valves were replaced in 2015, 85 were replaced Valve boxes have been located and cleaned out. According identified 900 inaccessible/inoperable/problem valves. and the	Map Primary: Others: e(with witness le or inoperab eplacing inacc aced in 2016, a to the Distribu- ne City is repo	(See comments) Accurate?
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valv operating status (open or closed), condition of valve (operation of operation. Comments: The City has been aggressively identifying and repairing or ri- reported that 57 valves were replaced in 2015, 85 were repla- Valve boxes have been located and cleaned out. According identified 900 inaccessible/inoperable/problem valves, and the about 100 in need of maintenance/repair/replacement. The	Map Primary: Others: e(with witness le or inoperab eplacing inacc aced in 2016, a to the Distribu- ne City is repo City has applie	
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valv operating status (open or closed), condition of valve (operation of operation. Comments: The City has been aggressively identifying and repairing or r reported that 57 valves were replaced in 2015, 85 were replaced Valve boxes have been located and cleaned out. According identified 900 inaccessible/inoperable/problem valves, and the about 100 in need of maintenance/repair/replacement. The amount of water main, which would result in additional valve	Map Primary: Others: e(with witness le or inoperab eplacing inacc aced in 2016, a to the Distribu ne City is repo City has applie replacement.	
Are there areas where additional valves are needed? If yes, list locations: Valve location system Valve Turning Frequencies Records Maintained? Valve records should include: valve number, location of valv operating status (open or closed), condition of valve (operation of operation. Comments: The City has been aggressively identifying and repairing or r reported that 57 valves were replaced in 2015, 85 were replaced Valve boxes have been located and cleaned out. According identified 900 inaccessible/inoperable/problem valves, and the about 100 in need of maintenance/repair/replacement. The amount of water main, which would result in additional valve continued progress and a long-term plan are still needed.	Map Primary: Others: e(with witness le or inoperab eplacing inacc aced in 2016, a to the Distribu ne City is repo City has applia replacement.	(See comments) Accurate?

	Cust	omer Service Inf	ormation	
Number of service conne	ctions	56,038	(number of parcels in City)	
Occupied parcels		43,406	(estimated number currently	occupied)
Number of metered servi	ce connections			
Percentage of service lin	e materials (all parcels):	C	wnership of Service (CWS/Custo	mer)
Copper	48.0%	From Corp Stop to C	Curb Stop	City
Galvanized or lead	52.0%	From Curb Stop to F	Property Line	City
Unknown		From Property Line	to Meter	Customer
Other		Meter		City
From July 1, 2016 to Jun service lines, which meet exceedance.	AST Start Program conse suspected lead/galvanized e 30, 2017, the City replac ts the EPA's requirement of	rvatively estimates in I lines are investigate ed 2150 service lines of at least 7 percent re	ere are 29,100 lead/galvanized se d, and non-copper portions of the s. This represents slightly over 7 p eplacement each year after a lead	lines are replaced. bercent of all targeted action level
CUSTOMER METERS	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	1- 4 	
Types of meters Used Number of Meters with R Residential Meter Sizes Industrial/Commercial Meter Average Age of Meter in Criteria for Changeout Number or Percent Char Master Meter Locations Calibration of Master Me Meter Reading Staff/Com	emote Reading Devices eter Sizes ice Program System ingeout per Year ters itract:		Detailed information reg water meters and replace not available at the time therefore the meter prog evaluated.	arding the city's ment program was of the survey, and gram could not be
Percent of Usage	by Customer Type		Large Users - % of Use	
% Residential	80%	McLaren Regional M	Medical Center	1%
% Other	20%	Genesee County Ja	il	<1%
		Hurley Medical Cen	ter (6th and Begole)	<1%
		Hurley Medical Cen	ter (One Hurley Place)	<1%
Comments:				

General Motors was a former customer that is now purchasing water from Genesee County, but may reconnect to the City's water system. The City is concentrating on the replacement of lead service lines. Approximately 1200 lead lines have been replaced in the last few years.

Year	# of Construction Permits Issued	Permitted Amount of WM Feet	A detailed breakdown of water main perm
2007	6	16,556	by purpose (new vs. replacement) was not
2008	4	2698	available at the time of the survey. A revie
2009	4	35,273	of records indicates that the majority of
2010	3	10,355	these permitted mains are for the
2011	1	13,854	replacement of existing mains. Most new
2012	2.	0	main is associated with transmission of rav
2013	1	31,418	water. Some permits included here are for
2014	2	0	pumps, controis, storage, and other
2015	4	18,100	improvements.
2016	3	10,300	

Comments:

Some of the above-permitted main was not constructed.

Water Ra	ntes	
What is your current rate schedule?	See comments	
Are current rates adequate to support O&M and CIPS?	See comments	
When was last time rates were adjusted?	2015	
Has a water rate study been performed? When?		
Is there a meter charge or ready to serve charge?	Yes	
Is a copy of the water rate schedule and ordinance available?		
Comments:		

A rate analysis was completed in 2016 by Raftelis Financial Consultants, which indicated a "typical" monthly water bill of \$53.84 for 5 ccf of water consumption. The bill includes commodity charges, operating costs, capital costs, personnel costs, etc. The Raftelis survey indentifies the commodity charge portion of a typical bill as \$15.89/month, or \$3.18/ccf (\$4.25/1000 gallons). The Raftelis survey further indicates that the current rate structure is not sufficient to meet future expenses due to a number of factors. The actual future gap between revenue and expenses is dependent on the City's final Source Selection and associated costs. The current rate was established in 2015 through a court decision.

			Repair Parts	Inventory
--	--	--	---------------------	-----------

Extra Mains (Sections for Each Size in Service)		
Repair Clamps (2 or more for each size)		
Tees, Crosses & Elbows		
Hydrants		
Valves		
Services (Corp & Curb Stops, Clamps and Lines)		
Other		
Comments:		
Information about repair parts and equipment was not available	e at the time of the surve	y.

Safety Programs

Confined Space Entry Program Trench Safety Program Comments: Information about the city's safety program was not available at the time of the survey.

PROGRAM COMPLIANCE

	Cross Co	onnection Prog	ram		
Ordinance No.	Ch. 46, Art. II, Div. 4	Date:	Various		
Approved Program (Y/N)?		Date:			
Staff Assigned to Program, (No.,	Dept and/or who)				
Is Annual Cross Connection repo	rt required (Y/N)?		Yes		
Was previous year's annual repo	rt received (Y/N)7		No	_ Date:	
was previous years annual repo	nacceptable (Y/N)/		NO		
Assembly Testing Frequency	macuve	High Hazard		Low Hazard	
Assembly Testing Performance		nigh hazaru.			
Record keeping:					
Private Well Isolation/Abandonm	ent Procedure:				
Comments:		• • • • • • • • • • • • • • • • • • •			
Annual Cross Connection Report	forms have not been rec	eived for 2015 or 2	016. The Cross	S Connection Inspec	ctor has been
working primarily on plumbing pe	rmits, and inspections an	e not being comple	ted.		
	Annual	Pumpage Rep	ort		
Is Annual Pumpage Report requi	red (Y/N)?		No		
Was previous year's annual repo	rt received (Y/N)?			Date:	
Comments:					
	Monthly	Operation Rep	orts		
Are Monthly Operation Reports r	equired (Y/N)?		Yes		
Were all previous year's reports i	received (Y/N)?		Yes	Timely?	Yes
Are previous year's reports accept	otable (Y/N)?		Yes		
If no, describe problems:	· · · · · · · · · · · · · · · · · · ·				
Commente					
The monthly operation report inc	ludes water nurchased fr	om GLWA chemic	als added at CS	-II. water quality da	ita at the water
plant tap, and water quality data	from the distribution syste	em. Chemical treat	ment at the Ced	ar Street and West	Side Reservoirs
is reported on daily summary rep	orts. Chemical feed data	from the reservoir	s should be inclu	uded on the monthl	v operation
reports once it is determined that	daily summary reports a	re no longer require	ed.	anna cara na mana anna anna an an an an an an an an an	Configuration of the second second
	Consume	r Confidence R	enort		
is the ennual CCR required? (X/I	Consume	I COIMdence I	Voe		
Was the previous year's report re	ceived? (Y/N)		Yes		6/13/2017
Was the previous year's accepta	ble? (Y/N)		Yes		0/10/2017
Was the previous year's certifica	tion form received? (Y/N)		Due 10/1/17	Date:	
Comments:					
	Emerger	ncy Response	Plan		
Date of ERP	2013	Acceptable?			
Filed where?			<u></u>		
Comments:	· · · · · · · · · · · · · · · · · · ·	***			
The most recent Emergency Res	sponse Plan on record wi	th the DEQ is from	2013. The 2013	3 Sanitary Survey re	ecommended an
update Emergency Response Pl	an due to changes in ope	rations. Since ther	n, signficant cha	nges to city and DE	Q staffing and
operational practices have occur	red, and an updated plan	is now required. If	an updated pla	n exists, the DEQ s	hould be notified
1		•			

PROGRAM COMPLIANCE

Date of Most Recent	Plan Various, up to 2016		
Filed Where?	Part of Rel. Study/Asset Mgt.	Acceptable?	
	General Layout	Yes	
	Facility locations & capacities	See comments	
	Water Main Inventory	Yes	
	Identification of Service Areas	In Contract w/GLWA	
	Hydraulic Analysis	See comments	
	Capital Improvement Plan	In DWRF Project Plan	
1.235			

Comments:

There is an existing hydraulic model of the distribution system, but fire flow contours or similar data were not provided. The U.S. EPA is in the process of developing and calibrating a new model. A draft Asset Management report was completed in 2016, which focused on the distribution system only, pending a selection of water source. Facility locations and storage and pumping capcities are included in the Reliability Study. Treatment capacities are available in this Sanitary Survey. A limited Capital Improvement Plan was also completed by Imagine Flint in 2105.

	Reliability Stud	ly	
Date of Most Recent Study	2016		
Filed Where?	City, MDEQ	Acceptable?	
Contents:	5 & 20 Year Demand Projections	Yes	
	Source Production Totals (Monthly)		
	Customer Supply Usage (Annual)		
	Res/Comm/Ind Usage (Annual)	Residential vs.other	
	Water Shortage Response Plan	See comments	
	Recommended Improvements		

Comments:

The Reliability Study projects a 20 percent population loss between 2015 and 2040, which would further affect the City's ability to raise adequate revenue through water rates. The study includes a detailed water shortage response plan, and water shortage is also addressed in Chapter 46, Article 1 of the City Ordinances. The water shortage response plan may need modification once the long-term and backup supply selection is made.

Applies for and obtains permits prior to construction (Y/N):	Yes	
Reviews plans prior to submittal to DEQ (Y/N):	Yes	
Standard specifications on file at CWS (Y/N):	• • • • • • • • • • • • • • • • • • • •	_
If applicable, adheres to contract with supplier regarding plan submittal (Y/N):	See comments	Date:
Follows master plan for any construction (Y/N):		
Develops as-built plans (Y/N):		
Updates general plans (Y/N):		
Comments:		_
The water contract with GLWA allows for review and approval of projects related	I to: new metering fac	cilities, water mains sized
24 inches or larger, pump stations, reservoirs, water towers, and projects in pro>	cimity to GLWA facilitie	es. It is not known
whether GLWA routinely excercises its right to do so.		

PROGRAM COMPLIANCE

Capacity Development

Comments on Capacity Development: The EPA has required (in its Administrative Order) that the City must demonstrate adequate Technical, Financial, and Managerial capacity (TMF) prior to switching to another water source (i.e., other than treated water purchased from the Great Lakes Water Authority (GLWA)). The decision whether to continue to purchase water from GLWA, begin treating raw water from the KWA, or select another source has not been finalized. Because the City's source water selection decision is not finalized, it is not known whether a formal TMF demonstration will be required. However, certain aspects of a TMF demonstration are necessary regardless of source selection.

The following components of a TMF capacity assessment warrant further discussion:

Technical Capacity:

1. Source - a water system must have an adequate quantity of water available to meet demands, either through its own production facilities or secured through contract and capable of delivery from another water system. At this time, the City only has a short-term agreement with GLWA for the purchase of treated water. The DEQ had instructed the City to either approve the long-term agreement with GLWA that was negotiated by Mayor Karen Weaver, or offer a reasonable alternaivte proposal to provide drinking water from another source, by June 26, 2017. The City has not done so, and therefore does not have satifactory Technical Capacity with regard to its source.

Financial Capacity:

1. Budget - a water system must have adequate revenue to operate its water system, including operational costs, personnel costs, capital improvements, and debt retirement. As stated in the Flint Water Rate Analysis by Raftelis, operational costs and staffling levels are highly dependent on the City's final selection of a water source. Raftelis projects a future gap between revenue and expenses, although the analysis was based on routine operation of the City's water plant and other conservative assumptions. The actual future gap, if any, is dependent on source selection, the terms of any water service agreements, efforts to improve water accountability (currently around 50 percent unaccounted), availability of grants and alternative funding sources, relative levels of automation and staffing, water rates, etc. Once the source determination is made, water rates should be reviewed and, if necessary, adjusted to ensure adequate financial capcity with regard to budget. It should be noted that, in addition to other duties, water treatment/operations staff are responsible for operation of five dams on the Flint River. The time and resources needed to manage the dams must be accounted for when developing staffing and budget plans for water treatment/pumping.

Also, it has been mentioned that a low pay scale is reportedly contributing to the City's difficulty in recruting, hiring, and retaining staff.

Managerial Capacity:

1. Maintaining Certified Operators - a water system must place its treatment and distribution systems under the supervision of properly-certified operators. Operations staff may either be City employees or contractors. The operator currently supervising the distribution system is a City of Flint permanent employee. The operator in charge of the treatment system is a contractor with Fleis & Vandenbrink Operations. The City may attempt to recruit an internal or external candidate to supervise the treatment system.

2. Sampling Plans - a water system must prepare sampling plans, and follow the plans when conducting compliance monitoring under the Safe Drinking Water Act. The City's Total Coliform Rule sampling plan must be revised to include an additional five (5) routine sites, with associated repeat sites. The Disinfection Byproducts sampling plan is satisfactory, but may need future revisions based on the Arcadis Group distribution system optimization study. The lead and copper sampling plan is revised as necessary as additional information is obtained regarding service line materials.

3. Cross Connection Control - a water system must implement a program for the elimination of cross connections within its distribution system. It appears that due to personnel shortages, adequate time is not being devoted to cross connection control, and inspections and program administration are lacking.

4. Other Plans and Studies - a water system must complete other plans and studies as required by the Safe Drinking Water Act. The City completed a draft Reliability Study and a draft Asset Management Plan in 2016. These studies should be finalized. Their contents are used to justify the City's Drinking Water Revolving Fund (DWRF) Project Plan and funding application. Also, an Asset Management Plan, and a 5-year and 20-year Capital Improvement Plan are required components of a Water System General Plan.

MONITORING

Bacteriological			
Date of Approved Site Sampling Plan :	2/21/2017		
Number of samples required each month:	100	Basis:	Population
Certified Lab Used:	City of Flint water	plant	
MCL, Monitoring or Reporting Violation(s) in past 3 years? (Y/N)	Yes	Date:	2014
Number & Type of Violations	3 MCL violations	in 2014	
Public Notice Issued according to regulations? (Y/N)	Yes	Date:	Various
Comments:			

The RTCR sampling plan was approved on 3/2/17 based on 20 routine sampling sites. Five more potential routine sites, with assoicated repeat sites, have been identified. The suitability of the sites will be confirmed, and the sampling plan will be expanded to 25 routine sites in the near future.

Date of Monitoring Schedule	5/12/2017	
MCL, Monitoring or Reporting Violations(s)? (Y/N)	No	
Public Notice Issued according to regulations? (Y/N)	NA	
Detects for inorganics > 50% of MCL? (Y/N)	No	
Detects for VOCs (Y/N)	No	
Detects for SOCs (Y/N)	No	
DBP Sampling Done According to Approved Plan? (Y/N/Waived)	Yes	
Date of Approved Disinfection Byproduct Monitoring Plan:	7/12/2016	

Comments:

The DBP Monitoring Plan may need to be updated based on the distribution system optimization study (in progress).

Lead and Copper Monitoring						
No. of Samples Required:	60					
Frequency (Semi Annual/Annual/Triennial)	See comments					
Exceedance of lead or copper action level (Y/N)	See comments					
If yes, was public education issued? (Y/N)	See comments	Date:				
Next Monitoring Period:	1/1/17 - 6/30/17	(final reporting in progress)				
Corrosion Control Program Status, if applicable	See comments					
Lead service line replacement status, if applicable	Active - see Custo	mer Sevice Information				
	page of this sani	tary survey for details				

Comments:

The city has collected two consecutive, 6-month rounds of samples (in 2016 and 2017) meeting the lead and copper action levels. The last monitoring period that exceeded the lead action level was January-June 2016. All required responses were completed in response to exceeding the action level. Samples are collected by the City, sentinel teams, and the public, and all valid tier 1 site results are used to calculate the 90th percentile lead and copper concentrations and determine compliance. The city is practicing corrosion control treatment for the incoming water from the GLWA. A corrosion control study is currently being conducted by Cornwell Engineering Group to evaluate current conditions and evaluate future possible situations (continued purchase of finished water from GLWA, purchase of water from Genesee County, treatment of KWA raw water at the Flint Water Plant, and combinations/mixing of those sources).

Date of Monitoring Schedule	Not R	equired
Date of Montoling Concurs	Alpha, beta, radium, uranium	Date:
	Radon	Date:
	Tritium	Date:
Detects for Rads > 50% of MCL? (Y/N)		
	If yes, list	Date:
Comments:		
Radiological monitoring is the responsibility of the	ne wholesale supplier (Great Lakes Water	Authority)

Analytical Capabilities

.

.

.

Parameter	Analytical	Calibration	Instruments	Method of Data	Frequency of	Sampling Location	Location for Water	Analysis Run by
	Method(s)	Frequency	Used	Recording	Measurements		Source	
Alkalinity	SM 2320B	Per batch of	Standard burettes	Manual	Weekly	CS-II	GLWA Supply Main	Lab staff
	Titration	titrant			Daily	Lab Tap	In-Plant Piping	
					Weekly	Distribution	Per RTCR Sampling Plan	
Total	SM 2340C	Per batch of	Standard burettes	Manual	Weekly	CS-II	GLWA Supply Main	Lab staff
Hardness		titrant			Daily	Lab Tap	In-Plant Piping	
					Weekly	Distribution	Per RTCR Sampling Plan	
Calcium	SM 3500 Ca D	Per batch of	Standard burettes	Manual	Weekly	CS-II	GLWA Supply Main	Lab staff
Hardness		titrant			Daily	Lab Tap	In-Plant Piping	
ar 1201 1202 12					Weekly	Distribution	Per RTCR Sampling Plan	Normal Continues of Continues o
pН	SM 4500 H+B	Daily	Hach HQ440d	Manual	Daily	CS-II	GLWA Supply Main	Lab staff
	Electrometric				Daily	Lab Tap	In-Plant Piping	
			Hach SL1000		Weekly	Distribution	Per RTCR Sampling Plan	
			Hach HQ440d		Every 2 Hours	CS-II	GLWA Supply Main	Operations staff
					Every 2 Hours	Mini Lab Tap	In-Plant Piping	
Conductivity	SM 2510B	Monthly	Mettler	Manual	Daily	CS-II	GLWA Supply Main	Lab staff
-			Toledo		Daily	Lab Tap	In-Plant Piping	
			Hach SL1000		Weekly	Distribution	Per RTCR Sampling Plan	
Temperature	SM 2550B	Annually	Grade 1	Manual	Daily	CS-II	GLWA Supply Main	Lab staff
	1788-000597 - H. HOT 196 24727-002		Thermometer		Daily	Lab Tap	In-Plant Piping	
					Weekly	Distribution	Per RTCR Sampling Plan	
Fluoride	SM 4500 F-C	Daily	Hach HQ440d	Manual	Daily	CS-II	GLWA Supply Main	Lab staff
	ISE				Daily	Lab Tap	In-Plant Piping	
Chlorine Residual		Daily	Hach SL1000	Manual	Twice per day	CS-II	GLWA Supply Main	Lab staff
					Twice per day	Lab Tap	In-Plant Piping	
1					Weekly	Distribution	Per RTCR Sampling Plan	
		Periodic Checks	Hach Pocket	Manual	Every 4 Hours	CS-II	GLWA Supply Main	Operations staff
		by Lab Manager	Colorimeter II		Every 2 Hours	Mini Lab Tap	In-Plant Piping	
			Hach CL-17	Manual	Continuous	CS-II	GLWA Supply Main	Operations staff
				Manual	Continuous	WTP Basement	In-Plant Piping	
Chloride	SM 4500 CI-B	Per batch of	Standard burettes	Manual	Weekly	CS-II	GLWA Supply Main	Lab staff
	Argentometric	titrant			Daily	Lab Tap	In-Plant Piping	
					Weekly	Distribution	Per RTCR Sampling Plan	
Turbidity	SM 2130B	Monthly - primary	Hach 2100 N	Manual	Twice per day	CS-II	GLWA Supply Main	Lab staff
	Nephelometric	Daily - secondary			Twice per day	Lab Tap	In-Plant Piping	
					Weekly	Distribution	Per RTCR Sampling Plan	
Total Colform	SM 9223 B-04	Biannual PE		Manual	Twice per day	CS-II	GLWA Supply Main	Lab staff
	Colilert				Twice per day	Lab Tap	In-Plant Piping	
					Weekly	Distribution	Per RTCR Sampling Plan	
HPC	SM 9215 B	Annual PE		Manual	Weekly	CS-II	GLWA Supply Main	Lab staff
	IDEXX Simplate				Weekly	Lab Tap	In-Plant Piping	
	· ·				Weekly	Distribution	Per RTCR Sampling Plan	
Iron			Hach DR 3900	M	Daily	CS-II	GLWA Supply Main	Lab staff
					Daily	Lab Tap	In-Plant Piping	
					Weekly	Distribution	Per RTCR Sampling Plan	

an na managa a sana ka managa m

Statutojy Well-spinored up and a state

NUMBER OF STREET, ST

Analytical Capabilities

х х.

tapaja en della "Di como en contento de mando el canedo 🕹 🌢

Parameter	Analytical Method(s)	Calibration Frequency	Instruments Used	Method of Dat Recording	Frequency of Measurements	Sampling Location	Location for Water Source	Analysis Run by
Sulfate			Hach DR 3900	Manual	Daily	I ab Tap	In-Plant Piping	Lab Staff
Phosphate			Hach DR 3900	Manual	Daily Daily Weekly	CS-II Lab Tap Distribution	GLWA Supply Main In-Plant Piping Per RTCR Sampling Plan	Lab Staff
 The lab is certifie Based on inspec Minor issues bro Lab QA/QC appediate The laboratory b The laboratory is 	ed for Total Coliforn tions and conversa nught to the attentio ears to be greatly ir alance was last cal s successfully runni	n, E. Coli, HPC, a tions between lab n of the Lab Mana nproved under the ibrated in Decemi ng extra performa	Other Notes/Ot and fluoride. I staff and DEQ field p ager are addressed p to current Lab Manage per 2016. Scale accu nce evaluation/profic	ersonnel, lab pr romptly. er, who is working racy is checked iency testing san	<u>aboratory Practic</u> actices are genera g on plans for furth monthly using certi nples each quarter	Ily satisfactory. er imprrovement. fied weights for all parameters be	eing reported to the DEQ/E	:Р А .

a second a second second

Sentre Margaret

AND TRACKS AND ADDRESS OF A DESCRIPTION OF A DESCRIPTIONO

Disinfectio	n (sodium hypochlo	orite addition)		
Point of Treatment	Control Station 2	akentlet ti songaganin tit		
Injection Point:	42-inch supply main	-		
5s(5)/4/(S-JE-scoll)(4-JE-365)((=, ==cit=)+				
Purpose:	See comments			
Year Initiated	2016			
Product:	Havasan LB-12			
Manufacturer:	Haviland	-		
Chemical Strength:	12%	_		
Dilution:	NA	_		
ANSI/NSF Standard 60 Approval? (Y/N)	Yes	NSF max dose:	84	mg/L
Target Feed Rate/Dosage	1.0 - 1.3	_mg/L		
Basis for Target Feed Rate	See comments			
Range of Incoming (GLWA) Residual	0.6 - 1.4	mg/L		
Range of Plant Tap Free Residual	0.8 - 2.0	_mg/L		
Range of Distribution System Free Residual	0.2 - 2.0	_mg/L		
Frequency of residual testing Incoming:	Continuous plus 2 confir	mation grabs/day		
Plant Tap:	Continuous plus 2 confir	mation grabs/day		
Distribution:	Several per week	_		
Analytical Method Used:	DPD			
Instrument:	Hach CL-17, Hach SL10	00, Hach Pocket Co	olorimeter	
Any Overfeed Instances? (Y/N)	No	Date(s):		
Any Low Feed Instances? (Y/N)	No	Date(s):		
Feed Pumps'				ς.
Type.	Dianhraom	Model	Milton Roy SD46-88P	
Number of Pumps:	2	-	Million 1109 00 10 001	•
Capacity:	10 gph each	Discharge Head:	150 psi	
				•
Type:	Diaphragm	Model:	LMI C721-71FS	
Number of Pumps:	1	_		•
Capacity:	4 gph	Discharge Head:	100 psi	
	(Note: this model is no lo	onger manufactured	, but repair parts are be	lieved
	to be readily available)			
		_		
Chemical Storage Tank Type	Totes (from supplier)	Volume:	220 gallons	-
Weight/Level Reading Method	Staff gage on tank wall	_		
Comments on Sodium Hypochlorite Feed: The C	ity purchases treated wat	er from the GLMA	and adds sodium hypor	chlorite
phosphoric acid, and sodium hydroxide to meet t	he plant tap free chlorine	residual (1.7 mg/l)	orthophosphate residua	al (3.6
mg/l), and pH (7.5 units) goals established by the	U.S. EPA's technical tea	am. The incoming.	Plant Tap, and Distribu	tion pH
ranges shown above are for the period of time w	hen sodium hypochloride	has been fed. The	feed pumps now have	flow-paced
controls to help maintain consistent feed rates.				
		4 - 144 - 141		
The existing treatment system was designed and	I installed as a temporary	measure while long	g-term treatment decision	ons are

The existing treatment system was designed and installed as a temporary measure while long-term treatment decisions are being made. Chemical scales may be installed at a later date. An SOP for chemical feed has been developed for both existing (temporary) and future (permanent) treatment at CS-II. Because the City has not selected a long-term water source, final decisions have not been made regarding the future treatment layout at CS-II.

Safety: The sodium hydroxide tote and sodium hypochlorite tote are stored together in a garage structure with air conditioning, a portable eye wash station, and face shield/gloves/PPE.

Corrosion In	hibitor (phosphoric	acid addition)		nd state
Point of Treatment	Control Station 2			
Injection Point:	42-inch supply main			
33) Matha Frandhan (G. (Caller (G. olyta)).		•		
Purpose:	See comments	•		
Year Initiated	2015 (December)	•		
Product	Phosphoric Acid	•		
Manufacturer:	Brenntag	•		
Chemical Strength	75%	-		
Dilution:	None			
ANSI/NSE Standard 60 Approval2 (Y/N)	Yes (NSF)	NSF max dose	13	ma/l
Target Feed Rate/Dosage	24-27	ma/l		
Basis for Target Feed Rate	See comments			
Bange of Incoming (GI WA) PO4	10-22	ma/l		
Range of Plant Tap PO4	35-39	mg/L		
Range of Distribution System PO4	29-39	- mg/L		
Frequency of residual testing	Daily	-		
Plant Tan:	Daily	-		
Fiant Tap.	Soveral per week	-		
Ansistian Mathed Llasd	Several per week	-		
Analytical Method Used.	Hach DR2000	-		
instrument.	Hach DR3900	-		
Any Overfeed Instances? (Y/N)	No	Date(s):		
Any Low Feed Instances? (Y/N)	No	Date(s):		- C
				-
Feed Pumps:	Disalar	N. S	1 14 0004 00001	
l ype:	Diaphragm	- Model: _	LIVII C921-36251	- 2
Number of Pumps:	<u>Z</u>	- Disada and Disada	100	
Capacity:	4 gpn each	_ Discharge Head: _	100	
Chemical Storage Tank Type	PE Shipping Totes	Volume:	220 gallons	
Weight/Level Reading Method	Scale markings on tote	-	220 901010	-
-	Codie Manningo officie	·		
Comments on Phosphoric Acid Feed: The City be control by re-establishing an orthophosphate scale The EPA has established a distribution system ort goal more consistently since May 2017. The incon the 12-month period covering June 1, 2016 to May	egan feeding phosphoric e on lead surfaces within thophosphate residual go ming, Plant Tap, and Dis y 31, 2017.	acid in December 20 the distribution syste al of 3.5 mg/l, and th tribution PO4 residua	15 to improve lead co em/individual plumbing ne City appears to be al ranges shown abov	prrosion g systems. meeting the e are for
The existing treatment system was designed and being made. Chemical scales may be installed at (temporary) and future (permanent) treatment at C decisions have not been made regarding the future	installed as a temporary is a later date. An SOP for CS-II. Because the City h re treatment layout at CS-	measure while long- r chemical feed has l las not selected a lor -II.	term treatment decision been developed for bo ng-term water source,	ons are oth existing final
Safety: The phosphoric acid tote is stored in a dif area in a garage structure with a portable eye was	ferent bay from the sodiu sh station.	m hydroxide and soo	dium hypochlorite stor	age/feed

pH Adjustn	nent (sodium hydro	xide addition)					
Point of Treatment	Control Station 2						
Injection Point:	42-inch supply main						
ALWARK RECEIPTING (D) (SURGERED CONTRACTOR)							
Purpose:	pH adjustment	-					
Year Initiated	2017 (February)	-					
Product	Sodium hydroxide	-					
Manufacturer:	Brenntag	-					
Chemical Strength	25%	-					
Dilution:	None	-					
ANSI/NSF Standard 60 Approval? (Y/N)	Yes (NSF)	NSF max dose:	200	mg/L			
Target Feed Rate/Dosage	2.6	mg/L					
Basis for Target Feed Rate	To meet the point-of-entr	y pH minimum goal	of 7.5 units, and the	_			
	distribution system goal of	of 7.5 +/- 0.3 units		-			
Range of Incoming (GLWA) pH	7.18 - 7.47	_					
Range of Plant Tap pH	7.17 - 7.50	-					
Range of Distribution System pH	7.14 - 7.59	•	N N N 199				
Frequency of pH testing Incoming:	Every 2 hours plus daily	confirmation grab by	y lab staff	-			
Plant Tap:	Every 2 hours plus daily	confirmation grab by	y lab staff	-			
Distribution:	Several per week	-					
Analytical Method Used:	Electrode						
Instrument:	Hach HQ440d, Hach SL	1000					
Any Overfeed Instances? (Y/N)	No	Date(s):					
Any Low Feed Instances? (Y/N)	No	Date(s):		-			
Food Pumps		-		-			
Type:	Dipphragm	Model	Milton Poy SD/6.88P				
Number of Pumps:	2		Willow Roy SD40-00P	-			
Canacity:	10 onb each	Discharge Head	150 nsi				
Captiony.	io gpireadit	_ Discharge riedu.	100 par	-			
Type:	Diaphragm	Model:	LMI C721-71FS				
Number of Pumps:	1			-			
Capacity:	4 gph	Discharge Head:	100 psi	_			
	(Note: this model is no lo	nger manufactured	, but repair parts are be	elieved			
	to be readily available)						
Chemical Storage Tank Type	PE Shipping Totes	Volume:	220 gallons	-			
Weight/Level Reading Method	Scale markings on tote	-					
Comments on Sodium Hydroxide Feed: The City	becan feeding sodium b	udrovide in Februar	v 2017 to stabilize nH L	ovole in			
the distribution system. Beginning in June 2017	the sodium hydroxide do	sade was gradually	increased to meet the	FPA's			
recommended distribution system pH goal of app	roximately 7.5 units. The	incoming. Plant Ta	p. and Distribution pH	ranges			
shown above are for the period of time when sod	um hydroxide has been f	ed. The feed pump	s now have flow-paced	controls			
to help maintain consistent feed rates.	,						
The existing treatment system was designed and	installed as a temporary	measure while long	-term treatment decision	ons are			
being made. Chemical scales may be installed a	t a later date. An SOP fo	r chemical feed has	been developed for bo	oth existing			
(temporary) and future (permanent) treatment at a	CS-II. Because the City r	has not selected a lo	ong-term water source,	final			
accisions have not been made regarding the future treatment layout at Co"ll.							
Safety: The sodium hydroxide tote and sodium h	voochlorite tote are store	d together in a gara	de structure with air co	nditioning			
a portable eye wash station, and face shield/glove	es/PPE.	- together in a gara	ge strastars mitri un oo				
	552 	er son a top motion a procession					

,

Corrosion Control Treatment - General Comments
As part of the U.S. EPA's Emergency Administrative Order, the City's Optimal Corrosion Control plan must be reviewed and, if necessary, revised. To accomplish this, a contract was awarded to Arcadis Group to complete a Water Distribution System Optimization study, including a Corrosion Control Plan (CCP). The CCP is being completed by Cornwell Engineering Group as a subcontractor to Arcadis Group.
The proposed scope of the CCP (dated 12/19/16) included: -An evaluation of the existing Flint system (purchase of treated water from Great Lakes Water Authority) -The potential conversion to Genesee County as water supplier -A plan for treating KWA raw water at the Flint Water Treatment Plant -An evaluation of the interface (blending) between two sources of treated water The DEQ recommended that the scope be flexible enough to consider other scenarios The final CCP has not been finalized, in part due to delays caused by the City failing to select a permanent water source.

Appendix A

Classes offered at the Flint Water Treatment Plant, 2016-2017:

Safe Drinking Water Act Overview: September 27, 28, and 29, 2016 (2 hours each day) – Bryce Feighner (DEQ)
Basic Math and Hydraulics (condensed course): October 18, 19, and 20 (2 hours each day) – Bob London and Jon Bloemker (DEQ)
Filtration: November 29, 30, and December 1, 2016 (2 hours each day) – Nick Pizzi
Rapid Mix, Flocculation, and Sedimentation: January 10 and 11, 2017 (2 hours each day) – Nick Pizzi
Jar Test Calculations: March 14, 2017 (2 Hours) – Nick Pizzi
Hands-on Jar Testing: March 15, 2017 (2 Hours) – Nick Pizzi
Chemical Feed: April 18, 2017 (2 Hours) – Nick Pizzi
Distribution Math: April 19, 2017 (2 Hours) – Nick Pizzi
Lime Softening Practice Math: April 19, 2017 (2 Hours) – Nick Pizzi
Ion Exchange Practice Math: April 20, 2017 (2 Hours) – Nick Pizzi
Basic Math: July 17, 2017 (2 Hours) – Nick Pizzi
Chemical Feed: July 18, 2017 (2 Hours) – Nick Pizzi

Attachment B



Dr. Karen Weaver Mayor

September 8, 2017

Mr. Robert A. London, P.E. Surface Water Treatment Engineer Engineering Unit Drinking Water and Municipal Assistance Division Department of Environmental Quality 401 Ketchum Street Suite B Bay City, Michigan 48706

Sent via e-mail

Dear Mr. London,

This correspondence is in response to the Water System Sanitary Survey, WSSN: 2310 received on August 11, 2017. The Survey identified several *significant deficiencies* and *deficiencies* associated with the Flint water system. Additionally, *recommendations* are made regarding several elements of the water system. As required in your Violation Notice, the City requests the Department of Environmental Quality consider the following information when assessing the various survey elements.

Significant Deficiencies

1. Source - The City has failed to select a long-term water supply source.

The City administration has recommended a preferred primary long-term water source (GLWA) and is currently in litigation to support obtaining all approvals required to finalize all contracts. A final long-term water supply source selection should be completed within the 120 day corrective action time period.

2. Distribution System – The City's cross connection program is not being implemented in a satisfactory manner.

The City of Flint's Cross Connection manager has been performing the City's plumbing and mechanical inspections for the last two years. Therefore, cross connection inspections and backflow prevention devise testing has been deficient. The City plans to hire a cross connection manager before the end of 2017 to restart the cross connection control program. Initially, additional support personnel may be required on an "as needed" basis to catch up on the lack of cross connection activity over the last couple of years.

CITY OF FLINT

The Standard Operating Procedures (SOPs) for the maintenance and operation of distribution system components are being developed by Arcadis as part of their Water Distribution System Optimization Plan. These draft SOPs should be available in September, 2017. Once the SOPs are reviewed and approved (planned for the end of 2017), budget and staff recommendations will be made to promote implementation of these best practices. These recommendations will be considered during the 2018 budget process.

4. System Management and Operation – The DEQ does not have confidence that the City can continue to demonstrate the Technical, Managerial, and Financial (TMF) capacity necessary to consistently operate the water system in accordance with Act 399 after the current technical and training assistance contract expire.

The City of Flint provided USEPA the attached August 18 correspondence addressing the managerial and operational staffing of the Utility's Water Division. The proposed staffing level (see organization chart) assumes that the mayor's water source recommendation is finalized. The City plans to achieve full staffing by the end of 2017. Training will continue until sufficient technical capabilities are achieved.

5. Financial – The City should adopt an appropriate rate structure and administrative policies for the water system

The City is currently undertaking a rate analysis based on the mayor's recommended water source selection. The Cost of Service analysis has been completed and provided to the FWICC Rate Subcommittee for comments. Comments have been received from the Subcommittee and these comments are being considered in the rate design. Upon completion of the rate study, appropriate rate adjustment will be considered when developing the 2018 budget.

Deficiencies

6. Storage – The Cedar Street Reservoir requires an inspection

The City agrees that Cedar Street Reservoir requires an inspection. However, before this inspection can be undertaken, a distribution system storage analysis is required to determine if West Side and Dort Reservoirs must be repaired/upgraded and placed in-service before draining Cedar Street Reservoir. This analysis is currently being performed by Arcadis. Hopefully, inspection of Cedar Street Reservoir can occur in 2018.

7. Operator Compliance – The City has been unable to recruit and retain a properlycertified operator-in-charge, and is also having difficulty reaching desired staffing levels.

Please see response to number 4. The City is interviewing candidates with appropriate credentials to be the certified operator-in-charge for the Flint water system. Additionally, Flint will continue to train existing operators to promote their achieving higher licensing levels. Hopefully, an existing operator will obtain the required licensing level through the MDEQ testing in November.

8. Security – The City has not provided an updated Emergency Response Plan for DEQ review.

The Emergency Response Plan will be updated by June, 2018.

Recommendations

,

9. Source – An evaluation of the reliability of utility power and the need for an on-site emergency generator should be completed.

The current treatment plant site receives electric power from two independent substations. This redundant power feed has historically provided a reliable electric power source to the treatment plant. Additional power source reliability should not be required.

10. Treatment – Additional features should be added to the treatment system currently in operation at CS-II to enhance treatment reliability and consistency, as well as operator safety.

The current chlorine, orthophosphate and caustic soda feed system were constructed as "temporary" facilities to treat GLWA water until a long-term water source was selected. If GLWA is designated as the long-term primary water source, the existing facilities will be modified to improve process control and monitoring, reliability, redundancy and ease of operation. Design of these improvements by CDM-Smith has commenced and will be completed after the water source selection is finalized. Construction will be completed in 2018.

11. Distribution System – The City should plan financially for periodic updates of the General Plan, Asset Management Plan and Capital Improvement Plan.

The City will either budget for periodic updates of these Plans or develop the in-house capabilities to properly modify the Plans to reflect changing conditions.

12. Distribution System – The design of future water main replacement projects should strongly consider water age/water main sizing.

A hydraulic model of the Flint distribution system has been develop and calibrated. This tool predicts water age under various hydraulic conditions in the distribution system. A storage analysis is also currently being conducted to optimize system storage considering peak demand requirements and the impact of water age on water quality. The results of these analyses will be used to develop the scope and timing of required distribution system capital improvement projects.

13. Storage – A back-up power supply should be provided for the Cedar Street Reservoir booster station.

The Cedar Street switchgear is compatible with the hook-up of a mobile generator. The City will either purchase a properly sized portable generator to service the booster station during a power outage or outsource this emergency response to a qualified vendor.

14. Pumps – Upgrades to the Torrey Road and Cedar Street booster pumps should be completed.

The Torrey Road booster pumps will be installed in 2018. The installation of pumps and VFDs in the Cedar Street booster station is included in a list of projects that will request WIIN/DWRF funding. A Project Plan will be submitted for this funding by December, 2017. Assuming the funding is approved, design will be completed in 2018 and installation in 2019.

15. Monitoring and Reporting – The City should begin planning financially for staff to complete all monitoring and reporting requirements.

As previously stated, the City will be fully staffed by the end of 2017. This staffing includes the water quality and laboratory support personnel to achieve MDEQ monitoring and reporting requirements, including the requirements of the Lead & Copper Rule.

The City recognizes that all *significant deficiencies* will not be corrected within the 120 day corrective action time period mandated in your letter. However, once a water source selection is finalized, staffing levels are enhanced, a Program Manager is contracted and SOPs are completed, the City will have made significant progress toward improving the quality and reliability of its water system operation.

If you have clarifying questions and/or need additional information, please contact me at (810) 237-2035 or via email at kweaver@cityofflint.com.

Respectfully submitted,

aren A. Skeaver

Dr. Karen W. Weaver Mayor

cc: Mr. Eric Oswald, MDEQ Mr. Sylvester Jones, City of Flint Mr. Rob Bincsik, City of Flint Mr. Mark Adas, City of Flint

Attachments: City of Flint Correspondence to USEPA – August 18,2017 Flint Water Organization Chart



Attachment C



STATE OF MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY SAGINAW BAY DISTRICT OFFICE



C. HEIDI GRETHER DIRECTOR

March 21, 2018

The Honorable Karen W. Weaver, Mayor City of Flint 1101 South Saginaw Street Flint, Michigan 48502

Dear Mayor Weaver:

SUBJECT: Water System Sanitary Survey, WSSN: 2310

The Department of Environmental Quality (DEQ) has reviewed the city of Flint's (City) efforts to resolve the Significant Deficiencies and Deficiencies identified in our 2017 sanitary survey of the City water system. The City, the DEQ, and the U.S. Environmental Protection Agency (EPA) have been working closely to address these issues.

The Significant Deficiencies, Deficiencies, and Recommendations listed below were identified in our sanitary survey, and the City provided a response in your September 8, 2017 letter. Based on your response, and several discussions with City staff and contractors, we have the following comments.

Significant Deficiencies

1. Source - The City has failed to select a long-term water supply source.

This issue is resolved. The City executed a 30-year water supply agreement with the Great Lakes Water Authority (GLWA), with an effective date of December 1, 2017. Selection of a long-term water source allows the City to move forward with addressing other water system issues.

2. Distribution System – The City's cross connection control program is not being implemented in a satisfactory manner.

This issue is unresolved. The City has stated its intent to fill the vacant cross connection manager position and resume cross connection control activities but has been unable to hire a permanent employee for the manager position. It is our understanding that the City is negotiating for temporary, contractual assistance to oversee its cross connection control program. The use of contractual services to implement the program is acceptable to DEQ. A permanent or contractual cross connection manager must be in place, and routine cross connection control program activities must resume, by June 20, 2018. Implementation of the cross connection program will be evaluated under item 4 (System Management and Operation) below.

3. Distribution System – the City has not provided details about maintenance and replacement programs and/or Standard Operating Procedures (SOPs) for hydrants, valves, meters, and galvanized service lines.

This issue is unresolved. Several SOPs were prepared for the City by the Arcadis Group as part of the City's Distribution System Optimization Plan, but the City has not indicated its formal approval of the SOPs. For each Distribution System SOP, the City must provide the following to the DEQ by April 20, 2018: a signed, dated copy of the SOP (if the City intends to implement the SOP as written), or a statement indicating that a revised SOP is necessary. If revised SOPs are necessary, signed, dated copies of the revised SOPs must be submitted to us by May 21, 2018. Also, an SOP for galvanized service lines was not submitted and a signed, dated copy must be provided by May 21, 2018. The City's implementation of the approved SOPs will be evaluated under item 4 (System Management and Operation) below.

4. System Management and Operation – The DEQ does not have confidence that the City can continue to demonstrate the Technical, Managerial, and Financial (TMF) capacity necessary to consistently operate the water system in accordance with Act 399 after the current technical and training assistance contracts expire.

The overall issue of demonstrating adequate TMF capacity remains unresolved until the other Significant Deficiencies and Deficiencies identified in this letter are appropriately addressed. The DEQ will continue to work with the City and with EPA to ensure TMF capacity is maintained.

5. Financial – The City should adopt an appropriate rate structure and administrative policies for the water system.

This issue is unresolved. Selection of a long-term water source has allowed the City to begin financial planning; however, a water rate structure must be implemented that allows the City to properly operate and maintain the water system. The City must notify us by May 21, 2018, of your plan to implement a sufficient rate structure, including an effective date for any new rates.

Deficiencies

6. Storage – The Cedar Street Reservoir requires an inspection.

This issue is unresolved; however, the DEQ agrees the distribution system storage analysis should be completed before an inspection plan and schedule are developed for the Cedar Street Reservoir. The City projects the analysis will be completed and the reservoir inspection will take place in 2018. The inspection must be completed, and an inspection report and plan for completing any necessary improvements must be submitted to us, by September 28, 2018. Mayor Weaver

7. Operator Compliance – The City has been unable to recruit and retain a properly-certified operator-in-charge, and is also having difficulty reaching desired staffing levels.

This issue is unresolved. The City has been unsuccessful in its attempts to recruit and hire critical water system staff. The City must supply a full-time operator-in-charge on a permanent or contractual basis and sufficient staffing on a permanent or contractual basis to conduct continuous treatment system operations by June 30, 2018.

8. Security – The City has not provided an updated Emergency Response Plan for DEQ review.

This issue is unresolved; however, the City has committed to competing the Emergency Response Plan by June 2018. We interpret this to mean an updated plan will be submitted to DEQ by June 30, 2018. This schedule is acceptable to the DEQ.

Recommendations

9. Source – An evaluation of the reliability of utility power and the need for an on-site emergency generator should be completed.

This issue is resolved. The selection of a long-term water source has made an evaluation of the power supply to the water treatment plant unnecessary. Power needs may be considered during the design of permanent chemical feed facilities (item 10 below).

10. Treatment – Additional features should be added to the treatment system currently in operation at CS-II to enhance treatment reliability and consistency, as well as operator safety.

Design of chemical feed system improvements must be completed by December 31, 2018, and construction must be completed by December 31, 2019.

11. Distribution System – The City should plan financially for periodic updates of the General Plan, Asset Management Plan and Capital Improvement Plan.

The City indicated its intent to budget for periodic updates or develop in-house capability to complete these tasks. The cost of completing this task must be reflected in your water rates/budget.

12. Distribution System – The design of future water main replacement projects should strongly consider water age/water main sizing.

The City indicated its intent to use the recently-developed hydraulic model of the distribution system during the design of water system improvements. This is acceptable to the DEQ.

4

13. Storage – A back-up power supply should be provided for the Cedar Street Reservoir booster station.

The City indicated its intent to either purchase or arrange for the use of a properly-sized portable generator at the Cedar Street Reservoir. The generator should be purchased, or the emergency services contract should be executed, by <u>December 31, 2018</u>.

14. Pumps – Upgrades to the Torrey Road and Cedar Street booster pumps should be completed.

The City indicated the Torrey Road pumps will be installed in 2018, and upgrades to the Cedar Street pumps will be designed in 2018 and completed in 2019. This schedule for completing the work is acceptable to the DEQ.

15. Monitoring and Reporting – The City should begin planning financially for staff to complete all monitoring and reporting requirements.

The City indicated its intent to have adequate staffing and laboratory facilities to complete these tasks. The cost of completing this task must be reflected in your water rates/budget.

If you have any questions, please contact me at the phone number listed below or by email to londonr@michigan.gov.

Sincerely,

Robert A. London, P.E. Surface Water Treatment Engineer Engineering Unit Drinking Water and Municipal Assistance Division 989-450-7834

bl/ajl

- cc: Mr. Mark Adas, City of Flint
 - Mr. Rob Bincsik, City of Flint
 - Mr. Robert Jones, F&V Operations
 - ✓Mr. Eric Oswald, DEQ
 - Ms. Sue Maul, DEQ

City of Flint Water Department Technical, Management and Financial Capacity

The City of Flint (COF) has identified its long-term water source and has initiated the implementation of selected projects necessary to enhance the reliability and quality of its water system. However, the enduring sustainability of its system can only be achieved if the COF has the proper technical, managerial and financial (TMF) capacity to properly operate the system. This requirement is recognized in USEPA's First Amendment to Flint's Emergency Administrative Order (Paragraph 60.b.iii) and Michigan DEQ's August, 2017 Water System Sanitary Survey.

To help define the TMF capacity requirements of the COF water system, Arcadis of Michigan LLC (Arcadis) recently completed a report entitled "Water Distribution System Optimization Plan". This analysis developed a 20-year Capital Improvement Program (CIP), an Asset Management Program, staffing requirements, performance metrics and Standard Operating Procedures (SOPs) for the COF Water Department.

The revenue generated by the COF Water Department is not sufficient to support the current operating costs of the system. This discrepancy results for several reasons – low collection rates, declining population, inaccurate meters, loss of industrial/commercial customers, and water theft. To achieve "Cost of Service" rates under current conditions, annual rate increases of 20%, 16% and 10% would be required over the next three (3) years. If collection rates were return to a level closer to industry standards (95%), three 10% rate adjustments would still be required to achieve sufficient revenue. While alternative rate design were investigated to minimizes residential customer rate impact, such as inclining block rates, none of these alternative rate designs were deemed to be politically or financially feasible.

The political and financial environment in Flint is not amenable to implementing a customer rate increase over the next several years. Therefore, revenue enhancements must be achieved through improving collections and reducing the physical and commercial water losses associated with non-revenue water. A projected five-year forecast for Water Department revenue has been developed based on the following assumptions:

- Increase Water Department revenue by adjusting the water/wastewater revenue allocation from 45%/55% to 50%/50%.
- Increased sales to General Motors (\$0.4M/year)
- Improve collection rates from approximately 70% to 80% in 2019, 90% in 2020 and 95% in 2021.
- One-half of current non-revenue water (25% of purchased water) results from commercial losses (meters and theft). These losses are converted to additional revenue by the meter replacement program and an aggressive water theft prevention program
- No customer rate increases

Based on these assumptions, the Water Department revenue would be:

	FY2019	FY2020	FY2021	FY2022	FY2023
Base revenue with improved collections	\$31M	\$35.4M	\$40M	\$42M	\$42M
Improved metering and eliminate water theft			\$5M	\$10M	\$20M
Total revenue	\$31M	\$35.4M	\$45M	\$52M	\$62M

It is assumed that the revenue benefits from the metering/theft programs would not be realized until after all meters are installed by the end of 2019. However, some theft issues could be resolved concurrent with meter replacement.

Future operating costs will be primarily impacted by staffing levels. Arcadis has recommended that the following positions be added to provide the appropriate TMF capacity.

- Laboratory Technician
- Cross Connection Program Manager
- Water Distribution Valve and Hydrant Crew (3)
- Customer Service/ Call Center Staff (4)
- Enterprise Asset Manager
- GIS Specialist/ Hydraulic Modeler
- Construction Inspectors
- Leak Detection Team
- Flushing Team (2)

The first six listed positions are considered "high priority". The current COF Water Department budget does include the laboratory and cross connection positions because they are directly related to water quality issues. The remaining positions have not been included in the five year plan due to budget constraints and the challenge of attracting qualified personnel. The total annual costs of these positions would be approximately \$1M.

The currently forecasted operating costs for the COF Water Department are presented below.

	2018	2019	2020	2021	2022
Projected Operating Costs	\$34.5M	\$36M	\$37M	\$38M	\$38.3M

Given the lack of investment in the Flint water system for several decades, the future capital expenditure requirements are significant. Over the next two years, approximately \$80M of WIIN grant funds have been designated for the COF to complete numerous capital projects that enhance the water system reliability, revenue and water quality management. However,

significant additional investment is required to support small main replacement, a cross connection control program, a customer service center, valve and hydrant replacement, SCADA and security upgrades and a water loss program for the COF water system. Arcadis has identified over \$300M of capital expenditure requirements over the next 20 years with the majority of these projects being small main replacement. Unfortunately, the COF will be challenged to find the funding for these projects.

The table below helps define when funds may be available to hiring additional staff and invest in the system if the revenue enhancement programs are successful.

	FY2019	FY2020	FY2021	FY2022	FY2023
Revenue	\$31M	\$35.4M	\$45M	\$52M	\$62M
Operating Costs	\$34.5M	\$36M	\$37M	\$38M	\$38.3M
Water Fund Balance*	\$8.5M	\$7.9M	\$9M	\$9M	\$9M
Funds available for staffing and/or capex			\$6.9M	\$14M	\$23.7M

*Beginning Water Fund balance = \$12M; Water Fund balance should be approximately 25% of O&M costs

Therefore, given the above discussion, the COF proposes the following plan to achieve its TMF capacity requirement:

- Fill all COF Water Department staffing vacancies at the earliest possible date, including the laboratory technician and cross connection program manager positions. Until all vacancies are filled, outsource critical responsibilities not covered by existing staff. For regulatory acceptance, this will require committing to specific dates for hiring each position and executing contracts for outsourcing.
- 2. Initiate and complete the meter replacement program by the end of 2019 to enhance system revenue with more accurate and reliable meters. In conjunction with the meter replacement program, inspect the premise of all active and inactive customer accounts to identify and resolve water theft issues. Continue with an aggressive water theft prevention program. Additionally, in conjunction with the meter replacement program, collect data to assist with the prioritization of cross connection activities.
- 3. Adhere to water bill collection policies to return collection rates to industry standards by 2021 (greater than 95%)
- 4. Efficiently and effectively complete a majority of the WIIN funded construction projects in 2018 and 2019. Given the size of this program and Flint's history of limited capital projects within its distribution system, it would be difficult to perform any additional City-funded capital projects during this time period.
- 5. Closely monitor projected vs. actual revenues and identify and correct any variances.
- 6. Assuming projected system revenues are achieved through the meter, collections and water theft programs and revenues are further enhanced by community development activities, begin implementing the staffing and capital program recommended in the Arcadis report in FY2021.

Organizational Chart Utilities Water Division

