



Fluoridation & Chlorination

WSSN 2310

Jul-18

D A T E	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
		Raw	Tap	Dist	Chlorine App. Mg/l	Chlorine (prior to filtration) mg/L OCl ⁻	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap					
								Free	Free	Free	Free					
		14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1		0.78	0.78		1.12				0.9						1.7	
2		0.74	0.77		1.23				0.9						1.8	
3		0.78	0.78		1.09				1.0						1.7	
4		0.79	0.76		1.20				0.9						1.7	
5																
6																
7																
8																
9																
10																
11																
12																
13																
14																
15																
16																
17																
18																
19																
20																
21																
22																
23																
24																
25																
26																
27																
28																
29																
30																
31																
AVG			0.77		1.16				0.9						1.7	
MAX			0.78		1.23				1.0						1.8	
MIN			0.76		1.09				0.9						1.7	



Chemical Analyses WSSN 2310 Jul-18

D A T E	pH		Total Hardness as CaCO ₃ mg/l		Total Alkalinity as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l		Iron mg/L		Calcium Ca ²⁺ mg/l		Magnesium as Mg ²⁺ mg/l		Chloride as Cl ⁻ mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38.00	39	40	41	42	43	44
1	7.46	7.70		104		84		34	0.01	0.05		28.1		8.3		16
2	7.43	7.65	106	106	###	84	36	36	0.01	0.00	28.1	28.1	8.7	8.7	14.0	15
3	7.45	7.67		102		86		32	0	0.00		28.1		7.8		16
4	7.40	7.66		106		86		36	0.01	0.00		28.1		8.7		16
5																
6																
7																
8																
9																
10																
11																
12																
13																
14																
15																
16																
17																
18																
19																
20																
21																
22																
23																
24																
25																
26																
27																
28																
29																
30																
31																
AVG	7.44	7.67		105		85		35		0.01		28.1		8.4		16
MAX	7.46	7.70		106		86		36		0.05		28.1		8.7		16.0
MIN	7.40	7.65		102		84		32		0.00		28.1		7.8		15.0



WSSN 2310

Jul-18

D A T E	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1						2/0			0.23	16.5					
2						2/0			0.23	16.3					
3						2/0			0.23	16.3					
4						2/0			0.23	16.4					
5															
6															
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															
31															
AVG									0.23	16.4					
MAX									0.23	16.5					
MIN									0.23	16.3					



Distribution System Monitoring WSSN 2310

Jul-18

DATE	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l																									Chlorine only sites mg/l					Number of Samples
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24	25	
1																															0
2	1.20			1.33	1.31			1.60	0.97			0.98		1.58		1.25	1.61		0.64												10
3			1.44			1.36	1.36			1.54			0.94		1.20							1.37		1.68			1.15	1.22			10
4																															0
5																															0
6																															0
7																															0
8																															0
9																															0
10																															0
11																															0
12																															0
13																															0
14																															0
15																															0
16																															0
17																															0
18																															0
19																															0
20																															0
21																															0
22																															0
23																															0
24																															0
25																															0
26																															0
27																															0
28																															0
29																															0
30																															0
31																															0
Monthly Cl₂ Avg.				1.30																											
Total Samples				18																											



Distribution System Monitoring

WSSN 2310

Jul-18

D A T E	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l																									Chlorine only sites mg/l					Number of Samples
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24	25	
1																															0
2	1.40			1.57	1.45			1.84	1.16			1.21		1.79		1.69	1.85		0.82											10	
3			1.63			1.51	1.63			1.79			1.17		1.41						1.56		1.85			1.41	1.47			10	
4																														0	
5																														0	
6																														0	
7																														0	
8																														0	
9																														0	
10																														0	
11																														0	
12																														0	
13																														0	
14																														0	
15																														0	
16																														0	
17																														0	
18																														0	
19																														0	
20																														0	
21																														0	
22																														0	
23																														0	
24																														0	
25																														0	
26																														0	
27																														0	
28																														0	
29																														0	
30																														0	
31																														0	
Monthly Cl₂ Avg.				1.52																											
Total Samples				18																											

