



Fluoridation & Chlorination

WSSN 2310

Aug-18

D A T E	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
					Chlori ne App. Mg/l	Chlorine (prior to filtration) mg/L OCl ⁻	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap				
		Raw	Tap	Dist							Free	Free	Free	Free	
		14	15	16	17	18	19	20	21	22	23	24	25	26	27
1		0.75	0.82		1.21				1.0					1.7	
2		0.73	0.72		1.11				0.9					1.6	
3		0.66	0.69		1.02				0.9					1.7	
4		0.69	0.69		1.16				0.9					1.7	
5		0.69	0.69		1.13				0.9					1.7	
6		0.70	0.69		1.12				0.9					1.7	
7		0.71	0.70		1.14				0.8					1.7	
8		0.70	0.71		1.20				0.9					1.6	
9		0.68	0.72		1.32				0.9					1.7	
10		0.68	0.71		1.35				0.8					1.7	
11		0.71	0.69		1.34				0.9					1.8	
12		0.69	0.71		1.31				0.9					1.7	
13		0.71	0.70		1.31				0.8					1.6	
14		0.67	0.74		1.31				0.8					1.6	
15		0.68	0.69		1.28				0.8					1.7	
16		0.70	0.70		1.21				0.8					1.8	
17		0.71	0.75		1.33				0.8					1.6	
18		0.71	0.78		1.35				0.8					1.7	
19		0.75	0.79		1.35				0.8					1.7	
20		0.71	0.71		1.42				0.7					1.6	
21		0.73	0.76		1.30				0.8					1.6	
22		0.70	0.72		1.36				0.8					1.7	
23		0.69	0.69		1.37				0.9					1.7	
24		0.68	0.68		1.26				0.8					1.7	
25		0.69	0.70		1.19				0.8					1.7	
26		0.68	0.69		1.26				0.9					1.7	
27		0.67	0.67		1.34				0.9					1.7	
28		0.68	0.68		1.14				0.9					1.7	
29		0.68	0.67		1.12				0.9					1.7	
30		0.66	0.66		1.11				0.9					1.6	
31		0.67	0.66		1.26				0.9					1.7	
AVG			0.71		1.25				0.9					1.7	
MAX			0.82		1.42				1.0					1.8	
MIN			0.66		1.02				0.7					1.6	



Chemical Analyses

WSSN 2310

Aug-18

D A T E	pH		Total Hardness as CaCO ₃ mg/l		Total Alkalinity as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l		Iron mg/L		Calcium Ca ²⁺ mg/l		Magnesium as Mg ²⁺ mg/l		Chloride as Cl ⁻ mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38.00	39	40	41	42	43	44
1	7.52	7.68		104		84		36	0	0.00		27.3		8.7		15
2	7.53	7.64		100		86		32	0.0	0.00		27.3		7.8		15
3	7.52	7.66		102		84		32	0	0.00		28.1		7.8		15
4	7.50	7.58		94		80		26	0.01	0.01		27.3		6.3		14
5	7.49	7.67		104		86		36	0.01	0.02		27.3		8.7		15
6	7.48	7.69		104		86		36	0.01	0.01		27.3		8.7		15
7	7.49	7.67	104	104	88	88	36	36	0.01	0.01	27.3	27.3	8.7	8.7	15	16
8	7.51	7.71		104		86		36	0	0.01		27.3		8.7		15
9	7.57	7.71		104		82		36	0	0.00		27.3		8.7		14
10	7.54	7.70		106		82		40	0.01	0.01		26.5		9.7		13
11	7.53	7.73		104		82		34	0.02	0.01		28.1		8.3		13
12	7.53	7.72		104		84		36	0.01	0.01		27.3		8.7		13
13	7.50	7.72		104		82		34	0.02	0.02		28.1		8.3		13
14	7.57	7.72	102	102	80	80	32	34	0.01	0.02	28.1	27.3	7.8	8.3	13	13
15	7.53	7.73		104		80		36	0.01	0.02		27.3		8.7		14
16	7.50	7.68		102		80		32	0	0.01		28.1		7.8		14
17	7.51	7.59		94		80		30	0.01	0.01		25.7		7.3		13
18	7.43	7.69		92		82		24	0.01	0.01		27.3		5.8		14
19	7.42	7.67		98		76		30	0.01	0.01		27.3		7.3		14
20	7.54	7.73		102		80		36	0.01	0.00		26.5		8.7		14
21	7.54	7.72	104	104	80	82	36	38	0.01	0.00	26.5	27.3	8.7	9.2	13	14
22	7.55	7.71		102		82		34	0.01	0.03		27.3		8.3		13
23	7.51	7.68		102		80		34	0.01	0.01		27.3		7.3		13
24	7.48	7.68		100		80		32	0.01	0.01		27.3		7.8		13
25	7.53	7.71		106		84		40	0.02	0.00		26.5		9.7		13
26	7.56	7.75		104		84		38	0.01	0.00		26.7		9.2		14
27	7.45	7.70		102		80		36	0	0.01		26.5		8.7		13
28	7.41	7.57	100	100	78	80	34	34	0.02	0.01	26.5	26.5	8.3	8.3	14	13
29	7.50	7.65		102		80		36	0.01	0.00		26.5		8.7		13
30	7.48	7.71		100		82		32	0.01	0.01		27.3		7.8		14
31	7.44	7.69		100		82		34	0.01	0.02		26.5		8.3		14
AVG	7.51	7.69		102		82		34		0.01		27.2		8.3		14
MAX	7.57	7.75		106		88		40		0.03		28.1		9.7		16.0
MIN	7.41	7.57		92		76		24		0.00		25.7		5.8		13.0



WSSN 2310

Aug-18

D A T E	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1						2/0			0.23	16.5					
2						2/0			0.23	17.1					
3						2/0			0.23	17.5					
4						2/0			0.23	18.3					
5						2/0			0.23	18.1					
6						2/0			0.22	18.6					
7						2/0			0.23	18.7					
8						2/0			0.23	18.7					
9						2/0			0.23	18.8					
10						2/0			0.23	18.4					
11						2/0			0.23	17.8					
12						2/0			0.22	17.7					
13						2/0			0.22	17.6					
14						2/0			0.23	17.9					
15						2/0			0.23	18.2					
16						2/0			0.23	18.8					
17						2/0			0.28	19.3					
18						2/0			0.23	19.3					
19						2/0			0.23	19.3					
20						2/0			0.23	19.1					
21						2/0			0.23	18.9					
22						2/0			0.22	18.0					
23						2/0			0.23	18.1					
24						2/0			0.23	18.7					
25						2/0			0.22	18.6					
26						2/0			0.23	18.5					
27						2/0			0.23	18.4					
28						2/0			0.23	19.3					
29						2/0			0.23	19.9					
30						2/0			0.23	20.1					
31						2/0			0.23	20.0					
AVG									0.23	18.5					
MAX									0.28	20.1					
MIN									0.22	16.5					



Distribution System Monitoring WSSN 2310

Aug-18

DATE	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l																									Chlorine only sites mg/l					Number of Samples
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24	25	
1														1.27	1.11	1.52	1.61	0.77	1.10					1.67							8
2	1.37	1.23	1.36	1.36	1.51															0.66		1.68							1.24		8
3											1.20					1.46	1.53	0.98	1.09						1.13					0.83	7
4																															0
5																															0
6	1.25		1.39	1.24	1.69	1.32																	1.44			1.20					7
7							1.38	1.63	0.97	1.45		0.76	1.03								1.28						1.13				8
8														1.37	1.06	1.57	1.48	0.90	0.97					1.56				1.00			8
9	1.11	1.18	1.32	1.35	1.74															0.93		1.74							1.16		8
10											1.22				1.52	1.60	1.00	1.01							1.71						6
11																															0
12																															0
13	1.14	1.31	1.34	1.34	1.50	1.50																		1.55		1.15			1.19		9
14							1.33	1.59	1.04	1.57	1.18	1.30	0.78								1.30	1.71					1.01				10
15														1.47	1.18	1.44	1.55	0.84	1.07					1.54				1.31	0.89		9
16	1.12		1.33	1.04	1.74															1.12					1.62						6
17																															0
18																															0
19																															0
20	1.20		1.37	1.38	1.77	1.40																	1.49			1.14					7
21							1.29	1.64	0.85	1.56		0.61	0.77								1.27						1.05				8
22														1.45	1.00	1.34	1.58	1.05	1.00					1.48				1.36			8
23	0.92	1.20	1.18	1.25	1.85															0.96		1.69						1.24			8
24											1.18				1.50	1.52	1.15	0.97						1.64					0.99		7
25																															0
26																															0
27	1.16		1.37	1.35	1.77	1.28																	0.96			1.04					7
28							1.31	1.70	1.65	1.58		0.92	0.90								1.31						1.10				8
29														1.60	1.10	1.49	1.52	1.03	0.96					1.57				1.35			8
30	1.16	1.06	1.32	1.30	1.63															1.05		1.69							1.12		8
31											1.38					1.32	1.54	1.08	0.97						1.36					0.80	7
Monthly Cl₂ Avg.			1.31																												
Total Samples			148																												



Distribution System Monitoring

WSSN 2310

Aug-18

DATE	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l																														Chlorine only sites mg/l					Number of Samples		
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24	25								
1														1.49	1.37	1.68	1.86	0.92	1.27					1.92									8					
2	1.53	1.41	1.62	1.55	1.73															1.00			1.88						1.22			1.51			8			
3										1.41						1.67	1.79	1.19	1.33							1.35							0.93			7		
4																																				0		
5																																					0	
6	1.46		1.61	1.46	1.94	1.55																	1.62			1.41										7		
7						1.55	1.81	1.12	1.74		0.95	1.19									1.51						1.41		1.32							8		
8													1.58	1.30	1.73	1.66	1.10	1.17							1.76				1.22							8		
9	1.27	1.34	1.50	1.54	1.91															1.17			1.92									1.37				8		
10										1.49						1.72	1.82	1.18	1.22							1.93										6		
11																																					0	
12																																					0	
13	1.31	1.46	1.47	1.51	1.68	1.70																	1.67			1.33					1.35					9		
14							1.54	1.72	1.27	1.75	1.29	1.47	0.93								1.53	1.91					1.28									10		
15														1.69	1.37	1.63	1.79	0.99	1.24						1.72				1.40			1.06				9		
16	1.29		1.60	1.31	1.98																1.25					1.84										6		
17																																					0	
18																																					0	
19																																					0	
20	1.39		1.54	1.55	2.04	1.64																	1.73			1.32										7		
21							1.48	1.83	1.00	1.77		0.80	0.95								1.47						1.21									8		
22														1.71	1.22	1.60	1.78	1.22	1.17							1.73										8		
23	1.12	1.42	1.40	1.40	2.06															1.14			1.93									1.41				8		
24										1.36						1.69	1.67	1.34	1.13							1.88								1.16			7	
25																																					0	
26																																					0	
27	1.36		1.58	1.57	1.91	1.47																	1.18			1.25											7	
28							1.58	1.89	1.81	1.77		1.13	1.06								1.49						1.32										8	
29														1.79	1.27	1.66	1.74	1.19	1.03									1.53									8	
30	1.36	1.31	1.50	1.55	1.88															1.21			1.87										1.25				8	
31											1.57					1.51	1.81	1.23	1.19						1.55										0.95			7
Monthly Cl ₂ Avg.			1.50																																			
Total Samples			148																																			



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Aug-18

Total number of positive routine samples:				Total Coliform: <u>0</u>			E.coli Bacteria: <u>0</u>		Chlorine Residual (mg/L)	
Date	Monitoring Station	Total Coliform	E.coli Bacteria	Date	Time	Retest of Station, Upstream & Downstream	Total Coliform	E.coli Bacteria	Free	Total
Total number of routine distribution samples analyzed:				148						
Total number of routine distribution samples required:				100						