



Fluoridation & Chlorination WSSN 2310 Aug-20

D A T E	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
		Raw	Tap	Dist	Chlorine App. Mg/l	Chlorine (prior to filtration) mg/L OCl ⁻	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap					
											Free	Free	Free	Free	Free	
		14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1		0.99	0.81		1.13				0.9						1.8	
2		0.66	0.83		0.96				0.9						1.7	
3		0.67	0.70		1.16				0.9						1.6	
4		0.80	0.79		1.36				0.8						1.6	
5		0.78	0.79		1.56				0.8						1.7	
6		0.85	0.87		1.56				0.8						1.6	
7		0.62	0.62		1.50				0.9						1.6	
8		0.66	0.69		1.60				0.8						1.6	
9		0.63	0.68		1.64				0.8						1.7	
10		0.74	0.79		1.43				0.8						1.7	
11		0.75	0.80		1.39				0.8						1.6	
12		0.65	0.66		1.36				0.8						1.6	
13		0.78	0.88		1.51				0.8						1.7	
14		0.60	0.68		1.66				0.8						1.7	
15		0.73	0.82		1.68				0.8						1.7	
16		0.75	0.82		1.72				0.9						1.7	
17		0.65	0.65		1.49				0.9						1.7	
18		0.73	0.78		1.38				0.8						1.6	
19		0.67	0.68		1.39				0.8						1.7	
10		0.75	0.72		1.38				0.8						1.6	
21		0.73	0.76		1.36				0.8						1.7	
22		0.69	0.70		1.28				0.8						1.8	
23		0.70	0.76		1.14				0.9						1.8	
24		0.76	0.85		1.15				0.8						1.7	
25		0.52	0.68		1.20				0.9						1.7	
26		0.80	0.79		1.25				0.8						1.7	
27		0.73	0.71		1.31				0.8						1.7	
28		0.71	0.77		1.46				0.8						1.7	
29		0.72	0.80		1.42				0.9						1.8	
30		0.64	0.70		1.35				0.8						1.6	
31		0.70	0.73		1.39				0.8						1.7	
AVG			0.75		1.39				0.8						1.7	
MAX			0.88		1.72				0.9						1.8	
MIN			0.62		0.96				0.8						1.6	



Chemical Analyses WSSN 2310 Aug-20

D A T E	pH		Total Hardness as CaCO ₃ mg/l		Total Alkalinity as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l		Iron mg/L		Calcium Ca ²⁺ mg/l		Magnesium as Mg ²⁺ mg/l		Chloride as Cl ⁻ mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38.00	39	40	41	42	43	44
1	7.48	7.56		100		80		30	0.01	0.01		28.1		7.3		14
2	7.44	7.51		100		80		32	0.0	0.01		27.2		7.8		16
3	7.34	7.56		98		80		28	0.01	0.01		28.1		6.8		15
4	7.30	7.55	100	100	80	80	30	30	0.03	0.02	28.1	28.1	7.3	7.3	16	16
5	7.31	7.57		94		80		22	0.01	0.01		28.9		5.3		16
6	7.34	7.54		98		84		26	0	0.01		28.9		6.3		16
7	7.38	7.52		104		84		36	0.01	0.02		27.3		8.7		15
8	7.37	7.49		100		80		34	0.01	0.01		26.5		8.3		15
9	7.45	7.52		98		80		34	0.01	0.01		25.7		8.3		15
10	7.32	7.54		100		80		28	0.01	0.01		28.9		6.8		15
11	7.29	7.50	100	100	76	80	28	30	0.02	0.01	28.9	28.1	6.8	7.3	16	15
12	7.31	7.51		100		82		28	0.01	0.01		28.9		6.8		16
13	7.29	7.53		100		82		30	0	0.01		28.1		7.3		16
14	7.29	7.55		98		80		24	0.01	0.02		29.7		5.8		16
15	7.49	7.53		98		80		34	0.01	0.02		25.7		8.3		15
16	7.49	7.57		102		80		34	0.01	0.01		27.3		8.3		15
17	7.28	7.51		100		80		28	0.02	0.01		28.9		6.8		16
18	7.34	7.56	100	98	76	80	28	28	0.01	0.01	28.9	28.1	6.8	6.8	14	15
19	7.31	7.54		100		80		32	0.02	0.02		27.3		7.8		15
20	7.29	7.53		100		78		30	0.01	0.00		28.1		7.3		16
21	7.30	7.55		98		76		28	0	0.02		28.1		6.8		15
22	7.45	7.58		100		78		36	0.01	0.02		25.7		8.7		15
23	7.46	7.50		102		78		36	0	0.00		26.5		8.7		13
24	7.30	7.55		102		80		30	0.01	0.01		28.9		7.3		14
25	7.29	7.52	98	100	76	78	26	34	0.03	0.01	28.9	26.5	6.3	8.3	16	15
26	7.27	7.52		100		80		28	0.01	0.01		28.9		6.8		19
27	7.29	7.53		98		76		26	0.01	0.02		28.1		6.3		15
28	7.30	7.53		100		80		32	0.01	0.02		27.3		7.8		15
29	7.40	7.54		100		80		34	0	0.01		26.5		8.3		15
30	7.39	7.53		98		78		32	0	0.00		26.5		7.8		14
31	7.32	7.55		100		78		28	0.01	0.00		28.9		6.8		16
AVG	7.35	7.54		100		80		30		0.01		27.7		7.4		15
MAX	7.49	7.58		104		84		36		0.02		29.7		8.7		19.0
MIN	7.27	7.49		94		76		22		0.00		25.7		5.3		13.0



WSSN 2310

Aug-20

D A T E	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1						2/0			0.23	20.1					
2						2/0			0.23	19.7					
3						2/0			0.23	20.1					
4						2/0			0.23	19.2					
5						2/0			0.23	19.8					
6						2/0			0.23	20.2					
7						2/0			0.23	20.5					
8						2/0			0.23	21.3					
9						2/0			0.23	21.5					
10						2/0			0.23	21.2					
11						2/0			0.23	21.4					
12						2/0			0.23	21.4					
13						2/0			0.23	21.4					
14						2/0			0.23	21.4					
15						2/0			0.23	21.9					
16						2/0			0.23	21.9					
17						2/0			0.23	21.2					
18						2/0			0.23	21.1					
19						2/0			0.23	21.0					
20						2/0			0.23	21.1					
21						2/0			0.23	21.1					
22						2/0			0.22	20.8					
23						2/0			0.23	20.9					
24						2/0			0.23	20.9					
25						2/0			0.23	21.2					
26						2/0			0.23	21.3					
27						2/0			0.23	21.4					
28						2/0			0.23	21.6					
29						2/0			0.23	22.0					
30						2/0			0.23	22.0					
31						2/0			0.23	21.4					
AVG									0.23	21.0					
MAX									0.23	22.0					
MIN									0.22	19.2					



Distribution System Monitoring WSSN 2310

Aug-20

DATE	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l																														Chlorine only sites mg/l					Number of Samples
	1	2	3	4	CS	6	7	8	9	10	WR	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24	25						
1																																		0		
2																																		0		
3	1.19	1.51		1.19	1.46	1.20												0.77														0.89	8			
4								1.21	0.98	1.37	1.12	0.68	1.53								1.24												7			
5														1.41	0.81	1.32	1.56		1.15					1.42			0.75		1.57	1.13		9				
6	0.93			1.31	1.58						0.98										0.98		1.67			1.64							7			
7															1.27	1.50		1.34															3			
8																																		0		
9																																		0		
10	1.36	1.57		1.29		1.50	0.88											0.87													1.23		8			
11								1.36	0.94	1.33	1.42	0.83	0.82								1.24						0.97						8			
12														1.53	0.96	1.44	1.39		0.90					1.48		1.05		1.62	1.05			9				
13	0.77			1.31	1.60						0.64										0.89		1.24			1.41							7			
14															1.16	1.57		1.15															3			
15																																		0		
16																																		0		
17	0.67	1.07		1.32	1.37	1.44												0.98														0.76		8		
18								1.38	0.95	1.48	0.94	0.78	0.99								1.32						0.92						8			
19														1.34	0.84	1.28	1.61		1.08					1.52		1.06		1.60	0.96				9			
20	1.20			1.10	1.48						1.16										0.20		1.63			1.48							7			
21															1.34	1.48		1.21															3			
22																																		0		
23																																		0		
24	0.55	1.52		1.39	1.32	1.35												0.86						1.35								0.88		8		
25								1.29	0.81	1.01	1.25	0.63	1.63								0.56						1.04						8			
26														1.49	1.32	1.19	1.49		1.13					1.50		1.12		1.62	0.86				9			
27	1.00			1.29	1.57																0.83		1.63			1.61							6			
28											1.03		0.80			1.25	1.44		1.25															5		
29																																			0	
30																																			0	
31	0.68	1.23		1.11	1.56	1.03												0.79														0.49		8		
Monthly Cl₂ Avg.					1.20																															
Total Samples					128																															



Distribution System Monitoring

WSSN 2310

Aug-20

DATE	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l																														Chlorine only sites mg/l					Number of Samples
	1	2	3	4	CS	6	7	8	9	10	WR	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24	25						
1																															0					
2																															0					
3	1.31	1.68		1.50	1.83	1.35												1.03												1.04	8					
4								1.64	1.13	1.56	1.50	1.05	1.72								1.52										7					
5															1.52	1.01	1.46	1.65		1.47					1.55		1.00		1.95	1.25	9					
6	1.13			1.46	1.87						1.45										1.23			1.82					1.69		7					
7																1.37	1.67		1.46												3					
8																															0					
9																															0					
10	1.50	1.76		1.50	1.53	1.10																								1.54	8					
11								1.61	1.07	1.58	1.53	1.01	1.02																1.11		8					
12															1.68	1.07	1.56	1.51		1.16					1.66		1.21		1.75	1.28	9					
13	0.97			1.43	1.71						1.40																				7					
14																															3					
15																															0					
16																															0					
17	0.88	1.11		1.37	1.46	1.57																								0.98	8					
18								1.70	1.04	1.53	1.44	1.00	1.01																		8					
19															1.61	0.74	1.40	1.73		1.41							1.15		1.78	1.04	9					
20	1.42			1.46	1.76						1.53																				7					
21																	1.48	1.60		1.37											3					
22																															0					
23																															0					
24	0.81	1.73		1.56	1.74	1.47																								0.97	8					
25								1.61	1.01	1.06	1.48	0.85	1.84																		8					
26															1.62	1.56	1.47	1.61		1.30						1.26		1.72	0.96	9						
27	1.19			1.42	1.83																										6					
28											1.43		1.02			1.47	1.55		1.36												5					
29																															0					
30																															0					
31	0.94	1.69		1.40	1.75	1.35																								0.95	8					
Monthly Cl₂ Avg.				1.41																																
Total Samples				128																																

