



Fluoridation & Chlorination

WSSN 2310

Sep-18

D A T E	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
		Raw	Tap	Dist	Chlorine App. Mg/l	Chlorine (prior to filtration) mg/L OCl ⁻	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap					
											Free	Free	Free			
		14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1		0.68	0.68		1.17				0.8						1.6	
2		0.63	0.63		1.19				0.9						1.7	
3		0.67	0.64		1.11				0.9						1.8	
4		0.60	0.63		1.08				0.9						1.7	
5		0.71	0.73		1.32				0.9						1.7	
6		0.70	0.71		1.30				0.8						1.7	
7		0.66	0.64		1.35				0.9						1.7	
8		0.73	0.75		1.38				0.9						1.7	
9		0.71	0.70		1.27				0.9						1.7	
10		0.67	0.66		1.27				1.0						1.7	
11		0.64	0.64		1.25				1.0						1.7	
12		0.73	0.72		1.16				0.9						1.6	
13		0.74	0.75		1.20				0.9						1.7	
14		0.74	0.77		1.27				0.9						1.6	
15		0.64	0.62		1.29				0.9						1.6	
16		0.63	0.66		1.29				0.8						1.6	
17		0.72	0.74		1.26				0.9						1.9	
18		0.72	0.74		1.10				0.9						1.7	
19		0.72	0.74		1.15				0.8						1.6	
20		0.71	0.71		1.22				0.9						1.9	
21		0.72	0.74		1.19				0.8						1.5	
22		0.75	0.72		1.26				0.9						1.7	
23		0.73	0.73		1.19				0.9						1.7	
24		0.70	0.73		1.28				0.8						1.6	
25		0.73	0.73		1.27				0.9						1.7	
26		0.73	0.75		1.32				0.9						1.6	
27		0.73	0.73		1.18				0.9						1.7	
28		0.69	0.73		1.26				0.9						1.6	
29		0.77	0.80		1.25				0.9						1.7	
30		0.73	0.73		1.33				0.9						1.7	
AVG		0.69	0.71		1.24				0.9						1.7	
MAX		0.77	0.80		1.38				1.0						1.9	
MIN		0.60	0.62		1.08				0.8						1.5	



Chemical Analyses WSSN 2310 Sep-18

DATE	pH		Total Hardness as CaCO ₃ mg/l		Total Alkalinity as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l		Iron mg/L		Calcium Ca ²⁺ mg/l		Magnesium as Mg ²⁺ mg/l		Chloride as Cl ⁻ mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38.00	39	40	41	42	43	44
1	7.42	7.65		98		81		32	0.01	0.01		26.5		7.8		13
2	7.44	7.61		98		80		30	0.01	0.01		27.3		7.3		14
3	7.40	7.56		98		82		28	0.01	0.01		28.1		6.8		14
4	7.42	7.69	100	100	78	80	32	34	0.03	0.02	27.5	26.5	7.8	8.3	13	13
5	7.47	7.66		100		80		32	0.00	0.01		27.3		7.8		14
6	7.46	7.68		102		82		34	0.01	0.01		27.3		8.3		13
7	7.54	7.72		100		82		30	0.02	0.01		28.1		7.3		13
8	7.53	7.63		104		84		34	0.01	0.00		28.1		8.3		13
9	7.52	7.59		104		84		36	0.01	0.01		27.3		8.7		14
10	7.53	7.61		100		82		32	0.00	0.00		27.3		7.8		12
11	7.51	7.54	102	102	82	80	34	34	0.01	0.02	27.3	27.3	8.3	8.3	12	13
12	7.50	7.54		102		80		34	0.01	0.00		27.3		8.3		13
13	7.55	7.51		100		80		30	0.01	0.01		28.1		7.3		13
14	7.51	7.54		102		82		32	0.01	0.01		28.1		7.8		14
15	7.53	7.49		94		76		26	0.01	0.02		27.3		6.3		14
16	7.47	7.49		102		76		32	0.01	0.01		28.1		7.8		14
17	7.53	7.52		102		78		34	0.01	0.01		27.3		8.3		13
18	7.49	7.53	98	100	80	80	28	32	0.02	0.01	28.1	27.3	6.7	7.3	13	12
19	7.54	7.52		104		82		34	0.01	0.00		28.1		8.3		13
20	7.52	7.51		100		80		30	0.01	0.01		28.1		7.3		12
21	7.57	7.56		104		82		34	0.01	0.00		28.1		8.3		13
22	7.59	7.58		104		82		34	0	0.02		28.1		8.3		14
23	7.60	7.57		104		84		34	0	0.00		28.1		8.3		14
24	7.56	7.58		104		80		34	0.01	0.01		28.1		8.3		14
25	7.55	7.54	102	104	82	80	32	34	0.01	0.01	28.1	28.1	7.8	8.3	12	13
26	7.53	7.52		104		80		34	0.01	0.02		28.1		8.3		14
27	7.57	7.57		106		80		36	0.02	0.01		28.1		8.7		14
28	7.51	7.54		106		84		36	0.02	0.01		28.1		8.7		13
29	7.53	7.54		100		76		28	0.01	0.01		28.9		6.8		15
30	7.61	7.59		102		82		32	0.01	0.00		28.1		7.8		14
AVG	7.52	7.57		102		81		33		0.01		27.8		7.9		13
MAX	7.61	7.72		106		84		36		0.02		28.9		8.7		15.0
MIN	7.40	7.49		94		76		26		0.00		26.5		6.3		12.0



WSSN 2310

Sep-18

DATE	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1						2/0			0.23	20.5					
2						2/0			0.23	19.9					
3						2/0			0.22	18.9					
4						2/0			0.23	19.2					
5						2/0			0.23	20.0					
6						2/0			0.23	20.2					
7						2/0			0.22	19.1					
8						2/0			0.22	18.1					
9						2/0			0.22	17.2					
10						2/0			0.22	16.9					
11						2/0			0.22	16.1					
12						2/0			0.22	16.9					
13						2/0			0.22	18.3					
14						2/0			0.22	19.0					
15						2/0			0.22	19.4					
16						2/0			0.22	20.3					
17						2/0			0.22	19.3					
18						2/0			0.22	19.2					
19						2/0			0.22	19.0					
20						2/0			0.22	19.1					
21						2/0			0.22	18.0					
22						2/0			0.22	17.2					
23						2/0			0.22	17.0					
24						2/0			0.22	17.4					
25						2/0			0.22	18.0					
26						2/0			0.22	18.3					
27						2/0			0.22	18.2					
28						2/0			0.22	18.3					
29						2/0			0.22	19.3					
30						2/0			0.22	18.0					
AVG									0.22	18.5					
MAX									0.23	20.5					
MIN									0.22	16.1					



Distribution System Monitoring WSSN 2310

Sep-18

DATE	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l																								Chlorine only sites mg/l					Number of Samples	
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24		25
1																															0
2																															0
3																															0
4	1.17				1.76		1.42	1.51	1.56	1.50		1.28	0.84								1.25					1.21	1.08			11	
5				1.35										1.50	1.06	1.41	1.55	0.80	0.81					1.49				1.43		9	
6	1.01	1.12	0.97		1.81															0.78		1.60	0.87							7	
7											1.37				1.26	1.51	0.99	0.90							1.60				0.89	7	
8																														0	
9																														0	
10	1.36	1.11	1.30	1.32	1.95	1.42																		1.01		1.20				8	
11							1.35	1.67	1.56	1.51		0.71	0.81								0.41						1.23			8	
12														1.48	1.17	1.47	1.40	0.97	1.05					1.51				1.41		8	
13	1.19	1.12	1.33	1.34	1.92															0.89		1.62						1.12		8	
14											1.35				1.42	1.53	1.07	1.11							1.63				0.91	7	
15																														0	
16																														0	
17	0.98	1.12		1.24	1.46	1.58																		1.54		1.16				7	
18							1.20	1.54	1.60	1.51		0.96	0.90								0.97						1.08			8	
19														1.54	1.01	1.39	1.44	0.99	1.13					1.34				1.36		8	
20																														0	
21			1.33		1.83						1.26				1.47	1.54	1.07	1.16							1.45				0.88	9	
22																														0	
23																														0	
24	1.04	1.16	1.28	1.29	1.95	1.40																		0.79		1.07				8	
25							1.21	1.23	0.78	1.41		0.92	0.65								0.94						1.00			8	
26														1.56		1.38	1.47	1.03	1.10					1.62				1.42		7	
27	1.11	0.98	1.32	1.26	1.87															0.73		1.65						1.29		8	
28											1.28					1.38	1.50	1.04	1.11						1.56					6	
29																														0	
30																														0	
	Monthly Cl₂ Avg.				1.28																										
	Total Samples				125																										



Distribution System Monitoring

WSSN 2310

Sep-18

DATE	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l																									Chlorine only sites mg/l					Number of Samples
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	26	27	28	29	30	21	22	23	24	25	
1																															0
2																															0
3																															0
4	1.37				1.93		1.60	1.70	1.78	1.69		1.51	0.97								1.36					1.30	1.25			11	
5				1.53										1.72	1.22	1.60	1.70	1.00	0.98				1.74							9	
6	1.13	1.27	1.11		1.99															0.97		1.73	1.05							7	
7										1.57					1.53	1.68	1.16	1.19							1.77				1.01	7	
8																														0	
9																														0	
10	1.55	1.29	1.50	1.51	2.18	1.63																	1.16			1.34				8	
11							1.56	1.84	1.75	1.70		0.87	1.03								0.57						1.40			8	
12														1.72	1.31	1.74	1.68	1.14	1.26				1.73					1.63		8	
13	1.34	1.27	1.43	1.48	2.12															1.16		1.81						1.25		8	
14										1.56					1.56	1.71	1.22	1.32							1.78				1.03	7	
15																														0	
16																														0	
17	1.13	1.36		1.41	1.85	1.74																	1.65			1.27				7	
18							1.40	1.78	1.88	1.70		1.11	1.06								1.25						1.26			8	
19														1.68	1.22	1.59	1.57	1.14	1.27				1.70					1.50		8	
20																														0	
21			1.47		2.07					1.49						1.67	1.76	1.26	1.34						1.61				1.08	9	
22																														0	
23																														0	
24	1.23	1.27	1.47	1.44	2.10	1.62																	0.97			1.21				8	
25							1.39	1.77	0.99	1.64		1.10	0.80								1.13						1.15			8	
26														1.77		1.61	1.77	1.22	1.32				1.83					1.58		7	
27	1.27	1.37	1.48	1.49	2.08											1.61	1.72	1.22	1.31	0.93		1.90						1.50		8	
28										1.52						1.61	1.72	1.22	1.31						1.80					6	
29																														0	
30																														0	
	Monthly Cl₂ Avg.				1.47																										
	Total Samples				125																										

