





**Fluoridation & Chlorination**

**WSSN 2310**

**Oct-19**

D A T E	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
		Raw	Tap	Dist	Chlorine App. Mg/l	Chlorine (prior to filtration) mg/L OCl <sup>-</sup>	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap					
								Free	Free	Free	Free					
		14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1		0.66	0.65		1.16				0.9						1.7	
2		0.65	0.65		1.07				1.0						1.7	
3		0.58	0.58		1.11				0.9						1.7	
4		0.60	0.59		1.15				1.0						1.7	
5		0.59	0.59		1.20				0.9						1.7	
6		0.56	0.57		1.25				0.9						1.6	
7		0.54	0.55		1.25				0.9						1.7	
8		0.55	0.55		1.15				0.9						1.7	
9		0.62	0.63		1.06				0.9						1.7	
10																
11																
12																
13																
14																
15																
16																
17																
18																
19																
20																
21																
22																
23																
24																
25																
26																
27																
28																
29																
30																
31																
AVG			0.59		1.16				0.9						1.7	
MAX			0.65		1.25				1.0						1.7	
MIN			0.55		1.06				0.9						1.6	



**Chemical Analyses                      WSSN 2310                      Oct-19**

D A T E	pH		Total Hardness as CaCO <sub>3</sub> mg/l		Total Alkalinity as CaCO <sub>3</sub> mg/l		NonCarbonate Hardness as CaCO <sub>3</sub> mg/l		Iron mg/L		Calcium Ca <sup>2+</sup> mg/l		Magnesium as Mg <sup>2+</sup> mg/l		Chloride as Cl <sup>-</sup> mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38.00	39	40	41	42	43	44
1	7.25	7.55	102	100	80	82	32	30	0.04	0.02	28.1	28.1	7.8	7.3	15	17
2	7.30	7.53		100		86		32	0.0	0.02		27.3		7.8		15
3	7.53	7.59		102		84		34	0.03	0.02		27.3		8.3		15
4	7.45	7.55		104		86		34	0.01	0.00		28.1		8.3		16
5	7.51	7.59		106		84		36	0	0.09		28.1		8.7		15
6	7.51	7.56		106		84		36	0.03	0.01		28.1		8.7		15
7	7.32	7.46		104		84		34	0.02	0.01		28.1		8.3		16
8	7.46	7.47	102	102	80	84	32	34	0.02	0.00	28.1	27.3	7.8	8.3	14	15
9	7.54	7.56		102		80		32	0.01	0.02		28.1		7.8		15
10																
11																
12																
13																
14																
15																
16																
17																
18																
19																
20																
21																
22																
23																
24																
25																
26																
27																
28																
29																
30																
31																
AVG	7.43	7.54		103		84		34		0.02		27.8		8.2		15
MAX	7.54	7.59		106		86		36		0.09		28.1		8.7		17.0
MIN	7.25	7.46		100		80		30		0.00		27.3		7.3		15.0



WSSN 2310

Oct-19

D A T E	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1						2/0			0.23	15.4					
2						2/0			0.23	15.5					
3						2/0			0.23	15.8					
4						2/0			0.23	15.3					
5						2/0			0.23	15.0					
6						2/0			0.23	15.8					
7						2/0			0.23	15.4					
8						2/0			0.23	15.1					
9						2/0			0.23	15.4					
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															
31															
AVG									0.23	15.4					
MAX									0.23	15.8					
MIN									0.23	15.0					





