



Fluoridation & Chlorination

WSSN 2310

Oct-16

DATE	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
					Chlorine App. Mg/l	Chlorine (prior to filtration) mg/L OCl ⁻	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap					
		Free	Free	Free				Free								
		Raw	Tap	Dist	18	19	20	21	22	23	24	25	26	27	28	
1			0.81		1.14				0.8						1.7	
2			0.83		1.16				0.7						1.7	
3			0.87		1.13				0.7						1.7	
4			0.83		1.13				0.6						1.7	
5			0.82		1.12				0.6						1.7	
6			0.83		1.14				0.7						1.7	
7			0.81		1.12				0.7						1.7	
8			0.81		1.15				0.8						1.8	
9			0.80		1.21				0.6						1.8	
10			0.81		1.24				0.7						1.6	
11			0.84		1.20				0.8						1.5	
12			0.85		1.17				0.7						1.6	
13			0.87		1.17				0.7						1.6	
14			0.83		1.22				0.8						1.7	
15			0.86		1.18				0.7						1.8	
16			0.86		1.15				0.8						1.7	
17			0.89		1.14				0.8						1.3	
18			0.86		1.15				0.7						1.6	
19			0.79		1.17				0.7						1.7	
20			0.77		1.16				0.7						1.7	
21			0.73		1.14				0.8						1.3	
22			0.73		1.15				0.8						1.8	
23			0.76		1.13				0.8						1.7	
24			0.74		1.15				0.7						1.7	
25			0.75		1.10				0.8						1.7	
26																
27																
28																
29																
30																
31																
AVG			0.81		1.16				0.7						1.7	
MAX			0.89		1.24				0.8						1.8	
MIN			0.73		1.10				0.6						1.3	



Chemical Analyses

WSSN 2310

Oct-16

D A T E	pH		Total Hardness as CaCO ₃ mg/l		Total Alkalinity as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l		Iron mg/L		Calcium Ca ²⁺ mg/l		Magnesium as Mg ²⁺ mg/l		Chloride as Cl ⁻ mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1	7.37	7.46		100		70		30		0.01		34.5		3.4		13
2	7.38	7.30		98		72		26		0.01		34.5		2.9		12
3	7.42	7.29		100		70		30		0.01		34.5		3.4		13
4	7.49	7.26		100		70		30		0.02		33.7		3.9		13
5	7.40	7.25		98		72		26		0.01		33.7		3.4		13
6	7.26	7.49		100		70		30		0.01		34.5		3.4		13
7	7.34	7.28		100		68		32		0.01		35.3		2.9		13
8	7.40	7.31		100		72		28		0.01		34.5		3.4		13
9	7.44	7.29		98		72		26		0		33.7		3.4		12
10	7.40	7.38		98		72		26		0.01		32.9		3.9		12
11	7.40	7.32		100		72		28		0.01		34.5		3.4		12
12	7.52	7.30		98		68		30		0.01		33.7		3.4		12
13	7.40	7.26		98		68		30		0.01		32.1		4.4		12
14	7.41	7.30		100		70		30		0.01		34.5		3.4		12
15	7.41	7.31		100		72		28		0.01		35.3		2.9		12
16	7.40	7.32		100		70		30		0.01		34.5		3.4		13
17	7.56	7.33		96		70		26		0		32.1		3.9		13
18	7.42	7.29		98		70		28		0.02		34.5		2.9		12
19	7.45	7.32		98		72		26		0.01		32.9		3.9		13
20	7.41	7.30		98		70		28		0.02		32.1		4.4		13
21	7.41	7.34		98		70		28		0.01		33.7		3.4		12
22	7.39	7.27		98		70		28		0.01		34.5		2.9		13
23	7.41	7.30		100		74		26		0.01		26.5		6.5		14
24	7.44	7.29		100		70		30		0.01		34.5		3.4		13
25	7.41	7.28		100		68		32		0.01		35.3		2.9		13
26																
27																
28																
29																
30																
31																
AVG	7.41	7.31		99		70		28		0.01		33.7		3.6		13
MAX	7.56	7.49		100		74		32		0.02		35.3		6.5		14.0
MIN	7.26	7.25		96		68		26		0.00		26.5		2.9		12.0



WSSN 2310

Oct-16

D A T E	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1					2 / 0	2 / 0			0.21	15.6					
2					2 / 0	2 / 0			0.21	15.7					
3					2 / 0	2 / 0			0.20	17.6					
4					2 / 0	2 / 0		<2	0.21	17.2					
5					2 / 0	2 / 0			0.21	15.2					
6					2 / 0	2 / 0			0.21	14.5					
7					2 / 0	2 / 0			0.21	14.3					
8					2 / 0	2 / 0			0.20	14.1					
9					2 / 0	2 / 0			0.21	13.6					
10					2 / 0	2 / 0			0.20	13.5					
11					2 / 0	2 / 0		<2	0.21	13.4					
12					2 / 0	2 / 0			0.20	13.4					
13					2 / 0	2 / 0			0.21	14.1					
14					1 / 0	2 / 0			0.21	14.4					
15					2 / 0	2 / 0			0.21	15.5					
16					2 / 0	2 / 0			0.21	15.2					
17					2 / 0	2 / 0			0.20	15.2					
18					2 / 0	2 / 0		<2	0.21	15.9					
19					2 / 0	2 / 0			0.21	15.3					
20					2 / 0	2 / 0			0.21	14.1					
21					2 / 0	2 / 0			0.21	14.2					
22					2 / 0	2 / 0			0.21	14.4					
23					2 / 0	2 / 0			0.20	14.0					
24					2 / 0	2 / 0			0.21	14.0					
25									0.21	14.6					
26															
27															
28															
29															
30															
31															
AVG									0.21	14.8					
MAX									0.21	17.6					
MIN									0.20	13.4					



Distribution System Monitoring WSSN 2310 Oct-16

D A T E	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR	Number of Samples
1											0
2											0
3											0
4	1.50	1.04	1.32	0.95	1.24	0.67	1.27	1.24	1.12	1.38	10
5	1.21	1.32	1.46	0.98	0.95	0.81	1.29	1.52	1.28	1.48	10
6	1.57	1.19	1.37	1.10	1.08	0.88	1.09	1.48	1.04	1.41	10
7											0
8											0
9											10
10											0
11	1.40	1.33	1.37	1.25	1.05	0.84	1.41	1.41	1.35	1.30	10
12	1.31	1.25	1.26	1.06	0.98	0.62	1.29	1.37	1.27	1.20	10
13	1.43	1.27	1.42	1.17	0.97	0.80	1.22	1.44	1.02	1.29	10
14											0
15											0
16											0
17											0
18	1.49	1.37	1.38	1.17	1.08	0.64	1.32	1.30	1.09	1.29	10
19	1.48	1.36	1.40	1.24	1.12	0.70	1.36	1.54	1.62	1.43	10
20	1.47	1.46	1.44	1.24	1.14	0.68	1.40	1.52	1.51	1.47	10
21											0
22											0
23											0
24											0
25	1.49	1.47	1.51	1.34	1.10	0.61	1.54	1.36	1.20	1.52	10
26											0
27											0
28											0
29											0
30											10
31											0
Monthly Cl₂ Avg.				1.244							
Total Samples				100							



Distribution System Monitoring WSSN 2310 Oct-16

D A T E	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR	Number of Samples
1											0
2											0
3											0
4	1.65	1.28	1.59	1.24	1.37	0.90	1.40	1.60	1.50	1.66	10
5	1.47	1.53	1.62	1.35	1.23	0.97	1.43	1.62	1.51	1.58	10
6	1.70	1.55	1.53	1.35	1.32	1.01	1.35	1.61	1.32	1.55	10
7											0
8											0
9											0
10											0
11	1.65	1.51	1.52	1.40	1.25	0.95	1.65	1.64	1.59	1.56	10
12	1.63	1.47	1.57	1.34	1.18	0.77	1.55	1.60	1.37	1.43	10
13	1.72	1.55	1.59	1.38	1.20	1.02	1.60	1.67	1.32	1.63	10
14											0
15											0
16											0
17											0
18	1.72	1.60	1.54	1.38	1.42	0.85	1.52	1.41	1.27	1.49	10
19	1.63	1.59	1.54	1.30	1.31	0.90	1.45	1.67	1.84	1.58	10
20	1.71	1.62	1.53	1.42	1.31	0.95	1.57	1.69	1.78	1.62	10
21											0
22											0
23											0
24											0
25	1.75	1.63	1.69	1.47	1.41	0.78	1.71	1.61	1.47	1.78	10
26											0
27											0
28											0
29											0
30											10
31											0
Monthly Cl₂ Avg.				1.456							
Total Samples				110							



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Oct-16

Total number of positive routine samples:				Total Coliform: <u>0</u>			E.coli Bacteria: <u>0</u>		Chlorine Residual (mg/L)	
Date	Monitoring Station	Total Coliform	E.coli Bacteria	Date	Time	Retest of Station, Upstream & Downstream	Total Coliform	E.coli Bacteria	Free	Total
Total number of routine distribution samples analyzed:				100						
Total number of routine distribution samples required:				100						