





**Fluoridation & Chlorination**

**WSSN 2310**

**Dec-16**

D A T E	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
					Chlorine App. Mg/l	Chlorine (prior to filtration) mg/L OCl <sup>-</sup>	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap					
		Free	Free	Free				Free								
		14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.79		1.11				0.8						1.7	
2			0.79		1.06				0.9						1.6	
3			0.81		1.07				0.7						1.8	
4			0.77		1.10				0.9						1.7	
5			0.78		1.12				0.9						1.8	
6			0.73		1.11				0.9						1.6	
7			0.77		1.04				0.8						1.7	
8																
9																
10																
11																
12																
13																
14																
15																
16																
17																
18																
19																
20																
21																
22																
23																
24																
25																
26																
27																
28																
29																
30																
31																
AVG			0.78		1.09				0.8						1.7	
MAX			0.81		1.12				0.9						1.8	
MIN			0.73		1.04				0.7						1.6	



**Chemical Analyses**

**WSSN 2310**

**Dec-16**

D A T E	pH		Total Hardness as CaCO <sub>3</sub> mg/l		Total Alkalinity as CaCO <sub>3</sub> mg/l		NonCarbonate Hardness as CaCO <sub>3</sub> mg/l		Iron mg/L		Calcium Ca <sup>2+</sup> mg/l		Magnesium as Mg <sup>2+</sup> mg/l		Chloride as Cl <sup>-</sup> mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1	7.38	7.36		100		70		30		0.01		32.9		4.4		13
2	7.38	7.28		100		68		32		0.01		32.9		4.4		13
3	7.33	7.25		98		70		28		0.01		32.1		4.4		12
4	7.40	7.27		98		70		28		0.01		32.1		4.4		12
5	7.39	7.34		96		70		26		0.01		35.3		1.9		12
6	7.34	7.31		96		68		28		0.01		32.1		3.4		12
7	7.36	7.29		96		70		26		0.01		30.5		4.9		13
8																
9																
10																
11																
12																
13																
14																
15																
16																
17																
18																
19																
20																
21																
22																
23																
24																
25																
26																
27																
28																
29																
30																
31																
AVG	7.37	7.30		98		69		28		0.01		32.6		4.0		12
MAX	7.40	7.36		100		70		32		0.01		35.3		4.9		13.0
MIN	7.33	7.25		96		68		26		0.01		30.5		1.9		12.0



**WSSN 2310**

**Dec-16**

D A T E	Total Coliform						Standard Plate Count	Conductivity (mS)	Temp deg.C	Color		Odor			
	Plant Tap									Raw	Tap	Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65				66	67	68	69	71	72
1					2 / 0	2 / 0			0.21	12.9					
2					2 / 0	2 / 0			0.20	13.0					
3					2 / 0	2 / 0			0.20	12.9					
4					2 / 0	2 / 0			0.21	12.9					
5					2 / 0	2 / 0			0.21	12.5					
6					2 / 0	2 / 0			0.20	12.7					
7									0.21	12.5					
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															
31															
AVG									0.21	12.8					
MAX									0.21	13.0					
MIN									0.20	12.5					



**Distribution System Monitoring      WSSN 2310      Dec-16**

D A T E	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR*	Number of Samples
1	1.65	1.44	1.54	1.33	1.13	0.46	1.57	1.62	1.19	0.83	10
2											0
3											0
4											0
5											0
6	1.56	1.42	1.41	1.32	1.04	0.48	1.33	1.35	1.62	1.27	10
7	1.57	1.52	1.37	1.29	1.18	0.53	1.42	1.52	1.54	1.16	10
8											0
9											10
10											0
11											0
12											0
13											0
14											0
15											0
16											0
17											0
18											0
19											0
20											0
21											0
22											0
23											0
24											0
25											0
26											0
27											0
28											0
29											0
30											10
31											0
<b>Monthly Cl<sub>2</sub> Avg.</b>				<b>1.289</b>		<div style="border: 1px solid black; padding: 5px;">           *Midway Market is being used in lieu of West Side Reservoir until further notice (11/15/2016)         </div>					
<b>Total Samples</b>				<b>30</b>							



**Distribution System Monitoring      WSSN 2310      Dec-16**

D A T E	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR*	Number of Samples
1	1.83	1.59	1.66	1.53	1.30	0.61	1.80	1.75	1.32	0.92	10
2											0
3											0
4											0
5											0
6	1.68	1.62	1.69	1.51	1.33	0.63	1.50	1.60	1.80	1.40	10
7	1.77	1.65	1.56	1.41	1.35	0.73	1.69	1.72	1.74	1.31	10
8											0
9											0
10											0
11											0
12											0
13											0
14											0
15											0
16											0
17											0
18											0
19											0
20											0
21											0
22											0
23											0
24											0
25											0
26											0
27											0
28											0
29											0
30											10
31											0
<b>Monthly Cl<sub>2</sub> Avg.</b>				<b>1.467</b>		<div style="border: 1px solid black; padding: 5px;">           *Midway Market is being used in lieu of West Side Reservoir until further notice (11/15/2016)         </div>					
<b>Total Samples</b>				<b>40</b>							



**ROUTINE POSITIVE DISTRIBUTION SAMPLES**

**Dec-16**

Total number of positive routine samples:				Total Coliform: <u>0</u>			E.coli Bacteria: <u>0</u>		Chlorine Residual (mg/L)	
Date	Monitoring Station	Total Coliform	E.coli Bacteria	Date	Time	Retest of Station, Upstream & Downstream	Total Coliform	E.coli Bacteria	Free	Total
Total number of routine distribution samples analyzed:				<b>30</b>						
Total number of routine distribution samples required:				<b>100</b>						