



Fluoridation & Chlorination

WSSN 2310

Jul-16

D A T E	Fluoride Applied F ⁻ mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
					Chlori ne App. Mg/l	Chlorine (prior to filtration) mg/L OCI	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap					
		Raw	Tap	Dist							Free	Free	Free	Free	Free	
		14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.80		0.43				0.7						1.0	
2			0.71		0.68				0.8						1.2	
3			0.69		0.69				0.8						1.2	
4			0.74		0.69				0.8						1.2	
5			0.73		0.69				0.8						0.9	
6			0.72		0.69				0.8						1.3	
7			0.73		0.70				0.7						1.4	
8			0.74		0.70				0.8						1.3	
9			0.74		0.70				0.8						1.3	
10			0.75		0.70				0.8						1.3	
11			0.75		0.69				0.8						1.3	
12			0.77		0.70				0.8						1.2	
13			0.78		0.70				0.7						1.3	
14			0.77		0.69				0.7						1.3	
15			0.87		0.75				0.7						1.2	
16			0.84		0.89				0.7						1.4	
17			0.82		0.94				0.8						1.4	
18			0.84		1.16				0.8						1.6	
19			0.85		1.12				0.7						1.6	
20			0.84		1.12				0.7						1.4	
21			0.82		1.11				0.7						1.5	
22			0.85		1.12				0.8						1.7	
23			0.88		1.11				0.7						1.6	
24			0.88		1.12				0.8						1.6	
25			0.86		1.11				0.8						1.6	
26			0.86		1.11				0.8						1.6	
27			0.78						0.7						1.7	
28																
29																
30																
31																
AVG			0.79		0.85				0.8						1.4	
MAX			0.88		1.16				0.8						1.7	
MIN			0.69		0.43				0.7						0.9	



Chemical Analyses

WSSN 2310

Jul-16

D A T E	pH		Total Hardness as CaCO ₃ mg/l		Total Alkalinity as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l		Iron mg/L		Calcium Ca ²⁺ mg/l		Magnesium as Mg ²⁺ mg/l		Chloride as Cl ⁻ mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1	7.44	7.39		102		74		28		0.02		29.7		6.8		12
2	7.48	7.39		102		74		28		0.02		33.7		3.9		12
3	7.44	7.30		102		76		26		0.02		32.9		4.9		13
4	7.41	7.30		102		76		26		0.02		30.5		6.3		13
5	7.41	7.31		98		74		24		0.03		33.7		3.4		13
6	7.41	7.35		100		74		26		0.01		33.7		3.9		13
7	7.45	7.31		100		74		26		0.02		33.7		3.9		13
8	7.49	7.38		100		74		26		0.02		29.7		6.3		13
9	7.49	7.40		102		74		28		0.02		32.9		4.9		12
10	7.47	7.34		100		74		26		0.02		33.7		3.9		13
11	7.47	7.32		102		74		28		0.03		34.5		3.9		13
12	7.33	7.32		104		72		32		0.02		33.7		4.9		13
13	7.45	7.33		102		72		30		0.02		34.5		3.9		13
14	7.44	7.33		104		72		32		0.02		32.9		5.3		13
15	7.47	7.32		102		72		30		0.02		34.5		3.9		13
16	7.45	7.35		102		72		30		0.01		34.5		3.9		13
17	7.45	7.33		102		72		30		0.03		32.9		4.9		13
18	7.43	7.33		102		74		28		0.01		36.1		2.9		14
19	7.42	7.34		102		74		28		0.02		32.9		2.9		14
20	7.46	7.34		98		72		26		0.01		36.1		1.9		13
21	7.47	7.34		102		68		34		0.02		36.9		2.4		13
22	7.46	7.40		102		72		30		0.02		35.3		3.4		13
23	7.46	7.37		102		72		30		0.01		32.9		4.9		13
24	7.45	7.36		100		72		28		0.02		32.9		4.4		13
25	7.44	7.35		102		72		30		0.02		32.9		4.9		13
26	7.43	7.34		102		70		32		0.01		32.9		4.9		13
27	7.45	7.41		98		72		26		0.01		33.7		3.4		13
28								0								
29								0								
30								0								
31								0								
AVG	7.45	7.35		101		73		25		0.02		33.5		4.3		13
MAX	7.49	7.41		104		76		34		0.03		36.9		6.8		14.0
MIN	7.33	7.30		98		68		0		0.01		29.7		1.9		12.0



WSSN 2310

Jul-16

D A T E	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1					2 / 0	2 / 0			0.21	16.9					
2					2 / 0	2 / 0			0.21	18.2					
3					2 / 0	2 / 0			0.21	18.3					
4					2 / 0	2 / 0			0.21	18.1					
5					2 / 0	2 / 0			0.21	18.8					
6					2 / 0	2 / 0			0.21	18.4					
7					2 / 0	2 / 0			0.21	18.4					
8					2 / 0	2 / 0			0.21	18.3					
9					2 / 0	2 / 0			0.21	18.2					
10					2 / 0	2 / 0			0.21	18.4					
11					2 / 0	2 / 0			0.21	18.0					
12					2 / 0	2 / 0			0.21	18.9					
13					2 / 0	2 / 0			0.21	19.0					
14					2 / 0	2 / 0			0.21	19.2					
15					2 / 0	2 / 0			0.21	19.4					
16					2 / 0	2 / 0			0.21	19.2					
17					2 / 0	2 / 0			0.21	18.7					
18					2 / 0	2 / 0			0.21	18.2					
19					2 / 0	2 / 0			0.21	18.9					
20					2 / 0	2 / 0			0.21	18.9					
21					2 / 0	2 / 0			0.21	18.5					
22					2 / 0	2 / 0			0.21	19.1					
23					2 / 0	2 / 0			0.21	19.2					
24					2 / 0	2 / 0			0.21	18.8					
25					2 / 0	2 / 0			0.21	18.5					
26					2 / 0	2 / 0			0.21	18.5					
27									0.21	18.9					
28															
29															
30															
31															
AVG									0.21	18.6					
MAX									0.21	19.4					
MIN									0.21	16.9					



Distribution System Monitoring WSSN 2310 Jul-16

DATE	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR	Number of Samples
1											0
2											0
3											0
4											0
5	1.00	1.03	1.05	0.84	0.75	0.26	1.04	1.22	0.84	0.98	10
6	1.18	0.99	0.98	0.75	0.65	0.27	0.97	1.03	0.78	1.06	10
7	1.16	1.06	0.98	0.77	0.68	0.34	0.92	1.18	0.83	1.02	10
8											0
9											0
10											0
11											0
12	1.17	0.81	1.01	0.82	0.83	0.42	0.94	1.14	0.95	1.21	10
13	1.17	1.08	1.04	0.86	0.71	0.26	0.91	1.07	0.83	1.16	10
14	1.02	0.93	1.01	0.80	0.73	0.30	0.88	1.03	1.65	1.04	10
15											0
16											0
17											0
18											0
19	1.30	1.16	1.29	1.04	0.92	0.27	1.10	1.34	0.94	1.51	10
20	1.35	1.07	1.13	1.04	0.90	0.23	1.14	1.32	1.18	1.29	10
21	0.96	1.15	1.38	1.16	0.97	0.29	1.16	1.36	1.14	1.31	10
22											0
23											0
24											0
25											0
26	1.33	1.19	1.32	1.14	0.97	0.30	1.16	1.32	1.41	1.41	10
27	1.34	1.39	1.19	1.08	1.01	0.29	0.96	1.53	1.10	1.63	10
28											0
29											0
30											0
31											0
Monthly Cl₂ Avg.				0.999							
Total Samples				110							



Distribution System Monitoring WSSN 2310 Jul-16

DATE	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR	Number of Samples
1											0
2											0
3											0
4											0
5	1.38	1.22	1.16	0.97	0.84	0.38	1.14	1.34	0.94	1.22	10
6	1.34	1.16	1.21	0.95	0.82	0.41	1.04	1.18	0.92	1.22	10
7	1.27	1.19	1.22	0.86	0.82	0.41	1.02	1.39	0.90	1.24	10
8											0
9											0
10											0
11											0
12	1.30	0.95	1.06	0.98	0.90	0.54	1.05	1.12	1.05	1.35	10
13	1.24	1.15	1.22	0.98	0.92	0.41	1.00	1.24	1.00	1.33	10
14	1.29	1.15	1.15	1.00	0.92	0.38	1.04	1.19	1.77	1.21	10
15											0
16											0
17											0
18											0
19	1.38	1.27	1.36	1.23	1.03	0.39	1.24	1.50	1.14	1.68	10
20	1.50	1.22	1.33	1.24	1.02	0.30	1.21	1.54	1.37	1.39	10
21	1.53	1.21	1.47	1.35	1.11	0.39	1.34	1.58	1.27	1.41	10
22											0
23											0
24											0
25											0
26	1.48	1.22	1.48	1.29	1.10	0.38	1.27	1.56	1.51	1.57	10
27	1.59	1.53	1.50	1.34	1.11	0.34	1.19	1.66	1.31	1.76	10
28											0
29											0
30											0
31											0
Monthly Cl₂ Avg.				1.148							
Total Samples				110							



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Jul-16

Total number of positive routine samples:				Total Coliform: <u>0</u>			E.coli Bacteria: <u>0</u>		Chlorine Residual (mg/L)	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Time	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform	Free	Total
Total number of routine distribution samples analyzed:				110						
Total number of routine distribution samples required:				100						