





**Flouridation & Chlorination**

**WSSN 2310**

**Feb-16**

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l						
					Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap				
		Free	Free	Free						Free	Free			
		Raw	Tap	Dist										
14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1		0.75						1.1					1.0	
2		0.74						1.0					1.0	
3		0.73						0.9					0.9	
4		0.74						1.0					0.9	
5		0.72						0.9					0.9	
6		0.69						1.0					1.0	
7		0.68						1.0					1.0	
8		0.68						1.0					1.0	
9		0.68						1.0					0.9	
10		0.70						1.0					1.0	
11		0.68						0.9					0.9	
12		0.68						0.9					0.1	
13		0.68						0.9					0.9	
14		0.65						1.0					0.8	
15		0.72						1.0					0.9	
16		0.67						0.9					0.9	
17		0.68						0.9					0.9	
18		0.67						0.9					0.8	
19		0.66						1.0					0.9	
20		0.66						1.0					1.0	
21		0.67						1.1					1.1	
22		0.71						1.1					1.0	
23		0.73						1.1					1.1	
24		0.72						0.9					0.9	
25		0.73						0.9					0.9	
26		0.68						1.0					1.0	
27		0.69						1.0					1.0	
28		0.69						1.1					0.9	
29		0.67						1.0					1.0	
AVG		0.69						1.0					0.9	
MAX		0.75						1.1					1.1	
MIN		0.65						0.9					0.1	



**Chemical Analyses**

**WSSN 2310**

**Feb-16**

D A T E	pH		Total Hard as CaCO <sub>3</sub> mg/l		Total Alk as CaCO <sub>3</sub> mg/l		NonCarbonate Hardness as CaCO <sub>3</sub> mg/l		Iron mg/L		Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1	7.27	7.39		104		74		30		0.05		31.3		6.3		12
2	7.39	7.28		102		70		32		0.02		34.5		3.9		15
3	7.28	7.22		100		72		28		0.02		36.9		1.5		15
4	7.38	7.24		102		70		32		0.03		35.3		3.4		15
5	7.26	7.05		102		72		30		0.02		36.1		4.4		14
6	7.36	7.27		98		70		28		0.03		33.7		3.4		13
7	7.35	7.25		100		70		30		0.02		32.1		4.9		11.5
8	7.33	7.22		98		70		28		0.02		31.3		4.9		10
9	7.31	7.26		102		70		32		0.05		34.5		3.9		13
10	7.31	7.19		104		72		32		0.02		35.3		3.9		15
11	7.34	7.21		100		70		30		0.01		32.1		4.9		10
12	7.35	7.21		100		72		28		0.02		31.3		5.3		15
13	7.26	7.18		104		70		34		0.03		32.9		5.3		14
14	7.34	7.23		98		72		26		0.02		32.1		4.4		12
15	7.34	7.21		100		72		28		0.02		29.7		6.3		12
16	7.37	7.22		102		70		32		0.02		33.7		4.4		15
17	7.23	7.17		100		70		30		0.02		36.1		2.4		11
18	7.25	7.15		100		68		32		0.03		30.5		5.8		13
19	7.32	7.18		104		68		36		0.03		36.1		3.4		12
20	7.25	7.18		98		70		28		0.03		32.1		4.4		12
21	7.33	7.20		98		70		28		0.02		29.7		5.8		12
22	7.32	7.17		100		70		30		0.02		32.1		4.9		11
23	7.28	7.18		98		70		28		0.03		36.1		1.9		11
24	7.27	7.17		98		70		28		0.04		35.3		2.4		12
25	7.28	7.17		98		68		30		0.02		36.9		1.5		12
26	7.28	7.17		96		72		24		0.02		31.3		4.4		11
27	7.27	7.21		98		72		26		0.02		31.3		4.9		10
28	7.32	7.19		102		72		30		0.02		31.3		5.8		12
29	7.33	7.20		100		74		26		0.03		31.3		5.3		12
AVG	7.31	7.21		100		71		30				33.2		4.3		12.5
MAX	7.39	7.39		104		74		36				36.9		6.3		15.0
MIN	7.23	7.05		96		68		24				29.7		1.5		10.0



**Bacteriological & Physical Parameters**

**WSSN 2310**

**Feb-16**

DATE	Total Coliform							Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1					2/0	2/0			0.22	12.1					
2					2/0	2/0			<2	0.22	9.60				
3					2/0	2/0			0.22	12.3					
4					2/0	2/0			<2	0.21	11.8				
5					2/0	2/0			0.22	12.6					
6					2/0	2/0			0.22	12.3					
7					2/0	2/0			0.22	12.6					
8					2/0	2/0			0.22	12.5					
9					2/0	2/0			<2	0.22	12.8				
10					2/0	2/0			<2	0.21	12.1				
11					2/0	2/0			<2	0.21	12.1				
12					2/0	2/0			0.21	12.6					
13					2/0	2/0			0.22	12.2					
14					2/0	2/0			0.22	11.6					
15					2/0	2/0			0.22	11.5					
16					2/0	2/0			0.22	11.6					
17					2/0	2/0			0.22	11.1					
18					2/0	2/0			0.22	10.6					
19					2/0	2/0			0.21	9.8					
20					2/0	2/0			0.21	9.0					
21					2/0	2/0			0.21	11.4					
22					2/0	2/0			0.21	10.9					
23					2/0	2/0			<2	0.21	10.9				
24					2/0	2/0			0.21	11.8					
25					2/0	2/0			0.21	12.0					
26					2/0	2/0			0.21	11.3					
27					2/0	2/0			0.20	12.2					
28					2/0	2/0			0.22	10.9					
29					2/0	2/0			0.22	9.2					
											11.5				
											12.8				
											9.0				



**Distribution System Monitoring**

**WSSN 2310**

**Feb-16**

D A T E	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR	Number of Samples
1											0
2											0.00
3	0.7	1.0	0.8	0.8	0.8	0.3	0.7	0.8	1.7	2.3	10
4	0.8	0.9	0.8	0.9	0.8	0.3	0.8	0.9	2.0	2.2	10
5	0.8	0.9	0.7	1.2	0.8	0.4	0.7	0.9	1.6	2.0	10
6											0
7											0
8											0
9	1.0	0.8	0.8	0.9	0.9	0.3			1.7	2.4	8
10	0.5	0.9	0.9	0.8	0.7	0.5	1.0	0.3	1.1	2.3	10
11	0.5	0.4	0.7	0.7	0.5	0.3	0.4	0.3	0.8	1.6	10
12											0
13											0
14											0
15											0
16											0
17	0.9	0.8	0.8	1.1	0.7	0.5	0.5	0.9	1.7	2.3	10
18	0.9	0.9	0.8	0.9	1.0	0.5	0.7	0.9	1.2	2.4	10
19											0
20											0
21											0
22											0
23	1.0	1.1	0.9	1.0	0.7	0.4	0.7	0.8	1.7	2.3	10
24	1.1	0.9	1.0	1.0	1.1	0.4	0.9	0.9	1.0	2.3	10
25							0.7	0.8			2
26											0
27											0
28											0
29											0
<b>Monthly Cl<sub>2</sub> Avg.</b>				<b>0.974</b>							
<b>Total Samples</b>				<b>100</b>							



**Distribution System Monitoring**

**WSSN 2310**

**Feb-16**

D A T E	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WR	Number of Samples
1											0
2											0.00
3	0.9	1.2	1.0	1.0	1.0	0.5	0.9	1.0	2.0	2.5	10
4	1.0	1.1	1.0	1.0	0.9	0.5	1.0	1.0	2.2	2.4	10
5	1.0	1.1	0.9	1.4	1.0	0.6	0.9	1.1	1.8	2.3	10
6											0
7											0
8											0
9	1.2	1.1	1.0	1.1	1.1	0.5			1.9	2.6	8
10	0.7	1.1	1.1	1.0	0.9	0.7	1.2	0.5	1.3	2.5	10
11	0.6	0.5	0.9	0.8	0.8	0.5	0.6	0.4	0.9	1.8	10
12											0
13											0
14											0
15											0
16											0
17	1.0	0.9	0.9	1.2	0.8	0.7	0.8	1.0	1.9	2.6	10
18	1.1	1.1	1.0	1.1	1.2	0.7	0.9	1.1	1.4	2.6	10
19											0
20											0
21											0
22											0
23	1.2	1.3	1.1	1.2	0.9	0.6	0.9	1.0	1.9	2.5	10
24	1.3	1.1	1.3	1.1	1.3	0.6	1.1	1.1	1.2	2.5	10
25							0.9	1.0			2
26											0
27											0
28											0
29											0
<b>Monthly Cl<sub>2</sub> Avg.</b>				<b>1.165</b>							
<b>Total Samples</b>				<b>100</b>							



**ROUTINE POSITIVE DISTRIBUTION SAMPLES**

**Feb-16**

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				<b>100</b>			
Total number of routine distribution samples required:				<b>100</b>			