Pierce Elementary
2500 N. Averill Avenue
Flint, Michigan 48503

ANALYTE	RESULT (mg/L)	ANALYTE	RESULT (mg/L)	Sample Description	Site Code	Site Code Description
Lead	0.008	Copper	0.51	01WC002	P1	First Primary draw of 125 milliliters
Lead	0.013	Copper	0.60	01WC002	P2	Second Primary draw of 125 milliliters
Lead	0.035	Copper	0.77	01WC002	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.019	Copper	0.35	01WC002	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.020	Copper	0.68	01DW001	P1	First Primary draw of 125 milliliters
Lead	0.002	Copper	0.25	01DW001	P2	Second Primary draw of 125 milliliters
Lead	0.002	Copper	0.17	01DW001	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.000	Copper	0.08	01DW001	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.026	Copper	0.36	01CF003 - RM 109	P1	First Primary draw of 125 milliliters
Lead	0.017	Copper	0.27	01CF003 - RM 109	P2	Second Primary draw of 125 milliliters
Lead	0.009	Copper	0.34	01CF003 - RM 109	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.15	01CF003 - RM 109	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.042	Copper	0.43	01DW004 - RM 109	P1	First Primary draw of 125 milliliters
Lead	0.017	Copper	0.26	01DW004 - RM 109	P2	Second Primary draw of 125 milliliters
Lead	0.003	Copper	0.15	01DW004 - RM 109	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.001	Copper	0.15	01DW004 - RM 109	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.014	Copper	0.28	01DW006 - RM 110	P1	First Primary draw of 125 milliliters
Lead	0.003	Copper	0.18	01DW006 - RM 110	P2	Second Primary draw of 125 milliliters
Lead	0.002	Copper	0.17	01DW006 - RM 110	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.001	Copper	0.16	01DW006 - RM 110	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.007	Copper	0.31	01CF005 - RM 110	P1	First Primary draw of 125 milliliters
Lead	0.008	Copper	0.30	01CF005 - RM 110	P2	Second Primary draw of 125 milliliters
Lead	0.002	Copper	0.16	01CF005 - RM 110	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.000	Copper	0.16	01CF005 - RM 110	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.097	Copper	0.60	01CF007 - RM 108	P1	First Primary draw of 125 milliliters
Lead	0.132	Copper	0.55	01CF007 - RM 108	P2	Second Primary draw of 125 milliliters
Lead	0.009	Copper	0.21	01CF007 - RM 108	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.15	01CF007 - RM 108	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.026	Copper	0.34	01DW009 - RM 111	P1	First Primary draw of 125 milliliters
Lead	0.038	Copper	0.51	01DW009 - RM 111	P2	Second Primary draw of 125 milliliters
Lead	0.007	Copper	0.22	01DW009 RM 111	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.003	Copper	0.15	01DW009 - RM 111	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.025	Copper	0.25	01CF011 - RM 107	P1	First Primary draw of 125 milliliters
Lead	0.011	Copper	0.19	01CF011 - RM 107	P2	Second Primary draw of 125 milliliters
Lead	0.003	Copper	0.16	01CF011 - RM 107	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.15	01CF011 - RM 107	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.043	Copper	1.15	01CF010 - RM 111	P1	First Primary draw of 125 milliliters
Lead	0.022	Copper	0.60	01CF010 - RM 111	P2	Second Primary draw of 125 milliliters
Lead	0.003	Copper	0.16	01CF010 - RM 111	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.003	Copper	0.15	01CF010 - RM 111	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.078	Copper	0.50	01DW012 - RM 112	P1	First Primary draw of 125 milliliters
Lead	0.011	Copper	0.19	01DW012 - RM 112	P2	Second Primary draw of 125 milliliters
Lead	0.004	Copper	0.16	01DW012 - RM 112	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.003	Copper	0.15	01DW012 - RM 112	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.468	Copper	0.20	01DW008 - RM 108	P1	First Primary draw of 125 milliliters
Lead	0.075	Copper	0.16	01DW008 - RM 108	P2	Second Primary draw of 125 milliliters
Lead	0.006	Copper	0.15	01DW008 - RM 108	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.004	Copper	0.15	01DW008 - RM 108	F02	Flush Sample taken 2 minutes after First Flush Sample

Note: Results of "Not Detected" have been converted to a numerical value of zero to allow for ease of sorting

Results in RED exceed 15 ppb for lead or 1.3 PPM for Copper
1 ppb = 0.001 mg/L

Pierce Elementary
2500 N. Averill Avenue
Flint, Michigan 48503

ANALYTE	RESULT (mg/L)	ANALYTE	RESULT (mg/L)	Sample Description	Site Code	Site Code Description
Lead	0.023	Copper	0.19	01DW027 - RM 311	P1	First Primary draw of 125 milliliters
Lead	0.019	Copper	0.25	01DW027 - RM 311	P2	Second Primary draw of 125 milliliters
Lead	0.061	Copper	0.39	01DW027 - RM 311	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.020	Copper	0.18	01DW027 - RM 311	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.061	Copper	0.60	01CF026 - RM 307	P1	First Primary draw of 125 milliliters
Lead	0.036	Copper	0.40	01CF026 - RM 307	P2	Second Primary draw of 125 milliliters
Lead	0.007	Copper	0.17	01CF026 - RM 307	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.004	Copper	0.15	01CF026 - RM 307	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.191	Copper	2.05	01DW025 - RM 307	P1	First Primary draw of 125 milliliters
Lead	0.069	Copper	0.50	01DW025 - RM 307	P2	Second Primary draw of 125 milliliters
Lead	0.028	Copper	0.20	01DW025 - RM 307	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.006	Copper	0.17	01DW025 - RM 307	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.017	Copper	0.39	01CF028 - RM 311	P1	First Primary draw of 125 milliliters
Lead	0.019	Copper	0.21	01CF028 - RM 311	P2	Second Primary draw of 125 milliliters
Lead	0.038	Copper	0.24	01CF028 - RM 311	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.015	Copper	0.17	01CF028 - RM 311	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.011	Copper	0.30	01CF032 - RM 310	P1	First Primary draw of 125 milliliters
Lead	0.005	Copper	0.13	01CF032 - RM 310	P2	Second Primary draw of 125 milliliters
Lead	0.003	Copper	0.12	01CF032 - RM 310	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.12	01CF032 - RM 310	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.029	Copper	0.36	01DW031 - RM 310	P1	First Primary draw of 125 milliliters
Lead	0.035	Copper	0.24	01DW031 - RM 310	P2	Second Primary draw of 125 milliliters
Lead	0.073	Copper	0.43	01DW031 - RM 310	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.003	Copper	0.12	01DW031 - RM 310	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.060	Copper	1.08	01CF030 - RM 308	P1	First Primary draw of 125 milliliters
Lead	0.009	Copper	0.18	01CF030 - RM 308	P2	Second Primary draw of 125 milliliters
Lead	0.011	Copper	0.14	01CF030 - RM 308	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.003	Copper	0.13	01CF030 - RM 308	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.078	Copper	0.48	01DW029 - RM 308	P1	First Primary draw of 125 milliliters
Lead	0.023	Copper	0.19	01DW029 - RM 308	P2	Second Primary draw of 125 milliliters
Lead	0.005	Copper	0.14	01DW029 - RM 308	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.13	01DW029 - RM 308	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.002	Copper	0.22	02KC033 - TEMPORARY CLASSROOM	P1	First Primary draw of 125 milliliters
Lead	0.000	Copper	0.51	02KC033 - TEMPORARY CLASSROOM	P2	Second Primary draw of 125 milliliters
Lead	0.000	Copper	0.27	02KC033 - TEMPORARY CLASSROOM	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.000	Copper	0.00	02KC033 - TEMPORARY CLASSROOM	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.000	Copper	0.73	02DW034 - TEMPORARY	P1	First Primary draw of 125 milliliters
Lead	0.054	Copper	0.82	02DW034 - TEMPORARY	P2	Second Primary draw of 125 milliliters
Lead	0.036	Copper	1.77	02DW034 - TEMPORARY	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.17	02DW034 - TEMPORARY	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.036	Copper	0.32	01DW024 - RM 312	P1	First Primary draw of 125 milliliters
Lead	0.008	Copper	0.16	01DW024 - RM 312	P2	Second Primary draw of 125 milliliters
Lead	0.006	Copper	0.15	01DW024 - RM 312	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.004	Copper	0.13	01DW024 - RM 312	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.053	Copper	0.53	01CF020 - RM 302	P1	First Primary draw of 125 milliliters
Lead	0.030	Copper	0.34	01CF020 - RM 302	P2	Second Primary draw of 125 milliliters
Lead	0.001	Copper	0.12	01CF020 - RM 302	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.000	Copper	0.11	01CF020 - RM 302	F02	Flush Sample taken 2 minutes after First Flush Sample

Note: Results of "Not Detected" have been converted to a numerical value of zero to allow for ease of sorting

Results in RED exceed 15 ppb for lead or 1.3 PPM for Copper
1 ppb = 0.001 mg/L

Pierce Elementary
2500 N. Averill Avenue
Flint, Michigan 48503

ANALYTE	RESULT (mg/L)	ANALYTE	RESULT (mg/L)	Sample Description	Site Code	Site Code Description
Lead	0.022	Copper	0.27	01CF023 - RM 312	P1	First Primary draw of 125 milliliters
Lead	0.014	Copper	0.19	01CF023 - RM 312	P2	Second Primary draw of 125 milliliters
Lead	0.009	Copper	0.17	01CF023 - RM 312	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.006	Copper	0.15	01CF023 - RM 312	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.220	Copper	0.51	01DW019 - RM 302	P1	First Primary draw of 125 milliliters
Lead	0.023	Copper	0.34	01DW019 - RM 302	P2	Second Primary draw of 125 milliliters
Lead	0.003	Copper	0.13	01DW019 - RM 302	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.12	01DW019 - RM 302	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.017	Copper	0.40	01DW022 - RM 306	P1	First Primary draw of 125 milliliters
Lead	0.006	Copper	0.17	01DW022 - RM 306	P2	Second Primary draw of 125 milliliters
Lead	0.004	Copper	0.15	01DW022 - RM 306	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.013	Copper	0.15	01DW022 - RM 306	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.015	Copper	0.36	01CF021 - RM 306	P1	First Primary draw of 125 milliliters
Lead	0.050	Copper	0.25	01CF021 - RM 306	P2	Second Primary draw of 125 milliliters
Lead	0.008	Copper	0.17	01CF021 - RM 306	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.003	Copper	0.14	01CF021 - RM 306	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.013	Copper	0.30	01CF018 - RM 301	P1	First Primary draw of 125 milliliters
Lead	0.016	Copper	0.31	01CF018 - RM 301	P2	Second Primary draw of 125 milliliters
Lead	0.004	Copper	0.16	01CF018 - RM 301	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.001	Copper	0.14	01CF018 - RM 301	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.004	Copper	0.30	01DW017 - MAIN CORRIDOR	P1	First Primary draw of 125 milliliters
Lead	0.002	Copper	0.15	01DW017 - MAIN CORRIDOR	P2	Second Primary draw of 125 milliliters
Lead	0.002	Copper	0.12	01DW017 - MAIN CORRIDOR	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.001	Copper	0.11	01DW017 - MAIN CORRIDOR	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.007	Copper	0.50	01KC016 - TEACHERS LOUNGE	P1	First Primary draw of 125 milliliters
Lead	0.002	Copper	0.63	01KC016 - TEACHERS LOUNGE	P2	Second Primary draw of 125 milliliters
Lead	0.000	Copper	0.20	01KC016 - TEACHERS LOUNGE	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.000	Copper	0.12	01KC016 - TEACHERS LOUNGE	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.010	Copper	0.20	01CF014 - RM 100	P1	First Primary draw of 125 milliliters
Lead	0.013	Copper	0.21	01CF014 - RM 100	P2	Second Primary draw of 125 milliliters
Lead	0.008	Copper	0.18	01CF014 - RM 100	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.003	Copper	0.14	01CF014 - RM 100	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.014	Copper	0.19	01DW015 - RM 100	P1	First Primary draw of 125 milliliters
Lead	0.003	Copper	0.14	01DW015 - RM 100	P2	Second Primary draw of 125 milliliters
Lead	0.001	Copper	0.13	01DW015 - RM 100	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.15	01DW015 - RM 100	F02	Flush Sample taken 2 minutes after First Flush Sample
Lead	0.012	Copper	0.25	01CF013 - RM 100	P1	First Primary draw of 125 milliliters
Lead	0.006	Copper	0.19	01CF013 - RM 100	P2	Second Primary draw of 125 milliliters
Lead	0.000	Copper	0.13	01CF013 - RM 100	F01	Flush Sample taken 30 Seconds after Second Primary Draw
Lead	0.002	Copper	0.16	01CF013 - RM 100	F02	Flush Sample taken 2 minutes after First Flush Sample

Note: Results of "Not Detected" have been converted to a numerical value of zero to allow for ease of sorting

Results in RED exceed 15 ppb for lead or 1.3 PPM for Copper
1 ppb = 0.001 mg/L

Pierce Elementary
2500 N. Averill Avenue
Flint, Michigan 48503

ANALYTE	RESULT (mg/L)	ANALYTE	RESULT (mg/L)	Sample Description	Site Code	Site Code Description
Lead	0.000	Copper	0.10	02KC033- TEMPORARY CLASSROOM	CA1	First Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA2	Second Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA3	Third Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA4	Forth Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA5	Fifth Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA6	Sixth Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA7	Seventh Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA8	Eigth Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA9	Ninth Sequential Sample
Lead	0.000	Copper	0.00	02KC033- TEMPORARY CLASSROOM	CA10	Tenth Sequential Sample
Lead	0.002	Copper	0.17	01CF013- RM 100	CB1	First Sequential Sample
Lead	0.002	Copper	0.16	01CF013- RM 100	CB2	Second Sequential Sample
Lead	0.002	Copper	0.15	01CF013- RM 100	CB3	Third Sequential Sample
Lead	0.002	Copper	0.16	01CF013- RM 100	CB4	Forth Sequential Sample
Lead	0.002	Copper	0.17	01CF013- RM 100	CB5	Fifth Sequential Sample
Lead	0.002	Copper	0.18	01CF013- RM 100	CB6	Sixth Sequential Sample
Lead	0.002	Copper	0.18	01CF013- RM 100	CB7	Seventh Sequential Sample
Lead	0.002	Copper	0.19	01CF013- RM 100	CB8	Eigth Sequential Sample
Lead	0.003	Copper	0.19	01CF013- RM 100	CB9	Ninth Sequential Sample
Lead	0.003	Copper	0.21	01CF013- RM 100	CB10	Tenth Sequential Sample
Lead	0.004	Copper	0.18	01CF018- RM 301	CC1	First Sequential Sample
Lead	0.002	Copper	0.13	01CF018- RM 301	CC2	Second Sequential Sample
Lead	0.002	Copper	0.12	01CF018- RM 301	CC3	Third Sequential Sample
Lead	0.002	Copper	0.12	01CF018- RM 301	CC4	Forth Sequential Sample
Lead	0.001	Copper	0.12	01CF018- RM 301	CC5	Fifth Sequential Sample
Lead	0.001	Copper	0.12	01CF018- RM 301	CC6	Sixth Sequential Sample
Lead	0.001	Copper	0.12	01CF018- RM 301	CC7	Seventh Sequential Sample
Lead	0.001	Copper	0.12	01CF018- RM 301	CC8	Eigth Sequential Sample
Lead	0.001	Copper	0.12	01CF018- RM 301	CC9	Ninth Sequential Sample
Lead	0.000	Copper	0.12	01CF018- RM 301	CC10	Tenth Sequential Sample
Lead	0.004	Copper	0.15	01CF032- RM 310	CD1	First Sequential Sample
Lead	0.005	Copper	0.14	01CF032- RM 310	CD2	Second Sequential Sample
Lead	0.006	Copper	0.14	01CF032- RM 310	CD3	Third Sequential Sample
Lead	0.004	Copper	0.14	01CF032- RM 310	CD4	Forth Sequential Sample
Lead	0.003	Copper	0.13	01CF032- RM 310	CD5	Fifth Sequential Sample
Lead	0.003	Copper	0.13	01CF032- RM 310	CD6	Sixth Sequential Sample
Lead	0.003	Copper	0.13	01CF032- RM 310	CD7	Seventh Sequential Sample
Lead	0.003	Copper	0.13	01CF032- RM 310	CD8	Eigth Sequential Sample
Lead	0.003	Copper	0.13	01CF032- RM 310	CD9	Ninth Sequential Sample
Lead	0.002	Copper	0.13	01CF032- RM 310	CD10	Tenth Sequential Sample

Note: Results of "Not Detected" have been converted to a numerical value of zero to allow for ease of sorting

Results in RED exceed 15 ppb for lead or 1.3 PPM for Copper
1 ppb = 0.001 mg/L