

**Summary of City of Flint Actions
In Response to the
United States Environmental Protection Agency
Emergency Administrative Order
Updated: June 7, 2018**

Chapters 52, 57, 59a & 59b: Weekly Report Regarding Flint Water Plant Operations
June 7, 2018.

United States Environmental Protection Agency Order Due Date: Weekly

The Michigan Department of Environmental Quality held a conference call with Flint Water Treatment Plant Staff on June 7, 2018, to review and discuss the summary of water quality and corrosion control parameters reported on the city of Flint's (City) May operation reports completed to date, and a summary of water quality parameters collected for the seven-day period from Thursday, May 31, 2018, to Wednesday, June 6, 2018, from the ten sites monitored weekly. Data review (from the MOR) and enhanced weekly distribution system data is summarized below. Please note: SITE NAME is being used for water quality data to replace the former West Side reservoir site. The City is not planning to return the West Side reservoir to service.

The following observations were noted:

- The supplemental phosphate dosage ranged between 2.29 and 2.36 milligrams per liter. The phosphate residuals measured at the plant tap ranged from 3.4 to 3.5 milligrams per liter entering the distribution system.
- All pH measurements were greater than 7.5 at all ten of the Enhanced Water Quality Monitoring (EWQM) sites and the Point of Entry (Plant tap) to the system. The pH levels ranged from 7.40 to 7.50 in the water received from Great Lakes Water Authority (GLWA); from 7.58 to 7.64 at Plant tap; and from 7.58 to 7.72 at the ten distribution system sites.
- The City's Sodium Hydroxide feed for pH control ranged from 2.1 to 3.5 milligrams per liter at Control Station #2.
- The phosphate residual at the ten established, weekly distribution system sites ranged between 3.20 and 3.55 milligrams per liter.
- Iron levels at EWQM sites ranged from 0.01 to 0.04 milligrams per liter. Plant tap iron concentrations measured 0.00 to 0.02 milligrams per liter in the last week.
- The supplemental chlorine feed at Control Station #2 ranged from 0.95 to 1.27 milligrams per liter and the plant tap free chlorine residuals ranged from 1.4 to 1.7 milligrams per liter.
- The free chlorine residuals at the City's 25 monitoring sites in the distribution system ranged from 0.63 to 1.71 milligrams per liter. The low residual occurred at two locations, MLK Boulevard and Foss Avenue, and the high residual was at South Dort Highway.