

**Summary of City of Flint (City) Actions  
In Response to the  
EPA Emergency Administrative Order  
Updated: August 3, 2017**

Chapters 52, 57, 59a & 59b: Weekly Report Regarding Flint Water Plant Operations August 3, 2017.

EPA Order Due Date: Weekly

The DEQ held a conference call with Flint Water Treatment Plant Staff on August 3, 2017, to review and discuss the summary of water quality and corrosion control parameters reported on the City's completed July operation report and August operation report completed to date, and a summary of water quality parameters collected for the seven-day period from Thursday, July 27, 2017, to Wednesday, August 2, 2017, from the ten sites monitored weekly. Data review (from the MOR) and enhanced weekly distribution system data is summarized below. Please note: SITENAME is being used for water quality data instead of West Side until the reservoir is placed back into service. The City contractor completed an inspection of the West Side reservoir May 22, 2017, to May 25, 2017. The Inspection report dated June 6, 2017, is being reviewed by the City.

Note: According to WTP staff and records submitted the chlorine tote ran dry at some point on July 26, 2017, between 4 a.m. and 8 a.m. for an unknown period of time. The WTP staff will be filing an incident report on this issue. Distribution system monitoring this week did not indicate a drop in chlorine residual.

The following observations were noted:

- The supplemental phosphate dosage ranged between 2.20 and 2.70 milligrams per liter. The phosphate residuals measured at the plant tap ranged from 3.6 to 3.9 milligrams per liter entering the distribution system.
- All pH measurements were greater than 7.0 at all ten of the Enhanced Water Quality Monitoring (EWQM) sites and the Point of Entry (Control Station #2) to the system. The pH levels ranged from 7.33 to 7.46 in the water received from Great Lakes Water Authority (GLWA); from 7.41 to 7.57 at Plant tap; and from 7.27 to 7.50 at the ten distribution system sites.
- The City's Sodium Hydroxide feed for pH control ranged from 3.0 to 3.2 milligrams per liter at Control Station #2.
- The phosphate residual at the ten established, weekly distribution system sites ranged between 3.4 and 3.6 milligrams per liter.
- Iron levels at EWQM sites ranged from 0.01 to 0.05 milligrams per liter. Plant tap iron concentrations measured 0.01 to 0.03 milligrams per liter in the last week.
- The supplemental chlorine feed at Control Station #2 ranged from 1.34 to 1.79 milligrams per liter and the plant tap free chlorine residuals ranged from 1.8 to 2.0 milligrams per liter.

- The free chlorine residuals at the City's 25 monitoring sites in the distribution system ranged from 0.53 to 1.70 milligrams per liter. The low residual occurred at MLK Boulevard and the high residual was at East Kearsley Street.