

**Summary of City of Flint (City) Actions  
In Response to the  
EPA Emergency Administrative Order  
Updated: September 22, 2017**

Chapters 52, 57, 59a & 59b: Weekly Report Regarding Flint Water Plant Operations  
September 22, 2017.

EPA Order Due Date: Weekly

The DEQ held a conference call with Flint Water Treatment Plant Staff on September 22, 2017, to review and discuss the summary of water quality and corrosion control parameters reported on the City's September operation report completed to date, and a summary of water quality parameters collected for the seven-day period from Thursday, September 14, 2017, to Wednesday, September 20, 2017, from the ten sites monitored weekly. Data review (from the MOR) and enhanced weekly distribution system data is summarized below. Please note: SITE NAME is being used for water quality data instead of West Side until the reservoir is placed back into service. The City contractor completed an inspection of the West Side reservoir May 22, 2017, to May 25, 2017. The Inspection report dated June 6, 2017, is being reviewed by the City.

The following observations were noted:

- The supplemental phosphate dosage ranged between 2.36 and 2.68 milligrams per liter. The phosphate residuals measured at the plant tap ranged from 3.6 to 3.8 milligrams per liter entering the distribution system.
- All pH measurements were greater than 7.0 at all ten of the Enhanced Water Quality Monitoring (EWQM) sites and the Point of Entry (Plant tap) to the system. The pH levels ranged from 7.30 to 7.50 in the water received from Great Lakes Water Authority (GLWA); from 7.39 to 7.58 at Plant tap; and from 7.27 to 7.38 at the ten distribution system sites.
- The City's Sodium Hydroxide feed for pH control ranged from 3.8 to 4.2 milligrams per liter at Control Station #2.
- The phosphate residual at the ten established, weekly distribution system sites ranged between 3.3 and 3.7 milligrams per liter.
- Iron levels at EWQM sites ranged from 0.00 to 0.02 milligrams per liter. Plant tap iron concentrations measured from 0.00 to 0.02 milligrams per liter in the last week.
- The supplemental chlorine feed at Control Station #2 ranged from 1.42 to 1.95 milligrams per liter and the plant tap free chlorine residuals ranged from 1.7 to 1.9 milligrams per liter.
- The free chlorine residuals at the City's 25 monitoring sites in the distribution system ranged from 0.35 to 1.62 milligrams per liter. The low residual occurred at Court Street and the high residual was at Clio Road.
- The MLK Boulevard EWQM site detected lead at 16 parts per billion collected on September 8, 2017, and reported on September 21, 2017. This sample was mistakenly collected as a first draw with unknown stagnation period. Weekly samples were also collected on September 14, 2017, and September 21, 2017, and are currently being processed and analyzed.