

Flint Residential and Business Testing Report - results collected July 01, 2022 through August 23, 2022

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LK25213	8/2/2022	Lead				0	Copper				0	3532	ALEXANDER ST	FLINT	48505
LK25214	8/2/2022	Lead				0	Copper				0	3532	ALEXANDER ST	FLINT	48505
LK23569	7/21/2022	Lead				0	Copper				0	4919	ALPHA WAY	FLINT	48506
LK23570	7/21/2022	Lead				0	Copper				0	4919	ALPHA WAY	FLINT	48506
LK24536	7/28/2022	Lead				0	Copper				0	3410	BEECHER RD	FLINT	48503
LK24537	7/28/2022	Lead				0	Copper				0	3410	BEECHER RD	FLINT	48503
LK26063	8/4/2022	Lead				0	Copper				0	3734	BEECHER RD	FLINT	48503
LK26064	8/4/2022	Lead				0	Copper				0	3734	BEECHER RD	FLINT	48503
LK27534	8/11/2022	Lead				1	Copper				0	3738	BEECHER RD	FLINT	48503
LK27533	8/11/2022	Lead				2	Copper				0	3738	BEECHER RD	FLINT	48503
LK26065	8/4/2022	Lead				0	Copper				0	1821	BENNETT AVE	FLINT	48506
LK26066	8/4/2022	Lead				0	Copper				0	1821	BENNETT AVE	FLINT	48506
LK23567	7/21/2022	Lead				0	Copper				0	2401	BETA LN	FLINT	48506
LK23568	7/21/2022	Lead				0	Copper				0	2401	BETA LN	FLINT	48506
LK24534	7/28/2022	Lead				0	Copper				0	911	BRADLEY AVE	FLINT	48503
LK24535	7/28/2022	Lead				0	Copper				0	911	BRADLEY AVE	FLINT	48503
LK26075	8/4/2022	Lead				0	Copper				0	2058	BRANCH ST	FLINT	48506
LK26076	8/4/2022	Lead				0	Copper				0	2058	BRANCH ST	FLINT	48506
LK20846	7/7/2022	Lead	0	0	0		Copper	0	0	0		3607	BRENTWOOD DR	FLINT	48503
LK27541	8/11/2022	Lead				0	Copper				0	2133	CARTIER ST	FLINT	48503
LK27542	8/11/2022	Lead				0	Copper				0	2133	CARTIER ST	FLINT	48503
LK29589	8/23/2022	Lead				0	Copper				0	3001	CHICAGO BLVD	FLINT	48503
LK29590	8/23/2022	Lead				0	Copper				0	3001	CHICAGO BLVD	FLINT	48503
LK29597	8/23/2022	Lead				0	Copper				0	934	CHURCH ST	FLINT	48502
LK29598	8/23/2022	Lead				2	Copper				0	934	CHURCH ST	FLINT	48502
LK29600	8/23/2022	Lead				0	Copper				0	1019	CHURCH ST	FLINT	48502
LK29599	8/23/2022	Lead				2	Copper				0	1019	CHURCH ST	FLINT	48502
LK29414	8/22/2022	Lead	0	0	0		Copper	0	0	0		6052	CLIO RD	FLINT	48504
LK29413	8/22/2022	Lead	0	0	0		Copper	0	0	0		6910	CLIO RD	FLINT	48504
LK29605	8/23/2022	Lead				0	Copper				0	712	COMMONWEALTH AVE	FLINT	48503
LK29606	8/23/2022	Lead				0	Copper				0	712	COMMONWEALTH AVE	FLINT	48503
LK29619	8/23/2022	Lead				0	Copper				0	2317	CORUNNA RD	FLINT	48503
LK29620	8/23/2022	Lead				2	Copper				0	2317	CORUNNA RD	FLINT	48503
LK25215	8/2/2022	Lead				0	Copper				0	506	CRAPO ST	FLINT	48503
LK25216	8/2/2022	Lead				0	Copper				0	506	CRAPO ST	FLINT	48503
LK25219	8/2/2022	Lead				0	Copper				0	612	CRAPO ST	FLINT	48503
LK25220	8/2/2022	Lead				0	Copper				0	612	CRAPO ST	FLINT	48503
LK27973	8/15/2022	Lead	0	0	0		Copper	0	0	0		1808	CRESTBROOK LN	FLINT	48507
LK25205	8/2/2022	Lead				10	Copper				290	2232	DAVISON RD	FLINT	48506
LK25206	8/2/2022	Lead				11	Copper				250	2232	DAVISON RD	FLINT	48506
LK25209	8/2/2022	Lead				0	Copper				0	710	DICKINSON ST	FLINT	48504
LK25210	8/2/2022	Lead				0	Copper				0	710	DICKINSON ST	FLINT	48504
LK25204	8/2/2022	Lead				1	Copper				0	1713	DONALD ST	FLINT	48505
LK25203	8/2/2022	Lead				2	Copper				0	1713	DONALD ST	FLINT	48505
LK20848	7/7/2022	Lead	60	6	19		Copper	0	0	0		1459	DUPONT ST	FLINT	48504
LK26074	8/4/2022	Lead				2	Copper				0	902	E 6TH ST	FLINT	48503

Flint Residential and Business Testing Report - results collected July 01, 2022 through August 23, 2022

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LK26073	8/4/2022	Lead				3	Copper				0	902	E 6TH ST	FLINT	48503
LK27622	8/11/2022	Lead	0	0	0		Copper	0	0	0		841	E 7TH ST	FLINT	48503
LK29588	8/23/2022	Lead				0	Copper				0	311	E COURT ST	FLINT	48502
LK29587	8/23/2022	Lead				2	Copper				0	311	E COURT ST	FLINT	48502
LK29584	8/23/2022	Lead				7	Copper				0	410	E COURT ST	FLINT	48503
LK29583	8/23/2022	Lead				17	Copper				140	410	E COURT ST	FLINT	48503
LK20851	7/7/2022	Lead	74	20	33		Copper	4050	520	1400		902	E COURT ST	FLINT	48503
LK27529	8/11/2022	Lead				0	Copper				0	725	E HOLBROOK	FLINT	48505
LK27530	8/11/2022	Lead				0	Copper				0	725	E HOLBROOK	FLINT	48505
LK27974	8/15/2022	Lead	0	0	0		Copper	0	0	0		518	E PARKWAY AVE	FLINT	48505
LK27623	8/11/2022	Lead	0	0	0		Copper	0	0	0		2602	FENTON RD	FLINT	48507
LK29585	8/23/2022	Lead				0	Copper				0	3621	FENTON RD	FLINT	48507
LK29586	8/23/2022	Lead				1	Copper				0	3621	FENTON RD	FLINT	48507
LK29591	8/23/2022	Lead				0	Copper				0	713	FRANK ST	FLINT	48504
LK29592	8/23/2022	Lead				0	Copper				0	713	FRANK ST	FLINT	48504
LK29609	8/23/2022	Lead				0	Copper				60	947	INGLESIDE AVE	FLINT	48507
LK29610	8/23/2022	Lead				0	Copper				0	947	INGLESIDE AVE	FLINT	48507
LK24695	7/28/2022	Lead	0	0	0		Copper	0	0	0		1519	IRENE AVE	FLINT	48503
LK25207	8/2/2022	Lead				0	Copper				0	2021	KNAPMAN ST	FLINT	48506
LK25208	8/2/2022	Lead				0	Copper				0	2021	KNAPMAN ST	FLINT	48506
LK27539	8/11/2022	Lead				0	Copper				0	1113	LAPEER RD	FLINT	48503
LK27540	8/11/2022	Lead				0	Copper				0	1113	LAPEER RD	FLINT	48503
LK25211	8/2/2022	Lead				0	Copper				0	2309	LEITH ST	FLINT	48506
LK25212	8/2/2022	Lead				1	Copper				0	2309	LEITH ST	FLINT	48506
LK26061	8/4/2022	Lead				0	Copper				0	2622	LESTER CT	FLINT	48503
LK26062	8/4/2022	Lead				0	Copper				0	2622	LESTER CT	FLINT	48503
LK28904	8/18/2022	Lead				0	Copper				80	931	MANN AVE	FLINT	48503
LK28905	8/18/2022	Lead				0	Copper				0	931	MANN AVE	FLINT	48503
LK29608	8/23/2022	Lead				1	Copper				0	1206	MASON ST	FLINT	48503
LK29607	8/23/2022	Lead				2	Copper				0	1206	MASON ST	FLINT	48503
LK23566	7/21/2022	Lead	0	0	0		Copper	0	0	0		818	MCKINLEY AVE	FLINT	48507
LK25222	8/2/2022	Lead				0	Copper				0	1647	MONTANA ST	FLINT	48506
LK25221	8/2/2022	Lead				2	Copper				0	1647	MONTANA ST	FLINT	48506
LK25225	8/2/2022	Lead				0	Copper				0	1809	N BALLENGER HWY	FLINT	48504
LK25226	8/2/2022	Lead				0	Copper				0	1809	N BALLENGER HWY	FLINT	48504
LK26067	8/4/2022	Lead				0	Copper				0	1426	N CHEVROLET	FLINT	48504
LK26068	8/4/2022	Lead				3	Copper				0	1426	N CHEVROLET	FLINT	48504
LK27535	8/11/2022	Lead				0	Copper				60	1402	N CHEVROLET AVE	FLINT	48504
LK27536	8/11/2022	Lead				0	Copper				50	1402	N CHEVROLET AVE	FLINT	48504
LK25230	8/2/2022	Lead				10	Copper				0	959	N CHEVROLET ST	FLINT	48504
LK25229	8/2/2022	Lead				21	Copper				0	959	N CHEVROLET ST	FLINT	48504
LK25233	8/2/2022	Lead				0	Copper				0	1057	N CHEVROLET ST	FLINT	48504
LK25234	8/2/2022	Lead				0	Copper				0	1057	N CHEVROLET ST	FLINT	48504
LK25227	8/2/2022	Lead				0	Copper				0	1669	N CHEVROLET ST	FLINT	48504
LK25228	8/2/2022	Lead				0	Copper				0	1669	N CHEVROLET ST	FLINT	48504
LK28992	8/18/2022	Lead	0	0	0		Copper	60	0	0		2002	N DEXTER ST	FLINT	48506

Flint Residential and Business Testing Report - results collected July 01, 2022 through August 23, 2022

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LK24538	7/28/2022	Lead				0	Copper				0	3718	N FRANKLIN AVE	FLINT	48506
LK24539	7/28/2022	Lead				0	Copper				0	3718	N FRANKLIN AVE	FLINT	48506
LK29615	8/23/2022	Lead				1	Copper				0	722	N GRAND TRAVERSE	FLINT	48503
LK29616	8/23/2022	Lead				3	Copper				0	722	N GRAND TRAVERSE	FLINT	48503
LK29614	8/23/2022	Lead				1	Copper				0	4913	N SAGINAW ST	FLINT	48505
LK29613	8/23/2022	Lead				7	Copper				0	4913	N SAGINAW ST	FLINT	48505
LK27621	8/11/2022	Lead	0	0	0		Copper	150	130	130		2559	PADUCAH ST	FLINT	48504
LK23564	7/21/2022	Lead	3	2	2		Copper	310	90	150		1909	PROCTOR AVE	FLINT	48504
LK27537	8/11/2022	Lead				0	Copper				0	1902	RASKOB ST	FLINT	48504
LK27538	8/11/2022	Lead				0	Copper				0	1902	RASKOB ST	FLINT	48504
LK20849	7/7/2022	Lead	0	0	0		Copper	0	0	0		3834	RED ARROW RD APT 4	FLINT	48507
LK29412	8/22/2022	Lead	0	0	0		Copper	0	0	0		1428	ROOSEVELT AVE	FLINT	48503
LK28906	8/18/2022	Lead				0	Copper				0	520	S GRAND TRAVERSE ST	FLINT	48502
LK28907	8/18/2022	Lead				1	Copper				0	520	S GRAND TRAVERSE ST	FLINT	48502
LK29611	8/23/2022	Lead				3	Copper				0	4907	SAGINAW ST	FLINT	48505
LK29612	8/23/2022	Lead				6	Copper				0	4907	SAGINAW ST	FLINT	48505
LK20847	7/7/2022	Lead	3	0	0		Copper	230	160	180		1802	SEYMOUR AVE	FLINT	48503
LK20850	7/7/2022	Lead	0	0	0		Copper	180	220	210		1811	SEYMOUR AVE	FLINT	48503
LK20852	7/7/2022	Lead	0	0	0		Copper	90	180	160		1811	SEYMOUR AVE	FLINT	48503
LK26077	8/4/2022	Lead				0	Copper				0	899	SIMCOE AVE	FLINT	48507
LK26078	8/4/2022	Lead				0	Copper				0	899	SIMCOE AVE	FLINT	48507
LK28993	8/18/2022	Lead	0	0	0		Copper	70	60	60		709	SPELLMAN DR	FLINT	48503
LK26069	8/4/2022	Lead				0	Copper				0	714	STOCKTON ST	FLINT	48503
LK26070	8/4/2022	Lead				0	Copper				0	714	STOCKTON ST	FLINT	48503
LK23565	7/21/2022	Lead	0	4	3		Copper	0	500	380		1819	TERRANCE DR	FLINT	48507
LK27531	8/11/2022	Lead				0	Copper				0	2524	TYRONE ST	FLINT	48504
LK27532	8/11/2022	Lead				2	Copper				0	2524	TYRONE ST	FLINT	48504
LK25030	8/1/2022	Lead	0	0	0		Copper	0	0	0		702	W 12TH ST	FLINT	48503
LK25231	8/2/2022	Lead				0	Copper				0	1201	W ATHERTON RD	FLINT	48507
LK25232	8/2/2022	Lead				0	Copper				0	1201	W ATHERTON RD	FLINT	48507
LK23563	7/21/2022	Lead	3	0	0		Copper	0	0	0		1201	W ATHERTON RD	FLINT	48507
LK29596	8/23/2022	Lead				1	Copper				0	316	W COURT ST	FLINT	48502
LK29595	8/23/2022	Lead				2	Copper				0	316	W COURT ST	FLINT	48502
LK29617	8/23/2022	Lead				0	Copper				0	414	W COURT ST	FLINT	48503
LK29618	8/23/2022	Lead				8	Copper				0	414	W COURT ST	FLINT	48503
LK29601	8/23/2022	Lead				4	Copper				0	415	W COURT ST	FLINT	48503
LK29602	8/23/2022	Lead				6	Copper				0	415	W COURT ST	FLINT	48503
LK29603	8/23/2022	Lead				0	Copper				0	1742	W COURT ST	FLINT	48503
LK29604	8/23/2022	Lead				0	Copper				0	1742	W COURT ST	FLINT	48503
LK29594	8/23/2022	Lead				0	Copper				0	2225	W COURT ST	FLINT	48503
LK29593	8/23/2022	Lead				2	Copper				0	2225	W COURT ST	FLINT	48503
LK25217	8/2/2022	Lead				1	Copper				60	221	W DEWEY ST	FLINT	48505
LK25218	8/2/2022	Lead				1	Copper				0	221	W DEWEY ST	FLINT	48505
LK26072	8/4/2022	Lead				0	Copper				0	145	W LAKEVIEW	FLINT	48503
LK26071	8/4/2022	Lead				1	Copper				0	145	W LAKEVIEW	FLINT	48503
LK27527	8/11/2022	Lead				0	Copper				0	617	W RANKIN	FLINT	48505

Flint Residential and Business Testing Report - results collected July 01, 2022 through August 23, 2022

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LK27528	8/11/2022	Lead				0	Copper				0	617	W RANKIN	FLINT	48505
LK25223	8/2/2022	Lead				0	Copper				0	1911	WEAVER ST	FLINT	48506
LK25224	8/2/2022	Lead				1	Copper				0	1911	WEAVER ST	FLINT	48506
LK26590	8/8/2022	Lead	0	6	5		Copper	0	90	70		2723	WINONA ST	FLINT	48504
LK24694	7/28/2022	Lead	246	11	70		Copper	600	0	150		1718	WISCONSIN	FLINT	48506
LK28903	8/18/2022	Lead				6	Copper				0	1420	WOLCOTT ST	FLINT	48503
LK28902	8/18/2022	Lead				50	Copper				0	1420	WOLCOTT ST	FLINT	48503
LK26079	8/4/2022	Lead	0	1	0		Copper	0	0	0		3014	YALE ST	FLINT	48503

Notes:

ppb = parts per billion

Lead values exceeding 15 ppb and Copper results exceeding 1,300 are highlighted in red.

Sample results of "Not Detected" have been replaced with a numerical value of zero for ease of sorting.

Samples without a zip code did not have one provided on the accompanying paperwork.

*** indicate Invalid Zip Code