

**Flint Residential Testing Report - results collected July 1, 2019 through December 19, 2019**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LI71754	10/22/2019	Lead	1	18	14		Copper	0	0	0		2417	ADONIE ST	FLINT	48503
LI76230	11/8/2019	Lead	0	0	0		Copper	0	0	0		2822	ALPHAWAY	FLINT	48506
LI81395	12/5/2019	Lead				0	Copper				0	632	ALVORD	FLINT	48507
LI81396	12/5/2019	Lead				0	Copper				0	632	ALVORD	FLINT	48507
LI48607	7/9/2019	Lead	0	0	0		Copper	0	0	0		3714	ARLENE AVE	FLINT	48532
LI49417	7/12/2019	Lead	0	0	0		Copper	0	0	0		3714	ARLENE AVE	FLINT	48532
LI80448	11/27/2019	Lead	0	0	0		Copper	0	0	0		2938	BARTH ST	FLINT	48504
LI64622	9/17/2019	Lead	0	0	0		Copper	0	0	0		1927	BASIL LN	FLINT	48504
LI74581	11/1/2019	Lead	0	0	0		Copper	0	0	0		3406	BEECHER RD	FLINT	48503
LI62161	9/6/2019	Lead	32	0	8		Copper	1760	70	490		3714	BEECHER RD	FLINT	48503
LI74580	11/1/2019	Lead	0	0	0		Copper	50	0	0		824	BELMONT	FLINT	48503
LI58976	8/23/2019	Lead	0	0	0		Copper	0	0	0		2420	BETA LANE	FLINT	48506
LI77399	11/15/2019	Lead	0	0	0		Copper	0	0	0		2408	BETA LN	FLINT	48506
LI66761	9/24/2019	Lead	0	0	0		Copper	0	0	0		2420	BETE LN	FLINT	48506
LI66762	9/24/2019	Lead	0	0	0		Copper	0	0	0		2050	BLADES AVE	FLINT	48503
LI84895	12/19/2019	Lead				0	Copper				120	3434	BREWSTER	FLINT	48506
LI84896	12/19/2019	Lead				0	Copper				0	3434	BREWSTER	FLINT	48503
LI83053	12/12/2019	Lead				2	Copper				0	2626	BROWN	FLINT	48506
LI83052	12/12/2019	Lead				22	Copper				0	2626	BROWN	FLINT	48503
LI50793	7/19/2019	Lead	0	0	0		Copper	0	0	0		3602	BROWNELL BLVD	FLINT	48504
LI63614	9/12/2019	Lead				0	Copper				0	221	BROWNING AVE	FLINT	48507
LI63615	9/12/2019	Lead				0	Copper				0	221	BROWNING AVE	FLINT	48507
LI63616	9/12/2019	Lead				0	Copper				0	2509	BRUNSWICK AVE	FLINT	48507
LI63617	9/12/2019	Lead				0	Copper				0	2509	BRUNSWICK AVE	FLINT	48507
LI63590	9/12/2019	Lead				0	Copper				0	905	BUCKINGHAM AVE	FLINT	48507
LI63591	9/12/2019	Lead				0	Copper				0	905	BUCKINGHAM AVE	FLINT	48507
LI83054	12/12/2019	Lead				0	Copper				0	3911	BUICK ST	FLINT	48505
LI83055	12/12/2019	Lead				0	Copper				0	3911	BUICK ST	FLINT	48505
LI58977	8/23/2019	Lead	1	0	0		Copper	60	0	0		3215	BURGESS ST	FLINT	48503
LI63586	9/12/2019	Lead				0	Copper				0	2022	BURR BLVD	FLINT	48503
LI63587	9/12/2019	Lead				0	Copper				0	2022	BURR BLVD	FLINT	48503
LI63600	9/12/2019	Lead				0	Copper				0	1207	CALDWELL	FLINT	48503
LI63601	9/12/2019	Lead				0	Copper				0	1207	CALDWELL	FLINT	48503
LI81385	12/5/2019	Lead				2	Copper				0	1602	CALUMET	FLINT	48503
LI81386	12/5/2019	Lead				5	Copper				0	1602	CALUMET	FLINT	48503
LI81393	12/5/2019	Lead				0	Copper				0	2001	CALUMET	FLINT	48503
LI81394	12/5/2019	Lead				0	Copper				0	2001	CALUMET	FLINT	48503
LI81390	12/5/2019	Lead				0	Copper				0	2007	CALUMET	FLINT	48503
LI81389	12/5/2019	Lead				1	Copper				0	2007	CALUMET	FLINT	48503
LI81391	12/5/2019	Lead				0	Copper				60	2013	CALUMET	FLINT	48503
LI81392	12/5/2019	Lead				0	Copper				0	2013	CALUMET	FLINT	48503
LI81399	12/5/2019	Lead				0	Copper				0	2307	CALUMET	FLINT	48503
LI81400	12/5/2019	Lead				0	Copper				0	2307	CALUMET	FLINT	48503
LI81383	12/5/2019	Lead				0	Copper				0	2413	CALUMET	FLINT	48503
LI81384	12/5/2019	Lead				0	Copper				0	2413	CALUMET	FLINT	48503
LI68595	10/1/2019	Lead	0	0	0		Copper	0	0	0		1902	CARMANBROOK PKY	FLINT	48507
LI53574	8/2/2019	Lead	0	0	0		Copper	0	0	0		2343	CASCADE AVE	FLINT	48504
LI55425	8/9/2019	Lead	0	0	0		Copper	0	0	0		3517	CASSIUS ST	FLINT	48505
LI57143	8/16/2019	Lead	0	0	0		Copper	0	0	0		1842	CHELAN	FLINT	48503
LI63580	9/12/2019	Lead				0	Copper				0	2048	CHELAN ST	FLINT	48503

Flint Residential Testing Report - results collected July 1, 2019 through December 19, 2019

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LI63581	9/12/2019	Lead				0	Copper				0	2048	CHELAN ST	FLINT	48503
LI63588	9/12/2019	Lead				0	Copper				0	2057	CHELAN ST	FLINT	48503
LI63589	9/12/2019	Lead				0	Copper				0	2057	CHELAN ST	FLINT	48503
LI66042	9/20/2019	Lead	0	0	0		Copper	0	0	0		1905	CHERRYLAWN DR	FLINT	48504
LI64620	9/17/2019	Lead	5	2	3		Copper	70	0	0		3509	CHICAGO BL	FLINT	48503
LI52839	7/30/2019	Lead	0	0	0		Copper	0	0	0		3801	CLAIRMONT	FLINT	48352
LI63596	9/12/2019	Lead				0	Copper				0	6902	CLIO RD	FLINT	48504
LI63597	9/12/2019	Lead				0	Copper				0	6902	CLIO RD	FLINT	48504
LI81403	12/5/2019	Lead				0	Copper				0	1927	COLON	FLINT	48506
LI81404	12/5/2019	Lead				0	Copper				0	1927	COLON	FLINT	48506
LI80826	12/3/2019	Lead	0	0	0		Copper	0	0	0		6621	COLONIAL DRIVE	FLINT	48505
LI84887	12/19/2019	Lead				0	Copper				50	2529	CORUNNA	FLINT	48503
LI84888	12/19/2019	Lead				0	Copper				0	2529	CORUNNA	FLINT	48506
LI84901	12/19/2019	Lead				0	Copper				0	2704	CORUNNA	FLINT	48503
LI84902	12/19/2019	Lead				0	Copper				0	2704	CORUNNA	FLINT	48504
LI48050	7/3/2019	Lead	0	0	0		Copper	70	70	70		4709	CRESTBROOK LANE	FLINT	48507
LI61730	9/5/2019	Lead				0	Copper				0	2418	DAKOTA	FLINT	48506
LI61731	9/5/2019	Lead				0	Copper				0	2418	DAKOTA	FLINT	48506
LI81381	12/5/2019	Lead				0	Copper				0	1432	DAKOTA AVE	FLINT	48506
LI81382	12/5/2019	Lead				0	Copper				0	1432	DAKOTA AVE	FLINT	48506
LI81387	12/5/2019	Lead				0	Copper				0	1627	DAKOTA AVE	FLINT	48506
LI81388	12/5/2019	Lead				0	Copper				0	1627	DAKOTA AVE	FLINT	48506
LI60767	8/30/2019	Lead	0	0	0		Copper	0	0	0		3525	DAVISON RD	FLINT	48506
LI81401	12/5/2019	Lead				0	Copper				0	501	DELL AVE	FLINT	48507
LI81402	12/5/2019	Lead				0	Copper				0	501	DELL AVE	FLINT	48507
LI69305	10/4/2019	Lead	2	1	1		Copper	0	60	0		819	DUPONT ST	FLINT	48507
LI83058	12/12/2019	Lead				0	Copper				0	133	E BAKER	FLINT	48505
LI83059	12/12/2019	Lead				0	Copper				0	133	E BAKER	FLINT	48505
LI79284	11/22/2019	Lead	0	39	29		Copper	0	0	0		2520	E COURT ST	FLINT	48503
LI83034	12/12/2019	Lead				0	Copper				0	437	E DARTMOUTH	FLINT	48505
LI83035	12/12/2019	Lead				0	Copper				0	437	E DARTMOUTH	FLINT	48505
LI84905	12/19/2019	Lead				0	Copper				0	729	E LORADO	FLINT	48503
LI84906	12/19/2019	Lead				0	Copper				60	729	E LORADO	FLINT	48505
LI83046	12/12/2019	Lead				0	Copper				0	905	E MCCLELLAN	FLINT	48505
LI83047	12/12/2019	Lead				1	Copper				0	905	E MCCLELLAN	FLINT	48505
LI48051	7/3/2019	Lead	7	13	12		Copper	0	0	0		1000	E SEVENTH ST	FLINT	48503
LI70846	10/15/2019	Lead	0	0	0		Copper	0	0	0		165	E STEWART AVE	FLINT	48505
LI80824	12/3/2019	Lead	0	0	0		Copper	0	0	0		6217	EAGLE RIDGE LN	FLINT	48505
LI65359	9/19/2019	Lead				0	Copper				0	1408	EARLMOOR	FLINT	48506
LI65360	9/19/2019	Lead				0	Copper				0	1408	EARLMOOR	FLINT	48506
LI52840	7/30/2019	Lead	2	2	2		Copper	0	0	0		917	EAST FORK DR	FLINT	48503
LI48052	7/3/2019	Lead	0	0	0		Copper	200	180	190		910	EAST GILLISPIE AVE	FLINT	48505
LI76231	11/8/2019	Lead	0	0	0		Copper	0	0	0		830	EDMUND ST	FLINT	48505
LI72874	10/25/2019	Lead	0	0	0		Copper	0	0	0		217	FLINT DRIVE	FLINT	48505
LI66043	9/20/2019	Lead	0	0	0		Copper	0	0	0		721	FLORAL PARK AVE	FLINT	48503
LI83036	12/12/2019	Lead				0	Copper				0	1610	FOREST HILL	FLINT	48504
LI83037	12/12/2019	Lead				0	Copper				0	1610	FOREST HILL	FLINT	48504
LI62162	9/6/2019	Lead	0	0	0		Copper	0	0	0		2762	GOLFSIDE LN	FLINT	48504
LI79285	11/22/2019	Lead	0	0	0		Copper	0	0	0		1714	GREENBROOK LANE	FLINT	48507
LI60766	8/30/2019	Lead	2	0	0		Copper	0	0	0		2031	HAMPDEN ROAD	FLINT	48503

**Flint Residential Testing Report - results collected July 1, 2019 through December 19, 2019**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LI57144	8/16/2019	Lead	0	0	0		Copper	0	0	0		3023	HELBER	FLINT	48504
LI65355	9/19/2019	Lead				0	Copper				0	2033	HOFF ST	FLINT	48506
LI65356	9/19/2019	Lead				0	Copper				0	2033	HOFF ST	FLINT	48506
LI83038	12/12/2019	Lead				0	Copper				80	526	HURLEY	FLINT	48505
LI83039	12/12/2019	Lead				66	Copper				180	526	HURLEY	FLINT	48505
LI83044	12/12/2019	Lead				0	Copper				0	530	HURLEY	FLINT	48505
LI83045	12/12/2019	Lead				2	Copper				0	530	HURLEY	FLINT	48503
LI49911	7/16/2019	Lead	0	0	0		Copper	0	0	0		1320	IDA ST	FLINT	48503
LI62915	9/10/2019	Lead	10	9	9		Copper	0	0	0		1917	JOLIET ST	FLINT	48504
LI63606	9/12/2019	Lead				0	Copper				0	2301	KANSAS	FLINT	48506
LI63607	9/12/2019	Lead				0	Copper				0	2301	KANSAS	FLINT	48506
LI66044	9/20/2019	Lead	0	0	0		Copper	0	0	0		1805	KANSAS AVE	FLINT	48506
LI72873	10/25/2019	Lead	2	2	2		Copper	0	0	0		1309	KEARSLEY PARK BLVD	FLINT	48503
LI83056	12/12/2019	Lead				0	Copper				0	1539	KEARSLEY PARK BLVD	FLINT	48506
LI83057	12/12/2019	Lead				0	Copper				0	1539	KEARSLEY PARK BLVD	FLINT	48506
LI61023	9/3/2019	Lead	0	2	2		Copper	70	0	0		1702	KENWOOD	FLINT	48506
LI65365	9/19/2019	Lead				0	Copper				0	1412	KIRK AVE	FLINT	48503
LI65366	9/19/2019	Lead				0	Copper				0	1412	KIRK AVE	FLINT	48503
LI84903	12/19/2019	Lead				1	Copper				0	1710	KNAPP	FLINT	48507
LI84904	12/19/2019	Lead				2	Copper				0	1710	KNAPP	FLINT	48503
LI84893	12/19/2019	Lead				0	Copper				0	1301	LAPEER	FLINT	48503
LI84894	12/19/2019	Lead				0	Copper				0	1301	LAPEER	FLINT	48503
LI57138	8/16/2019	Lead	0	0	0		Copper	0	0	0		3621	LARCHMONT ST	FLINT	48532
LI61738	9/5/2019	Lead				0	Copper				0	714	LELAND	FLINT	48507
LI61739	9/5/2019	Lead				0	Copper				0	714	LELAND	FLINT	48507
LI63618	9/12/2019	Lead				0	Copper				0	1706	LEVERN ST	FLINT	48506
LI63619	9/12/2019	Lead				0	Copper				0	1706	LEVERN ST	FLINT	48506
LI61744	9/5/2019	Lead				0	Copper				0	1718	LEVERN ST	FLINT	48506
LI61745	9/5/2019	Lead				0	Copper				0	1718	LEVERN ST	FLINT	48506
LI81397	12/5/2019	Lead				0	Copper				0	919	LEXINGTON	FLINT	48507
LI81398	12/5/2019	Lead				0	Copper				0	919	LEXINGTON	FLINT	48507
LI61740	9/5/2019	Lead				0	Copper				0	742	LINCOLN	FLINT	48507
LI61741	9/5/2019	Lead				0	Copper				0	742	LINCOLN	FLINT	48507
LI53573	8/2/2019	Lead	0	0	0		Copper	0	0	0		2009	LINCOLN DR	FLINT	48503
LI83060	12/12/2019	Lead				1	Copper				0	113	LINSEY	FLINT	48507
LI83061	12/12/2019	Lead				4	Copper				0	113	LINSEY	FLINT	48503
LI83050	12/12/2019	Lead				0	Copper				0	217	LINSEY	FLINT	48503
LI83051	12/12/2019	Lead				0	Copper				0	217	LINSEY	FLINT	48503
LI48053	7/3/2019	Lead	0	0	0		Copper	140	110	120		1702	LINWOOD	FLINT	48503
LI64621	9/17/2019	Lead	0	0	0		Copper	0	0	0		410	LIPPINCOTT BLVD APT 14	FLINT	48503
LI83049	12/12/2019	Lead				3	Copper				0	629	LOCHHEAD	FLINT	48507
LI83048	12/12/2019	Lead				4	Copper				0	629	LOCHHEAD	FLINT	48503
LI71390	10/18/2019	Lead	0	0	0		Copper	0	0	0		1905	LYNBROOK DR	FLINT	48507
LI71756	10/22/2019	Lead	0	0	0		Copper	0	0	0		1905	LYNBROOK DR	FLINT	48507
LI62163	9/6/2019	Lead	0	0	0		Copper	0	0	0		3433	LYNN ST	FLINT	48503
LI63598	9/12/2019	Lead				3	Copper				0	1918	M L KING	FLINT	48503
LI63599	9/12/2019	Lead				4	Copper				0	1918	M L KING	FLINT	48503
LI54256	8/6/2019	Lead	0	0	0		Copper	0	0	0		5710	MARJA ST	FLINT	48505
LI61736	9/5/2019	Lead				0	Copper				0	2405	MARYLAND	FLINT	48506
LI61737	9/5/2019	Lead				0	Copper				0	2405	MARYLAND	FLINT	48506

**Flint Residential Testing Report - results collected July 1, 2019 through December 19, 2019**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LI65357	9/19/2019	Lead				0	Copper				60	1313	MCINTOSH	FLINT	48503
LI65358	9/19/2019	Lead				0	Copper				50	1313	MCINTOSH	FLINT	48503
LI63582	9/12/2019	Lead				0	Copper				0	517	MCKEIGHAN AVE	FLINT	48507
LI63583	9/12/2019	Lead				0	Copper				0	517	MCKEIGHAN AVE	FLINT	48507
LI82360	12/10/2019	Lead	2	10	8		Copper	60	180	150		3106	MENOMINEE AVE	FLINT	48504
LI64624	9/17/2019	Lead	0	0	0		Copper	0	0	0		3014	MONTANA AVE	FLINT	48506
LI84900	12/19/2019	Lead				2	Copper				0	1918	MONTCLAIR	FLINT	48503
LI84899	12/19/2019	Lead				5	Copper				0	1918	MONTCLAIR	FLINT	48503
LI63602	9/12/2019	Lead				0	Copper				0	2815	N AVERILL AVE	FLINT	48506
LI63603	9/12/2019	Lead				0	Copper				0	2815	N AVERILL AVE	FLINT	48506
LI57140	8/16/2019	Lead	0	0	0		Copper	0	0	0		772	N CHEVROLET AVE	FLINT	48504
LI58975	8/23/2019	Lead	0	0	0		Copper	0	0	0		2602	N CHEVROLET AVE	FLINT	48504
LI65353	9/19/2019	Lead				0	Copper				0	2914	N DEXTER ST	FLINT	48506
LI65354	9/19/2019	Lead				0	Copper				0	2914	N DEXTER ST	FLINT	48506
LI61734	9/5/2019	Lead				0	Copper				0	2518	N VERNON AVE	FLINT	48506
LI61735	9/5/2019	Lead				0	Copper				0	2518	N VERNON AVE	FLINT	48506
LI63610	9/12/2019	Lead				0	Copper				0	714	NEUBERT AVE	FLINT	48507
LI63611	9/12/2019	Lead				0	Copper				0	714	NEUBERT AVE	FLINT	48507
LI65363	9/19/2019	Lead				0	Copper				0	2262	NOLEN DR	FLINT	48504
LI65364	9/19/2019	Lead				0	Copper				0	2262	NOLEN DR	FLINT	48504
LI63574	9/12/2019	Lead				0	Copper				0	2912	OKLAHOMA AVE	FLINT	48506
LI63575	9/12/2019	Lead				0	Copper				0	2912	OKLAHOMA AVE	FLINT	48506
LI63578	9/12/2019	Lead				0	Copper				0	2928	OKLAHOMA AVE	FLINT	48506
LI63579	9/12/2019	Lead				0	Copper				0	2928	OKLAHOMA AVE	FLINT	48506
LI61022	9/3/2019	Lead	0	0	0		Copper	0	0	0		1722	PARKFRONT	FLINT	48504
LI71755	10/22/2019	Lead	0	2	2		Copper	0	0	0		3601	PENBROKE LN APT #18	FLINT	48504
LI63622	9/12/2019	Lead				0	Copper				0	4229	PENGELLY RD	FLINT	48507
LI63623	9/12/2019	Lead				0	Copper				0	4229	PENGELLY RD	FLINT	48507
LI62914	9/10/2019	Lead	7	2	3		Copper	70	0	0		1640	PENNSYLVANIA AVE	FLINT	48503
LI79286	11/22/2019	Lead	0	0	0		Copper	0	0	0		2025	PIERCE ST	FLINT	48503
LI49418	7/12/2019	Lead	0	0	0		Copper	0	0	0		3618	PINGREE AVE	FLINT	48503
LI49910	7/16/2019	Lead	1	0	0		Copper	0	0	0		3205	PROCTOR AVE	FLINT	48503
LI84897	12/19/2019	Lead				0	Copper				0	2017	PROSPECT	FLINT	48507
LI84898	12/19/2019	Lead				0	Copper				0	2017	PROSPECT	FLINT	48502
LI49909	7/16/2019	Lead	0	0	0		Copper	0	0	0		2320	RADCLIFFE AVE	FLINT	48503
LI50792	7/19/2019	Lead	4	7	6		Copper	140	180	170		2617	RASKOB ST	FLINT	48506
LI63608	9/12/2019	Lead				0	Copper				0	4426	RED ARROW RD	FLINT	48507
LI63609	9/12/2019	Lead				0	Copper				0	4426	RED ARROW RD	FLINT	48507
LI48606	7/9/2019	Lead	0	0	0		Copper	0	0	0		2434	REID STREET	FLINT	48503
LI52385	7/29/2019	Lead	0	0	0		Copper	0	0	0		3419	ROBIN ST	FLINT	48505
LI69768	10/8/2019	Lead	0	0	0		Copper	0	0	0		1837	ROCKCREEK LANE	FLINT	48507
LI52386	7/29/2019	Lead	0	0	0		Copper	70	0	0		1069	RONALD ST	FLINT	48507
LI57141	8/16/2019	Lead	0	0	0		Copper	0	0	0		620	ROOME COURT	FLINT	0
LI63592	9/12/2019	Lead				0	Copper				0	622	RUTH AVE	FLINT	48505
LI63593	9/12/2019	Lead				0	Copper				0	622	RUTH AVE	FLINT	48505
LI76232	11/8/2019	Lead	0	0	0		Copper	0	0	0		1802	S DORT HWY	FLINT	48503
LI68176	9/27/2019	Lead	2	1	1		Copper	150	50	80		711	S SAGINAW ST	FLINT	48507
LI57816	8/20/2019	Lead	3	2	2		Copper	0	0	0		711	S SAGINAW ST	FLINT	48505
LI71391	10/18/2019	Lead	0	0	0		Copper	0	0	0		2318	SANTA BARBARA DRIVE	FLINT	48504
LI63612	9/12/2019	Lead				0	Copper				0	2055	SEYMOUR AVE	FLINT	48503

Flint Residential Testing Report - results collected July 1, 2019 through December 19, 2019

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LI63613	9/12/2019	Lead				0	Copper				0	2055	SEYMOUR AVE	FLINT	48503
LI49419	7/12/2019	Lead	0	0	0		Copper	0	0	0		831	SIMCOE	FLINT	48507
LI68177	9/27/2019	Lead	0	0	0		Copper	0	0	0		1236	SOMERSET LANE	FLINT	48503
LI83318	12/13/2019	Lead	0	0	0		Copper	0	0	0		416	SPENCER ST	FLINT	48504
LI64623	9/17/2019	Lead	0	0	0		Copper	0	0	0		2019	STONE BROOK CT	FLINT	48507
LI57817	8/20/2019	Lead	0	0	0		Copper	60	70	70		4264	SUGAR MAPLE RUN	FLINT	48506
LI71392	10/18/2019	Lead	0	0	0		Copper	80	0	0		2310	SWAYZE ST	FLINT	48503
LI61742	9/5/2019	Lead				0	Copper				0	2102	THOM ST	FLINT	48506
LI61743	9/5/2019	Lead				0	Copper				0	2102	THOM ST	FLINT	48506
LI58974	8/23/2019	Lead	0	0	0		Copper	0	0	0		501	THOMSON ST APT 3	FLINT	48503
LI68179	9/27/2019	Lead	2	0	0		Copper	0	0	0		702	THOMSON ST APT 5	FLINT	48504
LI68596	10/1/2019	Lead	0	0	0		Copper	0	0	0		2530	TIFFIN ST	FLINT	48504
LI49416	7/12/2019	Lead	3	0	0		Copper	100	0	0		2207	TROUT DR	FLINT	48505
LI80449	11/27/2019	Lead	0	0	0		Copper	0	0	0		4509	TRUMBULL DR	FLINT	48504
LI65349	9/19/2019	Lead				0	Copper				0	3914	TUXEDO	FLINT	48507
LI65350	9/19/2019	Lead				0	Copper				0	3914	TUXEDO	FLINT	48507
LI71753	10/22/2019	Lead	0	3	2		Copper	0	0	0		3701	VAN BUREN AVE BLDG A EXISTING	FLINT	48505
LI71757	10/22/2019	Lead	0	0	0		Copper	0	0	0		3701	VAN BUREN AVE BLDG B NEW BLDG	FLINT	48503
LI84886	12/19/2019	Lead				0	Copper				0	836	VICTORIA	FLINT	48504
LI84885	12/19/2019	Lead				1	Copper				0	836	VICTORIA	FLINT	48503
LI63584	9/12/2019	Lead				0	Copper				0	653	VICTORIA AVE	FLINT	48506
LI63585	9/12/2019	Lead				0	Copper				0	653	VICTORIA AVE	FLINT	48506
LI63594	9/12/2019	Lead				0	Copper				0	715	VICTORIA AVE	FLINT	48505
LI63595	9/12/2019	Lead				0	Copper				0	715	VICTORIA AVE	FLINT	48505
LI65352	9/19/2019	Lead				0	Copper				0	1738	VINCENT AVE	FLINT	48503
LI65351	9/19/2019	Lead				1	Copper				0	1738	VINCENT AVE	FLINT	48502
LI65361	9/19/2019	Lead				4	Copper				370	1025	W 12TH ST	FLINT	48503
LI65362	9/19/2019	Lead				7	Copper				50	1025	W 12TH ST	FLINT	48506
LI61728	9/5/2019	Lead				0	Copper				0	1038	W 12TH ST	FLINT	48507
LI61729	9/5/2019	Lead				0	Copper				0	1038	W 12TH ST	FLINT	48507
LI57139	8/16/2019	Lead	15	3	6		Copper	0	0	0		1323	W 2ND ST	FLINT	48503
LI83040	12/12/2019	Lead				0	Copper				0	401	W BAKER	FLINT	48505
LI83041	12/12/2019	Lead				0	Copper				0	401	W BAKER	FLINT	48505
LI68594	10/1/2019	Lead	0	0	0		Copper	0	0	0		115	W BAKER ST	FLINT	48505
LI84891	12/19/2019	Lead				0	Copper				0	2465	W COURT	FLINT	48503
LI84892	12/19/2019	Lead				0	Copper				0	2465	W COURT	FLINT	48504
LI82361	12/10/2019	Lead	0	0	0		Copper	0	50	0		3615	W COURT ST	FLINT	48532
LI83043	12/12/2019	Lead				3	Copper				0	417	W DAYTON	FLINT	48507
LI83042	12/12/2019	Lead				177	Copper				80	417	W DAYTON	FLINT	48505
LI51369	7/23/2019	Lead	0	0	0		Copper	70	90	90		132	W LAKEVIEW AVE	FLINT	48503
LI69306	10/4/2019	Lead	2	0	0		Copper	0	0	0		814	W MCCLELLAN ST	FLINT	48507
LI59453	8/27/2019	Lead	0	0	0		Copper	0	0	0		906	W MONROE	FLINT	48504
LI80825	12/3/2019	Lead	0	0	0		Copper	0	0	0		414	W PIERSON RD	FLINT	48505
LI63604	9/12/2019	Lead				0	Copper				0	618	W RUTH AVE	FLINT	48505
LI63605	9/12/2019	Lead				0	Copper				0	618	W RUTH AVE	FLINT	48505
LI63576	9/12/2019	Lead				0	Copper				0	125	W STEWART AVE	FLINT	48505
LI63577	9/12/2019	Lead				0	Copper				0	125	W STEWART AVE	FLINT	48505
LI84889	12/19/2019	Lead				0	Copper				0	134	W WITHERBEE	FLINT	48503
LI84890	12/19/2019	Lead				0	Copper				0	134	W WITHERBEE	FLINT	48505
LI63620	9/12/2019	Lead				0	Copper				0	1418	WALDMAN AVE	FLINT	48507

**Flint Residential Testing Report - results collected July 1, 2019 through December 19, 2019**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LI63621	9/12/2019	Lead				0	Copper				0	1418	WALDMAN AVE	FLINT	48507
LI79283	11/22/2019	Lead	0	0	0		Copper	0	0	0		1524	WAYNE STREET	FLINT	48503
LI68175	9/27/2019	Lead	0	0	0		Copper	0	0	0		6732	WEBSTER	FLINT	48505
LI49912	7/16/2019	Lead	0	0	0		Copper	0	0	0		4302	WESTERN RD LOT 69	FLINT	48506
LI61021	9/3/2019	Lead	0	0	0		Copper	60	0	0		3301	WESTWOOD PKWY	FLINT	48503
LI52387	7/29/2019	Lead	0	0	0		Copper	0	0	0		806	WILBERFORCE FLINT	FLINT	48503
LI58973	8/23/2019	Lead	0	0	0		Copper	70	70	70		709	WILBERFORCE LN	FLINT	48503
LI70845	10/15/2019	Lead	0	0	0		Copper	0	0	0		5710	WINTHROP BLVD	FLINT	48505
LI68178	9/27/2019	Lead	0	0	0		Copper	0	0	0		4419	WISNER ST	FLINT	48502
LI61732	9/5/2019	Lead				0	Copper				0	2521	WOODROW AVE	FLINT	48506
LI61733	9/5/2019	Lead				0	Copper				0	2521	WOODROW AVE	FLINT	48506
LI55424	8/9/2019	Lead	0	0	0		Copper	80	110	100		1821	WOODSLEA DR	FLINT	48507
LI57142	8/16/2019	Lead	1	1	1		Copper	60	0	0		1634	WYOMING AVE	FLINT	48507

Notes:

ppb = parts per billion

Lead values exceeding 15 ppb and Copper results exceeding 1,300 are highlighted in red.

Sample results of "Not Detected" have been replaced with a numerical value of zero for ease of sorting.

Samples without a zip code did not have one provided on the accompanying paperwork.

\*\*\* indicate Invalid Zip Code