

Flint Residential Testing Report - results collected January 01, 2021 through February 12, 2021

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ44327	2/8/2021	Lead				0	Copper				0	726	BEACH ST	FLINT	48504
LJ44328	2/8/2021	Lead				0	Copper				0	726	BEACH ST	FLINT	48507
LJ44160	2/5/2021	Lead	2	2	2		Copper	0	0	0		1901	BEGOLE ST	FLINT	48506
LJ42653	1/26/2021	Lead	0	0	0		Copper	0	0	0		1937	BURR BLVD	FLINT	48503
LJ41154	1/14/2021	Lead	0				Copper	0				1100	CEDAR STREET	FLINT	48503
LJ41151	1/14/2021	Lead	0				Copper	110				5018	CLIO ROAD	FLINT	48504
LJ41147	1/14/2021	Lead	0				Copper	0				3521	CORUNNA ROAD	FLINT	48503
LJ44335	2/8/2021	Lead				0	Copper				0	506	CRAPO	FLINT	48504
LJ44336	2/8/2021	Lead				0	Copper				0	506	CRAPO	FLINT	48504
LJ44540	2/9/2021	Lead	0	0	0		Copper	60	0	0		3514	DALE AVE	FLINT	48503
LJ44874	2/12/2021	Lead				0	Copper				0	2100	DAVISON	FLINT	48505
LJ44875	2/12/2021	Lead				0	Copper				0	2100	DAVISON	FLINT	48503
LJ41156	1/14/2021	Lead	0				Copper	0				3802	DAVISON ROAD	FLINT	48506
LJ44331	2/8/2021	Lead				0	Copper				0	713	DICKINSON	FLINT	48502
LJ44332	2/8/2021	Lead				0	Copper				0	713	DICKINSON	FLINT	48502
LJ44329	2/8/2021	Lead				0	Copper				0	726	DICKINSON	FLINT	48504
LJ44330	2/8/2021	Lead				0	Copper				0	726	DICKINSON	FLINT	48504
LJ41153	1/14/2021	Lead	0				Copper	0				1416	DUPONT STREET	FLINT	48503
LJ43057	1/28/2021	Lead				1	Copper				0	410	E COURT	FLINT	48505
LJ43056	1/28/2021	Lead				2	Copper				110	410	E COURT	FLINT	48505
LJ41149	1/14/2021	Lead	0				Copper	0				2838	E COURT ST	FLINT	48506
LJ44864	2/12/2021	Lead				0	Copper				0	721	E HOLBROOK AVE	FLINT	48506
LJ44865	2/12/2021	Lead				0	Copper				0	721	E HOLBROOK AVE	FLINT	48506
LJ44867	2/12/2021	Lead				2	Copper				0	754	E LYNDON	FLINT	48506
LJ44866	2/12/2021	Lead				19	Copper				180	754	E LYNDON	FLINT	48507
LJ44869	2/12/2021	Lead				0	Copper				0	330	E PHILADELPHIA BLVD	FLINT	48505
LJ44870	2/12/2021	Lead				0	Copper				0	330	E PHILADELPHIA BLVD	FLINT	48505
LJ41150	1/14/2021	Lead	0				Copper	0				2501	FLUSHING ROAD	FLINT	48504
LJ44325	2/8/2021	Lead				0	Copper				0	713	FRANK ST	FLINT	48506
LJ44326	2/8/2021	Lead				0	Copper				0	713	FRANK ST	FLINT	48504
LJ40584	1/12/2021	Lead	0	0	0		Copper	0	0	0		4815	GLENN AVE	FLINT	48505
LJ44876	2/12/2021	Lead				0	Copper				0	3222	GRAND TRAVERSE	FLINT	48505
LJ44877	2/12/2021	Lead				0	Copper				0	3222	GRAND TRAVERSE	FLINT	48505
LJ40583	1/12/2021	Lead	0	0	0		Copper	0	0	0		4702	GREENLAWN	FLINT	48504
LJ44861	2/12/2021	Lead				0	Copper				0	810	HOLBROOK	FLINT	48506
LJ44862	2/12/2021	Lead				0	Copper				0	810	HOLBROOK	FLINT	48503
LJ42654	1/26/2021	Lead	0	0	0		Copper	90	0	0		2010	HOWARD AVE	FLINT	48503
LJ44902	2/12/2021	Lead	0	0	0		Copper	0	0	0		1401	IDA	FLINT	48505
LJ44541	2/9/2021	Lead	3	0	0		Copper	280	130	170		921	KENNELWORTH AVE	FLINT	48507
LJ44339	2/8/2021	Lead				0	Copper				0	1425	KNIGHT	FLINT	48503
LJ44340	2/8/2021	Lead				0	Copper				0	1425	KNIGHT	FLINT	48503
LJ43062	1/28/2021	Lead				0	Copper				0	1361	LAPEER	FLINT	48503
LJ43063	1/28/2021	Lead				0	Copper				0	1361	LAPEER	FLINT	48503
LJ44859	2/12/2021	Lead				0	Copper				70	2301	LEVERN	FLINT	48503
LJ44860	2/12/2021	Lead				0	Copper				0	2301	LEVERN	FLINT	48503

Flint Residential Testing Report - results collected January 01, 2021 through February 12, 2021

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ44337	2/8/2021	Lead				0	Copper				0	916	MANN	FLINT	48503
LJ44338	2/8/2021	Lead				0	Copper				0	916	MANN	FLINT	48503
LJ44858	2/12/2021	Lead				0	Copper				0	924	MCQUEEN	FLINT	48503
LJ44868	2/12/2021	Lead				0	Copper				0	924	MCQUEEN	FLINT	48505
LJ41592	1/19/2021	Lead	0	0	0		Copper	0	0	0		4518	MILTON DR	FLINT	48507
LJ43060	1/28/2021	Lead				0	Copper				0	3318	MLK	FLINT	48505
LJ43061	1/28/2021	Lead				0	Copper				0	3318	MLK	FLINT	48505
LJ41155	1/14/2021	Lead	0				Copper	0				3317	MLK AVE	FLINT	48505
LJ44871	2/12/2021	Lead				0	Copper				0	5101	N SAGINAW ST	FLINT	48505
LJ44872	2/12/2021	Lead				0	Copper				0	5101	N SAGINAW ST	FLINT	48505
LJ41157	1/14/2021	Lead	0				Copper	0				4500	NORTH DORT HWY	FLINT	48505
LJ44159	2/5/2021	Lead	0	0	0		Copper	60	0	0		3131	PROSPECT ST	FLINT	48503
LJ43058	1/28/2021	Lead				0	Copper				0	520	S GRAND TRAVERSE	FLINT	48502
LJ43059	1/28/2021	Lead				0	Copper				0	520	S GRAND TRAVERSE	FLINT	48502
LJ41152	1/14/2021	Lead	0				Copper	0				6509	SAGINAW ST	FLINT	48505
LJ44863	2/12/2021	Lead				0	Copper				0	5309	SELBY ST	FLINT	48503
LJ44873	2/12/2021	Lead				0	Copper				0	5309	SELBY ST	FLINT	48505
LJ41148	1/14/2021	Lead	0				Copper	0				3302	SOUTH DORT HIGHWAY	FLINT	48505
LJ40585	1/12/2021	Lead	31	14	18		Copper	980	960	960		3616	SUNRIDGE DR	FLINT	48203
LJ44333	2/8/2021	Lead				0	Copper				0	426	W 1ST AVE	FLINT	48504
LJ44334	2/8/2021	Lead				0	Copper				60	426	W 1ST AVE	FLINT	48504
LJ43064	1/28/2021	Lead				0	Copper				0	2201	W COURT	FLINT	48503
LJ43065	1/28/2021	Lead				0	Copper				0	2201	W COURT	FLINT	48503
LJ44161	2/5/2021	Lead	0	0	0		Copper	0	0	0		1309	WALDMAN AVE	FLINT	48503

Notes:

ppb = parts per billion

Lead values exceeding 15 ppb and Copper results exceeding 1,300 are highlighted in red.

Sample results of "Not Detected" have been replaced with a numerical value of zero for ease of sorting.

Samples without a zip code did not have one provided on the accompanying paperwork.

*** indicate Invalid Zip Code