

Flint Safe Drinking Water Task Force – Use of Widemouthed Bottles

This response is intended to identify how the comments received from the Flint Safe Drinking Water Task Force have been addressed.

Michigan has moved to the use of widemouthed 1-liter sample bottles for the analysis of any lead water sample taken from a home and for the Lead and Copper Rule compliance monitoring program.