



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EwDM week ending

3/17/2021


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Signature] Date: 3/18/21



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS												**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Address	Name & Address	Sample date	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L P14)	Sample date	Lead (µg/L Pb)
#12 **	Woodsdale Church 503 Birchard		3/11/2021	cdp	4.1	0.23	7.48	80	28.1	102	0.157	0.03	15	18	3.25		ND
#14 (1)	Admiral Base Station 3802 Davison Rd.		3/17/2021	cdp	6.2	0.22	7.30	84	28.9	102	0.055	0.00	15	17	3.40	3/10/2021, 3/3/2021	ND
#16 (2)	Rite - Aid 2838 E Court St		3/12/2021	bp	5.6	0.23	7.62	82	28.9	106	0.046	0.01	15	16	3.41	3/5/2021, 2/26/2021	ND
#16 (2)	Rite - Aid 2838 E Court St		3/17/2021	cdp	5.5	0.22	7.41	82	28.9	104	0.065	0.01	15	18	3.50	*	
#17 (3)	Liquor Palace 3302 S. Dort Hwy		3/12/2021	bp	7.1	0.23	7.58	86	28.1	106	0.056	0.02	15	17	3.53	3/5/2021, 2/26/2021	ND
#17 (3)	Liquor Palace 3302 S. Dort Hwy		3/17/2021	cdp	6.0	0.22	7.47	82	28.9	104	0.133	0.02	14	18	3.39	*	
#4	Rite - Aid 3816 Darvina Rd.		3/11/2021	cdp	4.9	0.23	7.43	76	28.9	104	0.071	0.04	15	22	3.41	3/4/2021, 2/25/2021	ND
#4	Rite - Aid 3806 Darvina Rd.		3/15/2021	cdp	5.8	0.24	7.36	84	28.1	100	0.060	0.02	15	19	3.35	*	
#1 (5)	University Market 1059 Chevrolet Ave.		3/11/2021	cdp	5.2	0.23	7.43	80	28.9	102	0.084	0.02	15	19	3.41	3/4/2021, 2/25/2021	ND
#1 (5)	University Market 1059 Chevrolet Ave.		3/15/2021	cdp	7.1	0.23	7.31	80	27.3	102	0.105	0.03	15	21	3.51	*	
#19 B (6)	3317 MLK Blvd.		3/12/2021	bp	7.3	0.23	7.52	84	28.1	104	0.067	0.02	14	18	3.39	3/5/2021, 2/26/2021	ND
#19 B (6)	3317 MLK Blvd.		3/17/2021	cdp	6.0	0.22	7.47	84	28.1	106	0.060	0.02	15	16	3.38	*	
#19 (7)	Rite-Aid 5008 Elm Rd. 46504		3/16/2021	cdp	9.3	0.23	7.47	82	28.1	104	0.068	0.01	14	17	3.41	3/9/2021, 3/2/2021	ND
#8	BSOB N. Saginaw St.		3/16/2021	cdp	6.0	0.22	7.51	82	29.7	104	0.048	0.01	15	19	3.54	3/9/2021, 3/02/2021	ND
CSII	Control Station #2 4600 N. Dort Hwy.		3/16/2021	cdp	7.3	0.23	7.29	74	28.1	102	0.068	0.01	15	15	1.19	3/9/2021, 3/2/2021	ND
#5 (CS)	Center Street Reservoir- 8 Pump Station		3/11/2021	cdp	5.8	0.22	7.46	82	28.9	102	0.092	0.01	14	20	3.47	3/4/2021, 2/25/2021	ND
#5 (CS)	Center Street Reservoir- 8 Pump Station		3/15/2021	cdp	5.8	0.24	7.28	84	28.1	100	0.065	0.05	14	19	3.44	*	
#11	West Side Res 1461 Dupont St		3/16/2021	cdp	7.1	0.24	7.47	84	29.7	106	0.077	0.03	15	20	3.42	3/9/2021, 3/2/2021	ND