Department of Utilities

FLINT WATER PLANT

F&V operations and resource management

The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

_____

_____EWDM Week ending 4/28/2021_____

_____

_____

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: Scott Dungee_____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: _____ Date: 5/2/2021_____

FLINT WATER PLANT & FACILITIES

WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS											**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Name & Address	Sample date	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl⁻)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)
#12 **	Woodside Church 503 Garland															
#14 (1)	Admiral Gas Station 3802 Davison Rd.	4/28/2021	cdp	11.0	0.22	7.51	82	28.1	98	0.071	0.02	13	17	3.42	4/21/21	ND
#16 (2)	Rite - Aid 2838 E Court St	4/23/2021	bp	12.2	0.22	7.52	78	27.3	102	0.158	0.03	16	16	3.38	4/16/21	ND
#16 (2)	Rite - Aid 2838 E Court St	4/28/2021	cdp	10.8	0.22	7.51	82	28.9	98	0.131	0.04	14	20	3.42	*	
#17 (3)	Liquor Palace 3302 S dort hwy	4/23/2021	bp	10.4	0.22	7.51	82	28.9	100	0.112	0.02	15	11	3.53	4/16/21	ND
#17 (3)	Liquor Palace 3302 S. Dort Hwy	4/28/2021	cdp	10.2	0.22	7.47	82	28.1	98	0.063	0.01	13	19	3.40	*	
#4	Rite - Aid 3608 Corunna Rd.	4/22/2021	cdp	9.9	0.22	7.49	82	28.1	98	0.080	0.02	14	19	3.50	4/15/21	ND
#4	Rite - Aid 3608 Corunna Rd.	4/26/2021	cdp	10.2	0.22	7.49	82	28.1	100	0.063	0.01	14	9	3.41	*	
#1 (5)	University Market 1069 Chevrolet Ave.	4/22/2021	cdp	10.9	0.22	7.48	80	28.9	100	0.081	0.01	15	15	3.52	4/15/21	ND
#1 (5)	University Market 1069 Chevrolet Ave.	4/26/2021	cdp	10.6	0.22	7.53	82	28.1	96	0.082	0.01	13	15	3.48	*	
#19 B (6)	3317 MLK Blvd.	4/23/2021	bp	16.4	0.22	7.51	80	28.9	102	0.054	0.05	16	11	3.46	4/16/21	ND
#19 B (6)	3317 MLK Blvd.	4/28/2021	cdp	12.9	0.23	7.54	80	28.1	98	0.056	0.02	13	17	3.39	*	
#9 (7)	Rite-Aid 5018 Clio Rd. 48504	4/27/2021	cdp	12.4	0.22	7.53	82	27.3	98	0.069	0.01	14	13	3.35	4/20/21	ND
#8B	6509 N. Saginaw St.	4/27/2021	cdp	9.3	0.22	7.63	82	28.1	100	0.168	0.01	15	15	3.46	4/20/21	ND
CSII	Control Station #2 4500 N. Dort Hwy.	4/27/2021	cdp	9.4	0.19	7.28	76	28.9	100	0.159	0.00	15	12	1.26	4/20/21	ND
#5 (CS)	Cedar Street Reservoir & Pump Station	4/22/2021	cdp	8.9	0.22	7.52	80	28.9	100	0.396	0.05	14	18	3.69	4/15/21	ND
#5 (CS)	Cedar Street Reservoir & Pump Station	4/26/2021	cdp	15.6	0.23	7.56	80	27.3	100	0.120	0.02	13	11	3.40		
#11	West Side Res 1416 Dupont St	4/27/2021	cdp	10.9	0.23	7.45	80	27.3	98	0.158	0.02	13	9	3.54	4/20/21	ND