



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM week ending 5/5/21 revised \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_


*"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."*

City of Flint Representative: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

F&V Operations Representative: Robert Jones \_\_\_\_\_

Signature:  \_\_\_\_\_ Date: 5/10/21



**WEEKLY ENHANCED  
WATER QUALITY PARAMETER MONITORING**

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS											**PRIOR WEEK RESULTS			
Distribution System Location #	Sample Point Address	Name B	Sample date	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl <sup>-</sup> )	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)	
#12 **	Woodside Church 513 Garfield																	ND
#14 (1)	Admiral Bass Station 3882 Dawson Rd.		5/5/2021	cdp	11.0	0.223	7.50	80	28.9	104	0.070	0.02	14	14	3.57	4/28/21	ND	
#15 (2)	Rite - Aid 2838 E Court St		4/30/2021	cdp	10.6	0.223	7.54	82	30.5	104	1.720	0.13	15	16	3.95	4/23/21	ND	
#16 (2)	Rite - Aid 2838 E Court St		5/5/2021	cdp	11.6	0.223	7.47	80	28.9	100	0.152	0.04	15	14	3.46	*	ND	
#17 (3)	Liquor Palace 3382 S. Dort Hwy		4/30/2021	cdp	10.6	0.222	7.51	78	28.9	100	0.234	0.00	14	15	3.48	4/23/21	ND	
#17 (3)	Liquor Palace 3382 S. Dort Hwy		5/5/2021	cdp	12.5	0.223	7.49	82	28.9	102	0.070	0.06	14	17	3.43	*	ND	
#4	Rite - Aid 3808 Cornelia Rd.		4/29/2021	cdp	9.8	0.223	7.37	82	28.1	102	0.085	0.02	15	16	3.43	4/22/21	ND	
#4	Rite - Aid 3808 Cornelia Rd.		5/3/2021	cdp	10.5	0.223	7.52	82	28.9	102	0.073	0.06	14	16	3.40	*	ND	
#1 (5)	University Market 1089 Chevrolet Ave.		4/29/2021	cdp	10.1	0.223	7.35	80	28.9	100	0.093	0.02	14	17	3.43	4/22/21	ND	
#1 (5)	University Market 1089 Chevrolet Ave.		5/3/2021	cdp	11.6	0.223	7.54	82	28.1	100	0.236	0.03	15	15	3.46	*	ND	
#19 B (B)	3317 MLK Blvd.		4/30/2021	cdp	12.0	0.222	7.56	80	28.9	100	0.082	0.00	14	16	3.49	4/23/21	ND	
#19 B (B)	3317 MLK Blvd.		5/5/2021	cdp	11.1	0.223	7.47	82	28.1	102	0.075	0.00	13	15	3.42	*	ND	
#9 (7)	Rite-Aid 5018 Dix Rd. 48504		5/4/2021	cdp	13.2	0.223	7.46	84	27.3	100	0.068	0.01	15	19	3.34	4/27/21	ND	
#9B	6509 N. Sibley St.		5/4/2021	cdp	12.0	0.222	7.50	84	29.7	100	0.075	0.04	15	18	3.56	4/27/21	ND	
CS11	Central Station #2 4500 N. Dort Hwy.		5/4/2021	cdp	10.7	0.222	7.30	74	28.9	102	0.071	0.07	15	15	1.22	4/27/21	ND	
#5 (CS)	Canada Street Reservoir B Pump Station		4/29/2021	cdp	8.6	0.222	7.53	80	28.9	102	0.162	0.02	14	15	3.50	4/22/21	ND	
#5 (CS)	Canada Street Reservoir B Pump Station		5/3/2021	cdp	9.5	0.222	7.59	86	28.9	100	0.095	0.00	13	16	3.47		ND	
#11	West Side Reservoir 1418 Dupont St.		5/4/2021	cdp	11.9	0.222	7.58	82	29.7	102	0.122	0.02	15	19	3.37	4/27/21	ND	

Site #19 Construction adjacent to site 4/30/21