



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM week ending 3/18/20

~~\_\_\_\_\_~~  
~~\_\_\_\_\_~~  
~~\_\_\_\_\_~~


*"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."*

City of Flint Representative: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

F&V Operations Representative: Robert Jones \_\_\_\_\_

Signature: [Handwritten Signature] Date: 3/19/20



# WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS											**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Name & Address	Sample date	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)
#14 (1)	Admiral Gas Station 3802 Davison Rd.	3/18/2020	cdp	7.5	0.23	7.54	80	27.3	98	0.108	0.04	15	17	3.43		ND
#15 (2)	Rite - Aid 2838 E Court St	3/13/2020	cdp	4.9	0.23	7.48	82	27.3	100	0.098	0.02	14	21	3.36		ND
#15 (2)	Rite - Aid 2838 E Court St	3/18/2020	cdp	5.3	0.22	7.49	82	27.3	100	0.113	0.02	15	17	3.62	*	
#17 (3)	Liquor Palace 3302 S. Dort Hwy	3/13/2020	cdp	5.5	0.23	7.45	82	28.1	100	0.077	0.01	15	21	3.40		ND
#17 (3)	Liquor Palace 3302 S. Dort Hwy	3/18/2020	cdp	5.6	0.22	7.49	80	26.5	98	0.102	0.02	14	17	3.64	*	
#4	Rite - Aid 3806 Corvuna Rd.	3/12/2020	cdp	6.2	0.23	7.46	80	25.7	96	0.095	0.00	15	20	3.53		ND
#4	Rite - Aid 3806 Corvuna Rd.	3/16/2020	cdp	6.5	0.23	7.51	82	27.3	100	0.071	0.02	15	17	3.50	*	
#1 (5)	University Market 1059 Chevrolet Ave.	3/12/2020	cdp	6.7	0.23	7.47	80	25.7	100	0.15	0.02	15	17	3.44		ND
#1 (5)	University Market 1059 Chevrolet Ave.	3/16/2020	cdp	7.3	0.23	7.53	82	27.3	100	0.113	0.00	15	17	3.40	*	
#15 (6)	Neighborhood Engagement Hub 3216 MLK Blvd.	3/13/2020	cdp	7.5	0.22	7.50	82	26.5	104	0.214	0.09	15	21	3.34		ND
#15 (6)	Neighborhood Engagement Hub 3216 MLK Blvd.														*	
#15 (7)	Rite-Aid 5018 Cliv Rd. 48514	3/17/2020	cdp	9.3	0.23	7.44	80	26.5	96	0.065	0.00	15	19	3.49		ND
#8	N. Flint Automative 8204 N. Saginaw St.	3/17/2020	cdp	9.6	0.23	7.44	80	25.7	102	0.055	0.01	15	18	3.75		ND
CSII	Central Station #2 4500 N. Dort Hwy.	3/17/2020	cdp	7.5	0.21	7.24	78	26.5	98	0.127	0.02	15	20	1.26		ND
#5 (CS)	Cedar Street Reservoir B Pump Station	3/12/2020	cdp	8.7	0.23	7.60	84	28.1	100	0.098	0.01	16	18	3.46		ND
#5 (CS)	Cedar Street Reservoir B Pump Station	3/16/2020	cdp	7.4	0.23	7.66	80	26.5	100	0.061	0.01	14	17	3.44	*	
#12	503 Garland St. Woodside CE															ND
#11	West Side Pass 1418 Durant St	3/17/2020	cdp	9.8	0.24	7.72	86	28.1	100	0.576	0.11	16	18	3.24		ND