



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWD M week ending 4/8/2020


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Handwritten Signature] Date: 4/10/2020



WEEKLY ENHANCED
WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS													**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Address	Name & #	Sample date	Teach	Temp. (°C)	Cond. (µmS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)	
#14 (1)	Admiral Bas Station 3802 Davison Rd.		4/6/2020	cdp	8.7	0.23	7.52	80	28.1	104	0.085	0.00	15	19	3.47		ND	
#16 (2)	Rite - Ad 2638 E Court St		4/3/2020	cdp	7.3	0.23	7.48	80	27.3	100	0.18	0.02	15	18	3.55		ND	
#16 (2)	Rite - Ad 2638 E Court St		4/6/2020	cdp	8.2	0.23	7.52	78	26.5	96	0.142	0.02	15	19	3.53	*	ND	
#17 (3)	Liquor Palace 3302 S. Dort Hwy		4/6/2020	cdp	7.3	0.22	7.53	82	26.5	102	0.165	0.00	16	18	3.21		ND	
#17 (3)	Liquor Palace 3302 S. Dort Hwy		4/3/2020	cdp	7.0	0.23	7.49	88	29.7	102	0.056	0.03	16	20	3.44	*	ND	
#4	Rite - Ad 3605 Conuma Rd.		4/2/2020	cdp	7.8	0.23	7.44	84	28.9	100	0.06	0.01	16	18	3.38		ND	
#4	Rite - Ad 3605 Conuma Rd.		4/6/2020	cdp	8.2	0.23	7.56	80	27.3	100	0.095	0.02	15	21	3.38	*	ND	
#1 (5)	University Market 1089 Chevrolet Ave.		4/2/2020	cdp	7.8	0.23	7.43	82	27.3	102	0.071	0.01	17	20	3.33		ND	
#1 (5)	University Market 1089 Chevrolet Ave.		4/6/2020	cdp	8.4	0.23	7.32	84	27.3	100	0.184	0.02	16	20	3.39	*	ND	
#16 (6)	3377 MAK Blvd.		4/3/2020	cdp	8.5	0.23	7.52	84	26.5	100	0.069	0.02	16	18	3.40		ND	
#16 (6)	3377 MAK Blvd.		4/6/2020	cdp	9.5	0.23	7.52	80	27.3	102	0.048	0.00	16	19	3.21	*	ND	
#9 (7)	Rite-Ad 506 Clio Rd. 48504		4/7/2020	cdp	10.3	0.23	7.45	78	27.3	108	0.046	0.01	15	18	3.45		ND	
#8	6509 N. Saginaw St.		4/7/2020	cdp	10.4	0.23	7.54	80	26.5	100	0.099	0.01	16	20	3.38		ND	
CS11	Control Station #2 4500 N. Dort Hwy.		4/7/2020	cdp	8.9	0.22	7.30	78	28.9	96	0.083	0.01	16	17	1.31		ND	
#5 (CS)	Caden Street Reservoir 8 Pump Station		4/2/2020	cdp	7.4	0.23	7.56	86	27.3	100	0.089	0.01	16	18	3.43		ND	
#5 (CS)	Caden Street Reservoir 8 Pump Station		4/6/2020	cdp	8.2	0.23	7.55	80	26.5	104	0.097	0.03	16	20	3.53	*	ND	
#11	West Side Res 146 Dupont St		4/7/2020	cdp	10.3	0.23	7.58	82	26.5	102	0.297	0.05	16	20	3.31		ND	