

The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM week Ending 5/6/20


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Handwritten Signature] Date: 5/6/20



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS													**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Address	Name #	Sample date	Tech	Temp. (°C)	Cond. (µS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)	
#14 (1)	Admiral Gas Station 3802 Dawson Rd.		6/6/2020	cdp	10.7	0.222	7.55	82	28.9	100	0.056	0.03	14	19	3.52	4/22/20	ND	
#16 (2)	Rite - Aid 2838 E Court St		6/1/2020	bp	10.8	0.222	7.67	82	28.9	100	0.057	0.03	14	19	3.51	4/17/20	ND	
#16 (2)	Rite - Aid 2838 E Court St		6/6/2020	cddp	10.7	0.23	7.61	80	28.9	100	0.106	0.04	16	19	3.48	*	ND	
#17 B (3)	Liquor Palace 3316 S dort hwy		6/6/2020	cddp	9.5	0.222	7.47	80	28.1	102	0.077	0.03	15	20	3.47	4/17/20	ND	
#17 (3)	Liquor Palace 3302 S. Dort Hwy		6/1/2020	bp	11.7	0.222	7.66	82	28.1	102	0.097	0.03	14	18	3.49	*	ND	
#4	Rite - Aid 3808 Cornuna Rd.		4/30/2020	cddp	9.3	0.23	7.50	80	28.1	100	0.084	0.02	14	17	3.49	4/16/20	ND	
#4	Rite - Aid 3808 Cornuna Rd.		6/4/2020	cddp	10.4	0.23	7.54	80	28.9	100	0.083	0.03	15	16	3.42	*	ND	
#1 (5)	University Market 1059 Chevrolet Ave.		4/30/2020	cddp	10.4	0.23	7.52	82	27.3	102	0.048	0.02	16	19	3.42	4/16/20	ND	
#1 (5)	University Market 1059 Chevrolet Ave.		6/4/2020	cddp	10.9	0.23	7.57	82	28.1	100	0.079	0.02	15	18	3.43	*	ND	
#19 (6)	3317 MLK Blvd.		5/1/2020	bp	12.5	0.222	7.62	82	28.1	100	0.066	0.02	14	17	3.49	4/17/20	ND	
#19 (6)	3317 MLK Blvd.		6/6/2020	cddp	12.9	0.23	7.62	80	29.7	104	0.094	0.04	15	18	3.47	*	ND	
#9 (7)	Rite-Aid 5018 Chie. Rd. 48504		5/5/2020	cddp	11.9	0.222	7.49	84	27.3	102	0.055	0.02	14	19	3.25	4/21/20	ND	
#8	6509 N. Saginaw St.		5/5/2020	cddp	10.8	0.222	7.62	80	27.3	98	0.07	0.02	15	16	3.82	4/21/20	ND	
CS11	Central Station #2 4500 N. Dort Hwy.		6/5/2020	cddp	8.3	0.222	7.38	82	28.1	104	0.091	0.01	15	16	1.21	4/21/20	ND	
#5 (CS)	Cedar Street Reservoir B Pump Station		4/30/2020	cddp	10.5	0.222	7.50	82	27.3	102	0.071	0.04	15	18	3.50	4/16/20	ND	
#5 (CS)	Cedar Street Reservoir B Pump Station		6/4/2020	cddp	9.9	0.222	7.61	82	27.3	100	0.083	0.02	15	17	3.31	*	ND	
#11	West Side Res 1418 Dupont St.		6/5/2020	cddp	12.5	0.23	7.47	82	28.9	100	0.246	0.04	16	19	3.37	4/21/20	ND	