



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWBM wk ending 6/3/2020

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature:  _____ Date: 6/3/2020



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										**PRIOR WEEK RESULTS				
Distribution System Location #	Sample Point Address	Name #	Sample date	Tech	Temp. (°F)	Cond. (µS)	pH	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Sample Date	Lead (µg/L Pb)
#16 (1)	Advanced Bas Station 3802 Durban Rd.		6/3/2020	cdp	14.5	0.24	7.49	84	28.1	100	0.070	0.02	14	21	3.46	6/20/20	6/6/20	ND
#16 (2)	Rte - M4 2333 E Court St		6/29/2020	bp	15.3	0.26	7.86	90	28.9	110	0.113	0.01	18	24	3.39	6/15/20	6/1/20	ND
#18 (2)	Rte - M4 2300 E Court St		6/3/2020	cdp	14.3	0.24	7.81	86	28.9	102	0.074	0.02	18	21	3.43			
#17 B (3)	Ligon Parkca 3263 S East Hwy		6/29/2020	bp	15.2	0.25	7.82	90	30.5	112	0.098	0.01	18	21	3.40	6/16/20	6/1/20	ND
#17 (3)	Ligon Parkca 3202 S East Hwy		6/3/2020	cdp	14.3	0.24	7.43	84	28.1	102	0.114	0.03	18	22	3.84			
#4	Rte - M4 3806 Durban Rd.		6/29/2020	cdp	13.7	0.26	7.39	88	30.5	109	0.113	0.02	17	23	3.46	6/14/20	4/30/20	ND
#1 (5)	University Heights 0081 Riverside Ave.		6/29/2020	cdp	15.1	0.26	7.46	92	31.3	109	0.099	0.03	17	20	3.34	6/14/20	4/30/20	ND
#1 (5)	University Heights 0081 Riverside Ave.		6/1/2020	cdp	15.2	0.25	7.55	86	28.9	104	0.103	0.00	16	17	3.34			
#18 (8)	327 ML Blvd.		6/29/2020	bp	16.8	0.26	7.55	92	30.5	110	0.102	0.02	17	23	3.37	6/15/20	6/1/20	ND
#18 (8)	327 ML Blvd.		6/3/2020	cdp	16.0	0.24	7.54	86	27.3	102	0.200	0.03	16	22	3.50			
#9 (7)	Rte - M4 5901 Dn Rd. 4551A		6/2/2020	cdp	14.9	0.24	7.35	82	28.1	100	0.334	0.02	15	20	3.83	6/19/20	6/5/20	ND
#8	6500 N. Saginaw St.		6/2/2020	cdp	12.9	0.23	7.26	80	26.5	104	0.314	0.01	15	20	3.72	6/19/20	6/15/20	ND
C391	Dexter Station #2 4300 N. East Hwy.		6/2/2020	cdp	12.0	0.22	7.35	80	28.9	105	0.093	0.00	16	19	1.32	6/19/20	6/5/20	ND
#5 (C3)	Dexter Street Reservoir B Pump Station		6/29/2020	cdp	12.0	0.26	7.20	88	30.5	106	0.120	0.02	16	20	3.49	6/14/20	4/30/20	ND
#5 (C3)	Cedar Street Reservoir B Pump Station		6/1/2020	cdp	13.7	0.24	7.88	86	28.1	104	0.103	0.01	16	17	3.47			
#11	West Side Bus Hub Depot St		6/2/2020	cdp	15.1	0.25	7.28	84	28.1	104	0.185	0.04	15	19	3.32	6/19/20	6/5/20	ND