



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM week ending 6/10/2020

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Signature] Date: 6/11/2020



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS												**PRIOR WEEK RESULTS	
System Location	Sample Point Address	Name B	Sample date	Teach	Temp. (°F)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)
#14 (1)	Admiral Gas Station 3802 Davison Rd.		6/10/2020	cdp	15.7	0.24	7.50	82	28.1	100	0.150	0.02	16	18	3.44	6/3/20	ND
#16 (2)	Rite - Aid 2838 E. Court St		6/6/2020	bp	16.8	0.24	7.61	86	28.1	102	0.080	0.02	16	18	3.45	5/29/20	ND
#16 (2)	Rite - Aid 2838 E. Court St		6/10/2020	cdp	14.7	0.24	7.46	82	27.3	102	0.099	0.01	14	16	3.59	*	
#17 B (3)	Liquor Palace 3265 S. Dort Hwy		6/6/2020	bp	15.2	0.24	7.62	84	28.1	102	0.113	0.03	15	20	3.51	6/29/20	ND
#17 (3)	Liquor Palace 3202 S. Dort Hwy		6/10/2020	cdp	14.5	0.24	7.48	84	28.1	96	0.122	0.01	15	18	3.52		
#4	Rite - Aid 3805 Caruma Rd.		6/4/2020	cdp	14.0	0.24	7.49	86	27.3	104	0.098	0.03	14	19	3.49	5/28/20	ND
#4	Rite - Aid 3505 Caruma Rd.		6/8/2020	cdp	15.2	0.24	7.48	88	28.9	106	0.108	0.01	15	18	3.37	*	
#1 (5)	University Market 1055 Chevrolet Ave.		6/4/2020	cdp	16.8	0.25	7.52	88	28.1	102	0.087	0.01	14	19	3.41	5/28/20	ND
#1 (5)	University Market 1055 Chevrolet Ave.		6/8/2020	cdp	16.7	0.24	7.49	86	28.1	102	0.271	0.07	16	21	3.37	*	
#18 (6)	3317 M.K. Blvd.		6/6/2020	bp	17.3	0.24	7.54	84	28.1	102	0.123	0.02	16	20	3.50	5/29/20	ND
#18 (6)	3317 M.K. Blvd.		6/10/2020	cdp	20.0	0.24	7.48	86	28.9	100	0.090	0.01	15	19	3.47	*	
#19 (7)	Rite-Aid 5008 Oak Rd. 48504		6/9/2020	cdp	16.1	0.24	7.36	86	28.9	102	0.059	0.02	15	14	3.37	6/2/20	ND
#8	6509 N. Saginaw St.		6/9/2020	cdp	13.5	0.24	7.42	84	28.9	100	0.051	0.00	14	18	3.46	6/2/20	ND
CSII	Central Station #2 4200 N. Dort Hwy.		6/9/2020	cdp	12.9	0.23	7.35	84	28.9	104	0.130	0.03	14	19	1.26	6/2/20	ND
#5 (CS)	Center Street Reservoir B Pump Station		6/4/2020	cdp	13.1	0.24	7.57	82	28.1	106	0.115	0.03	16	18	3.49	5/28/20	ND
#5 (CS)	Center Street Reservoir B Pump Station		6/8/2020	cdp	13.2	0.25	7.53	86	28.1	106	0.116	0.01	16	18	3.40	*	
#11	West Side Res 1416 Durant St		6/9/2020	cdp	15.3	0.24	7.23	84	28.1	104	0.159	0.04	15	18	3.24	6/2/20	ND