



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM wk ending 6/17/2020

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature:  _____ Date: 6/22/2020



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										**PRIOR WEEK RESULTS		
Destination System Location	Sample Point Address	Name	Sample date	Temp. (°F)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)
#14 (1)	Maxwell Base Station 3002 Dunwoody Rd.		6/17/2020	16.7	0.23	7.49	80	27.3	96	0.063	0.02	14	19	3.46	6/10/20	ND
#18 (2)	Roa - Mid 2838 E. Chant St		6/12/2020	18.0	0.24	7.45	84	28.9	104	0.086	0.02	16	20	3.66	6/5/20	ND
#18 (2)	Roa - Mid 2838 E. Chant St		6/17/2020	16.0	0.23	7.48	80	27.3	100	0.064	0.03	14	18	3.57		
#17 B (3)	Liquor Pitaka 3308 S. Dent Hwy		6/12/2020	14.8	0.24	7.40	84	28.1	102	0.082	0.03	14	18	3.47	6/6/20	ND
#17 (3)	Liquor Pitaka 3302 S. Dent Hwy		6/17/2020	15.6	0.23	7.48	78	27.3	96	0.094	0.02	14	17	3.50		
#4	Roa - Mid 3008 Dunwoody Rd.		6/11/2020	16.1	0.24	7.71	86	28.1	100	0.080	0.01	15	20	3.51	6/4/20	ND
#4	Roa - Mid 3008 Dunwoody Rd.		6/16/2020	16.9	0.23	7.41	82	28.1	100	0.062	0.02	15	16	3.42		
#1 (5)	University Market 1039 Chamblee Ave.		6/11/2020	16.8	0.24	7.67	84	28.1	106	0.102	0.04	16	20	3.49	6/4/20	ND
#1 (5)	University Market 1039 Chamblee Ave.		6/15/2020	16.2	0.24	7.42	80	28.9	102	0.057	0.02	15	13	3.35		
#18 (6)	3357 M.L.K. Blvd.		6/12/2020	16.8	0.24	7.33	82	28.1	104	0.068	0.03	14	18	3.44	6/5/20	ND
#18 (6)	3357 M.L.K. Blvd.		6/17/2020	20.6	0.23	7.57	80	26.5	98	0.063	0.03	14	19	3.43		
#19 (7)	Roa - Mid 5108 Dco Rd. 4850A		6/16/2020	17.1	0.23	7.42	80	26.5	98	0.055	0.01	15	19	3.31	6/9/20	ND
#3	BSOB K. Sapping Dr.		6/16/2020	14.6	0.22	7.52	80	26.1	100	0.054	0.01	14	17	3.56	6/9/20	ND
CS11	Concord Station #2 4500 N. Dent Hwy.		6/16/2020	13.8	0.21	7.36	82	27.3	100	0.066	0.02	14	15	1.18	6/9/20	ND
#5 (SS)	Concord Station Reservoir B Pump Station		6/11/2020	13.0	0.24	7.78	86	27.3	100	0.092	0.02	16	22	3.49	6/4/20	ND
#5 (SS)	Concord Station Reservoir B Pump Station		6/16/2020	13.9	0.23	7.20	82	28.1	100	0.063	0.03	16	16	3.40		
#11	Wood Dale Base 1481 Dunwoody St.		6/16/2020	16.3	0.23	7.28	82	28.1	100	0.193	0.04	15	23	3.37	6/9/20	ND