



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM WK ending 7/1/2020


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: *[Signature]* Date: 7/1/2020



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS												**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Address	Name & Address	Sample date	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)
#14 (I)	Admiral Ben Station 3302 Division Rd.		7/1/2020	cdp	18.7	0.23	7.48	78	27.3	100	0.074	0.01	14	16	3.48		ND
#16 (2)	Rita - Aid 2838 E Court St		7/1/2020	cdp	16.3	0.23	7.47	80	28.1	100	0.070	0.03	15	18	3.54		ND
#16 (2)	Rita - Aid 2838 E Court St		6/26/2020	cdp	17.2	0.23	7.59	80	28.1	98	0.068	0.01	15	20	3.29	*	
#17 B (3)	Liquor Palace 336 S Court Hwy		6/26/2020	cdp	17.1	0.23	7.59	80	28.1	100	0.120	0.01	15	19	3.33		ND
#17 (3)	Liquor Palace 3302 S Court Hwy		7/1/2020	cdp	17.3	0.25	7.44	78	27.3	98	0.080	0.02	14	17	3.44		
#4	Rita - Aid 3806 Barunna Rd.		6/26/2020	cdp	18.1	0.23	7.46	80	26.5	100	0.237	0.02	14	19	3.43		ND
#4	Rita - Aid 3806 Barunna Rd.		6/29/2020	cdp	18.7	0.23	7.43	80	27.3	98	0.062	0.02	14	18	3.41	*	
#1 (5)	University Market 1089 Chevrolet Ave.		6/25/2020	cdp	19.6	0.23	7.48	82	25.7	100	0.077	0.02	14	18	3.36		ND
#1 (5)	University Market 1089 Chevrolet Ave.		6/29/2020	cdp	19.5	0.23	7.47	80	26.5	100	0.090	0.02	14	17	3.34	*	
#19 (6)	3317 MLK Blvd.		6/26/2020	cdp	21.1	0.23	7.86	80	27.3	96	0.072	0.02	15	19	3.24		ND
#19 (6)	3317 MLK Blvd.		7/1/2020	cdp	22.7	0.23	7.21	78	26.5	100	0.097	0.03	14	16	3.43	*	
#9 (7)	Rita - Aid 5008 Elm Rd. 48504		6/30/2020	cdp	18.9	0.23	7.66	82	28.1	100	0.154	0.02	15	15	3.44		ND
#8	6509 N. Saginaw St.		6/30/2020	cdp	15.4	0.23	7.78	76	26.5	102	0.093	0.02	14	16	3.57		ND
CS11	Control Station #2 4500 N. Court Hwy.		6/30/2020	cdp	15.2	0.22	7.33	80	28.1	100	0.080	0.02	14	17	1.27		ND
#5 (CS)	Cedar Street Reservoir B Pump Station		6/25/2020	cdp	16.9	0.23	7.52	82	26.5	98	0.249	0.02	15	18	3.37		ND
#5 (CS)	Cedar Street Reservoir B Pump Station		6/29/2020	cdp	16.9	0.23	7.23	78	27.3	98	0.146	0.02	14	17	3.50	*	
#11	West Side Res 1406 Durant St		6/30/2020	cdp	18.8	0.23	7.31	80	27.3	100	0.250	0.04	15	19	3.43		ND