



**WEEKLY ENHANCED  
WATER QUALITY PARAMETER MONITORING**

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										
Distribution System Location #	Sample Point B Address	Name	Sample Week	Tech	Temperature (°F)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO <sub>3</sub> )	Calcium (mg/L Ca <sup>2+</sup> )	Hardness (mg/L CaCl <sub>2</sub> )	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl <sup>-</sup> )	Ortho phosphate (mg/L PO <sub>4</sub> )
#1	[REDACTED] Davidson Rd.	[REDACTED]	Jan. 31	SB / CB	12.4	0.02	7.34	74	32.1	100	0.081	0.05	11	3.20
#2	[REDACTED] Court St.	[REDACTED]	Jan. 31	SB / CB	13.2	0.02	7.32	72	32.9	98	0.103	0.05	12	3.85
#3	[REDACTED] S. Dort Hwy	[REDACTED]	Jan. 31	SB / CB	11.8	0.02	7.37	72	29.7	102	0.151	0.03	11	3.53
#4	[REDACTED] Zeebma Rd.	[REDACTED]	Jan. 31	SB / CB	9.9	0.02	7.41	74	30.5	98	0.244	0.06	12	3.61
#5	[REDACTED] Flushing Rd.	[REDACTED]	Jan. 31	SB / CB	9.2	0.02	7.31	71	29.7	96	0.222	0.06	11	3.65
#6	[REDACTED] ALK Blvd.	[REDACTED]	Jan. 31	SB / CB	16.4	0.02	7.45	74	32.1	100	0.093	0.03	11	3.42
#7	[REDACTED] Jino Rd. 48504	[REDACTED]	Jan. 31	SB / CB	12.6	0.02	7.38	73	31.3	100	0.104	0.03	12	3.65
#8	[REDACTED] K. Senglew St.	[REDACTED]	Jan. 31	SB / CB	14.8	0.02	7.31	72	31.3	100	0.087	0.03	11	3.70
#9	Central Station #2 45100 K. Dort Hwy.	[REDACTED]	Jan. 31	SB / CB	5.3	0.02	7.38	74	30.5	100	0.091	0.01	11	1.19
FS	Dexter Street Reservoir B Pump Station	[REDACTED]	Jan. 31	SB / CB	8.2	0.02	7.47	73	31.3	102	0.138	0.03	13	3.44
WS	West Side Reservoir B Pump Station	[REDACTED]	Jan. 31	SB / CB	7.1	0.02	7.42	72	31.3	102	0.308	0.07	12	3.78