



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM wk ending 2/3/21

~~_____

_____~~


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Handwritten Signature] Date: 2/4/21



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										**PRIOR WEEK RESULTS		
Distribution System Location #	Sample Point Name & Address	Sample date	Test	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)
#14 (1)	Admiral Base Station 3807 Deacon Rd.	2/3/2021	bp	8.0	0.23	7.45	80	28.9	100	0.093	0.04	16	19	3.43	1/27/21	ND
#16 (2)	Rtn - Ad 2838 E Court St	1/29/2021	cdp	6.0	0.22	7.44	80	28.9	100	0.068	0.00	14	17	3.31	1/22/21	ND
#16 (2)	Rtn - Ad 2838 E Court St	2/3/2021	bp	6.7	0.22	7.47	82	26.5	100	0.079	0.04	15	18	3.55		
#17 (3)	Liquor Palace 3302 S Court Hwy	1/29/2021	cdp	6.6	0.23	7.40	78	28.9	102	0.067	0.00	14	17	3.37	1/22/21	ND
#17 (3)	Liquor Palace 3302 S Court Hwy	2/3/2021	bp	6.6	0.23	7.44	84	27.3	102	0.071	0.04	15	18	3.64		
#4	Rtn - Ad 3808 Deacon Rd.	1/28/2021	cdp	6.4	0.22	7.47	80	30.5	100	0.066	0.02	14	17	3.46	1/21/21	ND
#4	Rtn - Ad 3808 Deacon Rd.	2/2/2021	bp	8.6	0.23	7.45	82	27.3	100	0.079	0.02	15	17	3.62		
#1 (5)	University Market 1853 Davinok Ave.	1/28/2021	cdp	6.2	0.22	7.46	76	28.9	102	0.156	0.02	15	18	3.54	1/21/21	ND
#1 (5)	University Market 1853 Davinok Ave.	2/1/2021	bp	6.2	0.22	7.31	80	27.3	100	0.178	0.02	14	18	3.75		
#18 B (6)	337 MLK Blvd.	1/29/2021	cdp	6.8	0.22	7.59	78	28.9	102	0.077	0.04	15	16	3.35	1/22/21	ND
#18 B (6)	337 MLK Blvd.	2/3/2021	bp	6.5	0.22	7.28	84	27.3	104	0.073	0.02	16	18	3.52		
#9 (7)	Rtn-Ad 5085 Ch. Rd. 46504	2/2/2021	bp	9.9	0.23	7.34	80	28.1	102	0.083	0.03	15	17	3.51	1/26/21	ND
#8	6505 N. Saginaw St.	2/2/2021	bp	6.2	0.23	7.54	78	28.1	102	0.051	0.03	14	17	3.44	1/26/21	ND
CSII	Central Station #2 4500 N. Court Hwy.	2/2/2021	bp	7.8	0.21	7.54	78	28.1	104	0.064	0.02	15	15	1.30	1/26/21	ND
#5 (CS)	Cedar Street Reservoir 8 Pump Station	1/28/2021	cdp	7.7	0.22	7.52	76	30.5	102	0.080	0.01	14	14	3.44	1/21/21	ND
#5 (CS)	Cedar Street Reservoir 8 Pump Station	2/1/2021	bp	7.0	0.22	7.48	80	27.3	102	0.081	0.00	14	16	3.52		
#11	West Side Pies 1465 Durant St	2/2/2021	bp	7.6	0.22	7.60	82	28.1	102	0.057	0.01	15	18	3.50	1/26/21	ND