



## WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										
Distribution System Location #	Sample Point & Address	Name	Sample Week	Tech	Temperature (°C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO <sub>3</sub> )	Calcium (mg/L Ca <sup>2+</sup> )	Hardness (mg/L CaCO <sub>3</sub> )	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl <sup>-</sup> )	Ortho phosphate (mg/L PO <sub>4</sub> )
#1	Davison Rd.		Feb. 07	SB / CB	11.0	18	7.21	72	33.7	102	0.112	0.03	15	3.52
#2	E Court St		Feb. 07	SB / CB	11.7	18	7.32	72	34.5	98	0.121	0.03	14	3.64
#3	Dart Hwy	S.	Feb. 07	SB / CB	11.3	18	7.23	72	34.5	98	0.149	0.03	14	3.65
#4	Corunna Rd.		Feb. 07	SB / CB	10.2	18	7.31	70	35.3	98	0.167	0.05	15	3.57
#5	Flushing Rd.		Feb. 07	SB / CB	7.7	17	7.30	72	35.3	102	0.201	0.14	15	3.65
#6	MLK Blvd.		Feb. 07	SB / CB	13.5	19	7.29	70	39.3	100	0.137	0.04	14	3.26
#7	Clio Rd. 48504		Feb. 07	SB / CB	12.6	19	7.38	72	37.7	100	*0.360	0.09	15	3.76
#8	N. Saginaw St.		Feb. 07	SB / CB	15.1	18	7.31	72	32.1	98	*0.681	0.17	15	3.07
#9	N. Dart Hwy.		Feb. 07	SB / CB	5.4	21	7.31	70	32.9	100	0.068	0.02	13	1.21
CS	Cedar Street Reservoir & Pump Station		Feb. 07	SB / CB	6.8	17	7.32	72	33.7	100	0.177	0.08	14	3.60
WS	West Side Reservoir & Pump Station		Feb. 07	SB / CB	7.9	19	7.38	72	32.9	102	0.168	0.03	15	3.61

\* Turbidities were taken after supply was restored from main break.