



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EW DM week ending 9/9/2020


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Signature] Date: 9/10/2020



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Name & Address	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Hardness (mg/L CaCO ₃)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Sulfate mg/L	Phosphate (mg/L PO ₄)	Sample date	Lead (µg/L Pb)
#14 (1)	Admiral Gas Station 3802 Davison Rd.	cdp	22.0	0.23	7.64	80	27.3	104	0.047	0.00	15	17	3.40	9/2/20	ND
#16 (2)	Rite - Aid 2838 E Court St	cdp	22.1	0.23	7.57	80	27.3	102	0.077	0.01	15	16	3.57	8/28/20	ND
#16 (2)	Rite - Aid 2838 E Court St	cdp	22.2	0.23	7.69	78	28.9	100	0.076	0.01	14	16	3.42	*	
#17 B (3)	Liquor Palace 3306 S. Court Hwy	cdp	22.4	0.23	7.59	80	26.5	100	0.064	0.01	14	19	3.41	8/28/20	ND
#17 (3)	Liquor Palace 3302 S. Court Hwy	cdp	21.7	0.23	7.50	78	28.9	102	0.086	0.00	15	18	3.40		
#4	Rite - Aid 3806 Cornum Rd.	cdp	22.6	0.23	7.55	78	28.9	96	0.079	0.01	14	17	3.31	8/27/20	ND
#4	Rite - Aid 3806 Cornum Rd.	cdp	22.3	0.23	7.53	80	28.1	102	0.067	0.04	15	18	3.36	*	
#1 (5)	University Market 1059 Chevrolet Ave.	cdp	23.5	0.23	7.60	78	26.5	96	0.111	0.03	15	17	3.42	8/27/20	ND
#1 (5)	University Market 1059 Chevrolet Ave.	cdp	22.9	0.23	7.56	78	29.7	100	0.064	0.01	16	18	3.27	*	
#19 (6)	337 MIL Blvd.	cdp	24.2	0.23	7.53	80	26.5	102	0.074	0.02	15	16	3.44	8/28/20	1
#19 (6)	337 MIL Blvd.	cdp	23.8	0.23	7.64	80	28.1	104	0.139	0.01	15	17	3.36	*	
#9 (7)	Rite-Aid 5018 Ohio Rd. 48504	cdp	22.5	0.23	7.50	80	28.1	98	0.084	0.01	15	17	3.27	9/1/20	ND
#8	6508 N. Saginaw St.	cdp	20.2	0.23	7.84	80	28.9	102	0.090	0.01	15	18	3.68	9/1/20	ND
CSII	Control Station #2 4500 N. Dort Hwy.	cdp	21.2	0.23	7.28	78	28.9	104	0.103	0.01	15	12	1.23	9/1/20	ND
#5 (CS)	Cedar Street Reservoir & Pump Station	cdp	22.0	0.23	7.69	78	27.3	102	0.150	0.01	15	17	3.43	8/27/20	ND
#5 (CS)	Cedar Street Reservoir & Pump Station	cdp	21.6	0.23	7.69	78	28.9	98	0.119	0.01	15	17	3.33	*	
#11	West Side Res 1406 Dupont St	cdp	21.3	0.24	7.88	78	28.9	102	0.087	0.02	16	17	3.37	9/1/20	ND