



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

FWDM WK ending
10/7/2020


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Signature] Date: 10/8/2020



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										**PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Name & Address	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Hardness (mg/L CaCO ₃)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Sulfate mg/L	Phosphate (mg/L PO ₄)	Sample date	Lead (µg/L Pb)
#14 (1)	Admiral Gas Station 3802 Davison Rd.	cdp	19.1	0.23	7.40	82	28.1	98	0.085	0.01	14	19	3.43	9/30/20	ND
#16 (2)	Rite-Aid 2838 E Court St	bp	18.2	0.23	7.63	82	28.1	100	0.072	0.04	15	16	3.55	9/25/20	ND
#16 (2)	Rite-Aid 2838 E Court St	cdp	18.5	0.23	7.43	80	27.3	98	0.140	0.03	14	14	3.49	*	
#17 (3)	Liquor Palace 3302 S. Dort Hwy	bp	18.1	0.23	7.69	80	27.3	100	0.084	0.01	16	17	3.67	9/25/20	ND
#17 (3)	Liquor Palace 3302 S. Dort Hwy	cdp	17.3	0.23	7.51	80	28.1	100	0.103	0.02	14	18	3.40		
#4	Rite-Aid 3808 Conemaugh Rd.	cdp	20.0	0.23	7.47	78	27.3	96	0.076	0.03	14	18	3.51	9/24/20	ND
#4	Rite-Aid 3808 Conemaugh Rd.	cdp	19.1	0.23	7.47	78	27.3	96	0.124	0.02	16	18	3.40	*	
#1 (5)	University Market 1059 Chevrolet Ave.	bp	20.6	0.23	7.46	80	26.5	100	0.084	0.01	13	16	3.43	9/24/20	ND
#1 (5)	University Market 1059 Chevrolet Ave.	cdp	19.7	0.23	7.51	80	27.3	96	0.148	0.03	15	17	3.46	*	
#19 B (6)	3377 MLV Blvd.	bp	21.0	0.23	7.53	80	28.1	102	0.060	0.00	15	15	3.60	9/25/20	ND
#19 B (6)	3377 MLV Blvd.	cdp	20.1	0.23	7.50	80	26.5	100	0.085	0.03	14	17	3.37	*	
#8 (7)	Rite-Aid 5008 Chlo Rd. 48504	cdp	20.3	0.23	7.60	80	28.1	100	0.120	0.01	15	18	3.37	9/29/20	ND
#8	6509 N. Saginaw St.	cdp	17.3	0.23	7.68	80	28.1	102	0.105	0.01	15	18	3.59	9/29/20	ND
CSII	Control Station #2 4500 N. Dort Hwy.	cdp	16.3	0.22	7.30	78	29.7	100	0.103	0.01	14	19	1.24	9/29/20	ND
#5 (CS)	Cedar Street Reservoir B Pump Station	cdp	19.4	0.23	7.56	80	26.5	100	0.107	0.01	14	17	3.52	9/24/20	ND
#5 (CS)	Cedar Street Reservoir B Pump Station	cdp	18.7	0.23	7.57	80	26.5	98	0.109	0.02	15	21	3.44	*	
#11	West Side Res 146 Dupont St	cdp	18.4	0.23	7.87	80	27.3	102	0.087	0.02	15	18	3.41	9/29/20	ND