



The City of Flint and F&V Operations and Resource Management are submitting the following report(s) to Michigan Department of Environment, Great Lakes and Energy:

EWDM WK ending 11/11/2020


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons or persons who manage the system or those persons directly responsible for gathering such information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Flint Representative: _____

Signature: _____ Date: _____

F&V Operations Representative: Robert Jones _____

Signature: [Signature] Date: 11/11/2020



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										**PRIOR WEEK RESULTS			
Distribution System Location #	Sample Point Address	Name B	Sample date	Tech	Temp. (°C)	Cond. (mS)	pH (su)	Total Alkalinity (mg/L CaCO3)	Calcium (mg/L Ca2+)	Hardness (mg/L CaCO3)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl-)	Sulfate mg/L	Phosphate (mg/L PO4)	Sample date	Lead (µg/L Pb)
#14 (I)	Admiral Gas Station 3802 Davison Rd.		11/11/2020	cdp	15.4	0.22	7.58	82	28.9	100	0.062	0.03	14	14	3.33		NID
#16 (2)	Rte - Aid 2838 E Court St		11/6/2020	bp	14.7	0.23	7.70	82	28.1	102	0.071	0.04	15	16	3.46		NID
#16 (2)	Rte - Aid 2838 E Court St		11/11/2020	cdp	14.3	0.23	7.57	82	28.9	98	0.060	0.02	13	15	3.33	*	
#17 (3)	Liquor Palace 3302 S Court Hwy		11/6/2020	bp	14.5	0.22	7.78	82	28.1	100	0.088	0.01	14	14	3.48		NID
#17 (3)	Liquor Palace 3302 S Court Hwy		11/11/2020	cdp	13.9	0.22	7.57	78	27.3	98	0.097	0.03	13	15	3.32		
#4	Rte - Aid 3605 Couronne Rd.		11/5/2020	cdp	14.7	0.23	7.64	78	28.9	100	0.103	0.02	14	13	3.45		NID
#4	Rte - Aid 3605 Couronne Rd.		11/9/2020	cdp	14.5	0.23	7.68	82	29.7	100	0.112	0.00	14	17	3.36	*	
#1 (5)	University Market 1069 Chevrolet Ave.		11/5/2020	cdp	14.8	0.23	7.68	80	28.9	100	0.101	0.01	14	16	3.55		NID
#1 (5)	University Market 1069 Chevrolet Ave.		11/9/2020	cdp	14.9	0.23	7.66	80	28.1	100	0.120	0.04	14	15	3.41	*	
#19 B (6)	3397 MLK Blvd.		11/6/2020	bp	15.7	0.23	7.62	80	28.1	100	0.067	0.02	15	15	3.41		NID
#19 B (6)	3397 MLK Blvd.		11/11/2020	cdp	15.7	0.23	7.54	80	28.1	100	0.069	0.02	15	15	3.27	*	
#9 (7)	Rte-Aid 5008 Dia Rd. 48504		11/10/2020	cdp	17.0	0.23	7.77	78	29.7	98	0.055	0.02	13	15	3.34		NID
#8	6503 N. Saginaw St.		11/10/2020	cdp	14.2	0.22	7.89	78	29.7	100	0.085	0.00	14	14	3.34		NID
CSII	Central Station #2 4500 N. Dort Hwy.		11/10/2020	cdp	14.5	0.22	7.33	78	29.7	100	0.117	0.03	13	15	4.29		NID
#5 (CS)	Calder Street Reservoir B Pump Station		11/5/2020	cdp	15.7	0.23	7.83	82	28.1	96	0.098	0.01	15	14	3.48		NID
#5 (CS)	Calder Street Reservoir B Pump Station		11/9/2020	cdp	14.7	0.23	7.88	80	28.1	98	0.101	0.02	14	15	3.45	*	
#11	West Side Res 146 Dupont St		11/10/2020	cdp	14.8	0.23	7.89	80	28.1	98	0.062	0.03	14	15	3.37		NID