

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Fibrebond Corporation 1300 Davenport Drive PO Box 5001 Minden, LA 71055	COMPLIANCE ASSURANCE PROGRAM NO.:
	251
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104612
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: D-9163 11'6" x 29'5.5" x 9'0" Equipment Shelter			
USE GROUP: S2	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 0 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 105 PSF	FLOOR LIVE LOAD: 150 PSF	GROUND SNOW LOAD: 80 PSF	
WIND SPEED: 150 MPH	ROOF DEAD LOAD: 45 PSF	FLOOR DEAD LOAD: 35 PSF	HEATING DEGREE DAYS: 6232

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 28, 2013

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 1, 2013

cc: Professional Service Industries Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI Inc 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.:
	416
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104725
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: LLC 1252 27'-4" x 50'-0" with Crawlspace			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:	GROUND SNOW LOAD:	
29.6/ 44.4 PSF	40 PSF	50/ 75 PSF	
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	7700

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 26, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 28, 2013

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI Inc 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.:
	416
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104760
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: VSC 8589 27'-4"x44'-0"+8'-3" Porch with Basement			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:	GROUND SNOW LOAD:	
29.6/ 44.4 PSF	40 PSF	50/ 75 PSF	
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	6404

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 26, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 28, 2013

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Skyline Lancaster Highway 61 NE PO Box 590 Lancaster, WI 53813	COMPLIANCE ASSURANCE PROGRAM NO.:
	481
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104735
	TYPE OF APPROVAL:
	New System


DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: SA225-MS Ranch with Basement			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:	GROUND SNOW LOAD:	
53.9 PSF	40 PSF	70 PSF	
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	15 PSF	10 PSF	9021

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
LIMITATIONS OF APPROVAL (IF ANY) *The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured: HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.			

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 26, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 28, 2013

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: VFP Inc 402 Industrial Park Road PO Box 446 Duffield, VA 24244	COMPLIANCE ASSURANCE PROGRAM NO.: 457
	BUILDING SYSTEM APPROVAL REPORT NO.: 104373
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model #4505 11'-6"x20'-0"x9'-0" Concrete Shelter with Various Options			
USE GROUP: S2	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 105 PSF	FLOOR LIVE LOAD: 150 PSF	GROUND SNOW LOAD: 100 PSF	
WIND SPEED: 150 MPH	ROOF DEAD LOAD: 60 PSF	FLOOR DEAD LOAD: 38 PSF	HEATING DEGREE DAYS: 7200-9000

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------

LIMITATIONS OF APPROVAL (IF ANY) "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
March 26, 2013

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
March 28, 2013

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: VFP Inc 402 Industrial Park Road PO Box 446 Duffield, VA 24244	COMPLIANCE ASSURANCE PROGRAM NO.: 457
	BUILDING SYSTEM APPROVAL REPORT NO.: 104372
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model #4507 11'-6"x26'-6"x9'-0" Concrete Shelter with Various Options			
USE GROUP: S2	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 100 PSF	FLOOR LIVE LOAD: 150 PSF	GROUND SNOW LOAD: 100 PSF	
WIND SPEED: 150 MPH	ROOF DEAD LOAD: 60 PSF	FLOOR DEAD LOAD: 38 PSF	HEATING DEGREE DAYS: 7200-9000

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
----------------------------	------------------------------	------------------------------	-------------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 26, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 28, 2013

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: VFP Inc 402 Industrial Park Road PO Box 446 Duffield, VA 24244	COMPLIANCE ASSURANCE PROGRAM NO.: 457
	BUILDING SYSTEM APPROVAL REPORT NO.: 104371
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model #450811'-6"x30'-0"x9'-" Concrete Shelter w/Gen Room with Various Options			
USE GROUP: S2	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 100 PSF	FLOOR LIVE LOAD: 150 PSF	GROUND SNOW LOAD: 100 PSF	
WIND SPEED: 150 MPH	ROOF DEAD LOAD: 60 PSF	FLOOR DEAD LOAD: 38 PSF	HEATING DEGREE DAYS: 7200-9000

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------


LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:
March 26, 2013

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
March 28, 2013

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Commodore Corporation, The 1902 Century Drive PO Box 729 Goshen, IN 46526	COMPLIANCE ASSURANCE PROGRAM NO.:
	395
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104736
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: RG838-A28 30'-0"x64'-0" Ranch with Crawlspace			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:	GROUND SNOW LOAD:	
30.8 PSF	40 PSF	40 PSF	
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	8999


APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:



 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

March 28, 2013

AGENCY OFFICIAL:



 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 1, 2013

cc: RADCO

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI Inc 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.:
	416
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104751
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: HR 4139-1 Ranch 29'-11" x 48'-0" with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 57.8 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 75 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7064

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 21, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 26, 2013

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mark Line Industries 51687 CR 133 PO Box 277 Bristol, IN 46507	COMPLIANCE ASSURANCE PROGRAM NO.:
	160
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104678
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: 4860 S Plex			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 26 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF	FLOOR LIVE LOAD: 50 PSF		GROUND SNOW LOAD: 55 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 7 PSF	HEATING DEGREE DAYS: 6975

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

ISSUED DATE:

March 19, 2013

PUBLISHED DATE:

March 21, 2013

cc: TR Arnold & Associates Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mark Line Industries 51687 CR 133 PO Box 277 Bristol, IN 46507	COMPLIANCE ASSURANCE PROGRAM NO.:
	160
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104677
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 6060 S-Plex			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 30 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF	FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 55 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 7 PSF	HEATING DEGREE DAYS: 6975

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
March 19, 2013

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
March 21, 2013

cc: TR Arnold & Associates Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Fairmont Homes Inc 502 S Oakland - Plant 2 PO Box 27 Nappanee, IN 46550	COMPLIANCE ASSURANCE PROGRAM NO.: 451
	BUILDING SYSTEM APPROVAL REPORT NO.: 104704
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model 92574 - 2009 MRC with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 53.9 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 70 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 20 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 9316

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION


REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

March 14, 2013

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

March 18, 2013

cc: RADCO

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	COMPLIANCE ASSURANCE PROGRAM NO.:
	167
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104689
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: 6815-MI-01 Ranch 30'-0"x72'-0" with Crawlspace			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 53.9 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 70 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 9316

APPLICABLE STATE CODES


Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 14, 2013

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 18, 2013

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Whitley Manufacturing Co Inc. 201 W First Street PO Box 496 South Whitley, IN 46787	COMPLIANCE ASSURANCE PROGRAM NO.: 241
	BUILDING SYSTEM APPROVAL REPORT NO.: 104469
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model#6959 (11) Classroom / (17) module Building			
USE GROUP: E	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 330 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 25 PSF		FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 25 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6580

APPLICABLE STATE CODES

Building -- 2009 MBC	Electrical -- 2008 NEC	Mechanical -- 2009 MMC	Plumbing -- 2009 MPC
-----------------------------	-------------------------------	-------------------------------	-----------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured'
This building system does not include the required automatic sprinkler system, site constructed masonry wall component and crawlspace foundation and piers.

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
March 13, 2013

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
March 15, 2013

cc: TR Arnold & Associates Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Rochester Homes Inc 1345 N Lucas Street PO Box 587 Rochester, IN 46975	COMPLIANCE ASSURANCE PROGRAM NO.:
	128
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104680
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: ER-7 Ranch 37'4"x62'2" with Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 53.9 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7573

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 13, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 15, 2013

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI Inc 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.:
	416
	BUILDING SYSTEM APPROVAL REPORT NO.:
	104679
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL:			
VST 8688 Two and a Half Story 27'-4"x46'-0" with Basement			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:	GROUND SNOW LOAD:	
29.6 PSF	40 PSF	50 PSF	
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	6404

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 13, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 15, 2013

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Dickinson Homes Inc 1500 W Breitung Avenue PO Box 2245 Kingsford, MI 49802	COMPLIANCE ASSURANCE PROGRAM NO.: 123
	BUILDING SYSTEM APPROVAL REPORT NO.: 104569
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 4MODPROWRB10 with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 46.2 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 60 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 9316

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 12, 2013

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 14, 2013

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ventaire LLC - Sagebrush Bldg Sys LLC 909 N Wheeling Avenue Tulsa, OK 74110	COMPLIANCE ASSURANCE PROGRAM NO.: 491
	BUILDING SYSTEM APPROVAL REPORT NO.: 104543
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Fuel Kiosk			
USE GROUP: B	CONSTRUCTION TYPE: IIB	OCCUPANT LOAD: 8 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF	FLOOR LIVE LOAD: 100 PSF	GROUND SNOW LOAD: 45 PSF	
WIND SPEED: 100 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 35 PSF	HEATING DEGREE DAYS: 6359

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 March 12, 2013

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 March 14, 2013

cc: PFS Corporation