



DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS

DIRECTOR'S OFFICE

CONSTRUCTION SAFETY STANDARDS

Filed with the Secretary of State on August 31, 1976 (as amended March 6, 1981)
(as amended September 3, 1996) (as amended December 27, 2000) **(as amended March 14, 2013)**

These rules become effective immediately upon filing with the Secretary of State
unless adopted under section 33, 44, or 45a(6) of 1969 PA 306.

Rules adopted under these sections become effective 7 days after filing with the Secretary of State.

(By authority conferred on the director of the department of licensing and regulatory affairs
by sections 19 and 21 of 1974 PA 154, and Executive Reorganization Order Nos. 1996-2, 2003-1, 2008-4,
and 2011-4, MCL 445.2001, 445.2011, 445.2025, and 445.2030)

R 408.42031, R 408.42034, R 408.42041, R 408.42043, R 408.42045, R 408.42046,
and R 408.42047 of the Michigan Administrative Code are amended as follows:

**CONSTRUCTION SAFETY AND HEALTH STANDARD
PART 20. DEMOLITION**

Table of Contents:

R 408.42001 Scope.....	1	R 408.42043 Removal of structural steel.....	3
R 408.42023 Definitions.....	1	R 408.42044 Manual removal of ceiling and floor systems.....	3
R 408.42031 Demolition generally.....	1	R 408.42045 Mechanical demolition.....	3
R 408.42032 Guarding floor and wall openings.....	2	R 408.42046 Demolition by use of explosives.....	3
R 408.42033 Means of egress.....	2	R 408.42047 Storage of debris.....	4
R 408.42034 Material chutes and drops.....	2		
R 408.42041 Removal of chimneys, stacks, and walls. .	3		

R 408.42001 Scope.

Rule 2001. This part pertains to the demolition of structures by manual or mechanical means and to the safeguarding of the employees in this operation.

R 408.42023 Definitions.

Rule 2023. (1) "Balling" means to demolish by mechanically swinging a weighted ball.

(2) "Clamming" means to demolish by use of a clam bucket.

(3) "Competent person" means a person who is experienced and capable of identifying an existing or potential hazard in surroundings, or under working conditions, that are hazardous or dangerous to an employee and who has the authority and knowledge to take prompt corrective measures to eliminate the hazards.

(4) "Demolition" means to dismantle, tear down, or raze.

(5) "Hazardous substance" means a substance that is toxic, corrosive, a strong sensitizer, flammable, or explosive.

(6) "Manual demolition" means stripping or demolition by hand labor.

(7) "Mechanical demolition" means demolition by powered equipment other than hand-held tools.

R 408.42031 Demolition generally.

Rule 2031. (1) Before the start of a demolition operation, an employer shall ensure that all of the following are done:

(a) An engineering survey of the structure and equipment is conducted by a competent person knowledgeable in demolition to determine all of the following:

(i) The condition of the foundation, roof, walls, and floors.

(ii) Whether any adjacent structure will be affected by the demolition.

(iii) The utility service entering the building.

(iv) Any other conditions and equipment affecting the safety of an employee.

(b) An employer shall ensure that there is a written report of the survey at the field office until the completion of the job. The report shall include information such as the name of the person conducting the survey, date of the survey, and hazardous substances and dangerous conditions found and their location.

In an emergency situation, a survey is not required. If a field office does not exist at the demolition site, then an employer shall file the written report of the survey at the employer's main office.

(c) An employer shall inform utility companies of the planned demolition. An employer shall ensure that utility services are shut off, capped, or otherwise protected from damage, except as specified in subrule (2) of this rule.

(d) An employer shall ensure that glazed sash and doors and other glass that might cause an injury shall be protected or removed before demolition starts.

(2) If an employee is required to work in a structure that has been damaged by fire, flood, or explosion, then an employer shall ensure that the affected walls and floors are shored or braced before manual demolition starts.

(3) If an area or item, such as a pipe, tank, or bin, is known or suspected to contain a hazardous substance, then an employer shall ensure that testing is performed and the hazard eliminated before demolition is permitted to begin.

(4) An employer shall ensure that manual demolition of structural components starts at the top of the structure and proceeds downward so that each level is completely dropped before the next lower wall and floor is dropped, except that if a connection portion is a different level, then that portion may be removed first. This requirement does not prohibit the cutting of a floor for the removal of materials if the requirements of R 408.42044 are complied with.

(5) An employer shall ensure that an employee shall not be exposed to weather conditions during demolition work if weather conditions constitute a hazard.

(6) During manual demolition of a structure of skeleton steel construction, the steel framing may be left in place, but an employer shall ensure that all structural supports are cleared of loose material as the demolition proceeds downward.

(7) An employer shall ensure that an employee is not permitted to work on a floor below a floor opening when demolition is conducted on the upper level, unless the employee is protected by a solid barricade not less than 42 inches high and located not less than 6 feet back from the projected edge of the opening above.

(8) During demolition, an employer or his or her designated representative shall make daily inspections to detect hazards and unsafe conditions. An employer shall ensure that an employee is not permitted to work

where hazards exist until the hazards are corrected by shoring, bracing, or other effective means.

R 408.42032 Guarding floor and wall openings.

Rule 2032. The provisions of Part 45. Fall Protection, being R 408.44501 et seq. of the Michigan Administrative Code, shall be complied with for all portions of the structure where there is employee exposure to the conditions covered by that part.

R 408.42033 Means of egress.

Rule 2033. (1) When an employee is required to be inside a structure being demolished, only a means of egress designated by the employer shall be used and maintained. All other means of egress shall be closed off.

(2) The means of egress shall be free of hazards. During manual demolition, the means of egress shall be supplied with an illumination intensity of not less than 10 candlepower.

(3) A means of egress shall be guarded to protect an employee from falling material.

(4) An employee entrance to a multistory structure to be demolished shall be protected by a roof canopy for a distance of not less than 8 feet from the structure. The canopy shall be not less than 1 foot wider on each side than the entrance and shall be capable of sustaining a load of 150 pounds per square foot.

R 408.42034 Material chutes and drops.

Rule 2034. (1) The area onto and through which material is to be dropped shall be completely enclosed with barricades not less than 42 inches high and not less than 6 feet back from the opening and the area receiving the material. Signs warning of the hazard of falling materials shall be posted on the barricades at each level containing the barricades.

(2) Where material is dropped through more than 1 level, the opening shall be enclosed between the upper and lower levels, an enclosed chute shall be provided, or the intermediate levels shall be barricaded as prescribed in subrule (1) of this rule. If the drop is more than 40 feet inside the building, only an enclosed opening or chute shall be used. The chute or enclosure shall extend through the ceiling of the receiving level.

(3) A material chute shall be constructed to withstand any impact load imposed on it without failure.

(4) A material chute, or section thereof, at an angle of more than 45 degrees from the horizontal shall be entirely enclosed, except for an opening equipped with a closure at or about each floor level for insertion of materials. The opening shall not be more than 48 inches in height measured along the wall of the chute. At all stories below the top floor, the openings shall be kept closed when not in use. The chute shall fit the floor or wall opening or the open space shall be closed.

(5) Where material is dumped from mechanical equipment or a wheelbarrow, a toeboard or bumper not less than 4 inches thick by 6 inches high nominal size

secured to the floor shall be provided at each material chute opening.

R 408.42041 Removal of chimneys, stacks, and walls.

Rule 2041. (1) During manual demolition, a wall or ceiling shall not be permitted to fall on a floor of a building unless the floor is capable of sustaining the impact.

(2) A chimney, stack, or wall shall not be permitted to stand alone without lateral bracing unless it can withstand the force of the wind and other uncontrolled forces. A chimney, stack, or wall shall be left in a stable condition at the end of each shift.

(3) During manual demolition, a wall serving as a retaining wall to support earth shall not be demolished until the load against the wall has been removed.

(4) A wall serving as a retaining wall for debris shall be capable of supporting the imposed load.

(5) A wall serving as a bearing wall for an adjoining structure shall not be demolished until the adjoining structure has been underpinned.

(6) Safety access to and from the top of the chimney or stack shall be provided during manual demolition.

R 408.42043 Removal of structural steel.

Rule 2043. (1) During manual demolition, structural steel shall be removed column length by column length and tier by tier without overstressing any member.

(2) Structural steel members shall be lowered from an upper level by mechanical means.

R 408.42044 Manual removal of ceiling and floor systems.

Rule 2044. (1) A floor upon or above which an employee is working and which will be weakened by manual demolition shall be shored to support the intended load.

(2) An opening that is cut into a floor for disposal of materials shall not be more than 25% of the total floor area, unless the lateral supports of the removed flooring remain in place.

(3) An opening that is cut into a floor shall extend the full span of the floor between supports.

(4) Before a floor is demolished, debris and other material shall be removed from the area and adjacent areas for a distance of not less than 20 feet.

(5) Before demolishing a floor arch, debris and other material shall be removed from the arch and other adjacent floor area. Planks that are not less than 2 inches by 10 inches in cross section, full size undressed, shall be provided for, and used by, an employee to stand on while breaking down a floor arch between beams. The planks shall be located so as to provide a safe support for the workmen if the arch between the beams collapses. The open space between planks shall not be more than 16 inches.

(6) A safe walkway, not less than 18 inches wide, formed of planks not less than 2 inches thick if wood, or of equivalent strength if metal, shall be provided for, and used by, employees when necessary to enable them to reach any point without walking upon exposed beams.

(7) Planks shall be laid together over solid bearings with the ends overlapping at least 1 foot.

(8) A floor arch to an elevation of not more than 25 feet above grade may be removed to provide storage area for debris, if the removal does not endanger the stability of the structure.

R 408.42045 Mechanical demolition.

Rule 2045. (1) Mechanical equipment shall not be used on a floor or other working surface unless the floor or surface is capable of supporting the imposed load of the equipment and the anticipated material loads.

(2) Equipment used in mechanical demolition shall comply with both of the following:

(a) Only be operated by a qualified and authorized employee.

(b) Meets the requirements prescribed in the applicable rules of Part 10. Lifting and Digging Equipment, and Part 13. Mobile Equipment, R 408.41001 et seq. and R 408.41301 et seq. of the Michigan Administrative Code.

(3) A floor or wall opening shall have curbs or stop logs, as prescribed in R 408.42034 to prevent mechanical equipment from running over the edge.

(4) Only those employees necessary to the operation of mechanical demolition equipment shall be permitted in the demolition area at any time.

(5) The weight of a demolition ball shall not be more than 50% of the crane's rated load based on the boom length and the maximum angle of operation that the ball will be used, or the weight shall not be more than 25% of the nominal breaking strength of the line and connection by which it is suspended, whichever is the lesser.

(6) The crane boom and load line shall be as short as possible to accomplish the job.

(7) The ball shall be positively connected to the load line with a swivel connector to prevent accidental disconnection and to prevent twisting of the line.

(8) Roof cornices and other ornamental stonework shall be removed before pulling a wall over, except when balling or clamming.

R 408.42046 Demolition by use of explosives.

Rule 2046. Explosives handled, transported, stored, and used in demolition shall be as prescribed in General Industry Safety Standard Part 27. Blasting and Use of Explosives, R 408.42701 et seq. of the Michigan Administrative Code.

R 408.42047 Storage of debris.

Rule 2047. (1) Storage of debris or salvaged material on a floor shall not exceed the allowable floor load.

(2) Storage space into which material is placed shall be blocked off by a barricade or wall when hazardous to an employee, except for an opening used to place or remove the material. The opening to the storage space shall be kept closed at all times when not in use.

(3) In a building having wooden floor construction, the flooring boards may be removed from not more than 1 floor above grade to provide storage space for debris, if falling material is not permitted to endanger the stability of the structure.



Michigan Occupational Safety and Health Administration
PO Box 30643
Lansing, Michigan 48909-8143

For technical questions of this standard – Ph: 517-284-7680 (CSDH) or 517-284-7720 (CETD)
To order copies of this standard – Ph: 517-284-7740

The Department of Labor and Economic Opportunity will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, disability, or political beliefs. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.