

M-20 @ Schrader Creek Design Build Project

Question & Answers #3

(Q) Who will be the selection committee scoring the SOQ's and what areas of MDOT will they be from (TSC, Region, Central)?

(A) As the PM, I will be on the selection team. The other members of the selection team have not yet been identified. However, the selection team will consist of a cross-section including design, construction and specialty areas. Also based on this project being a design build project a member of the CSRT group will also be on the team.

(Q) Will that selection team be the same for both phases of the selection process?

(A) If there is a need for scoring at the RFQ and RFP stages, we try to keep the scoring team the same as much as possible, but we cannot commit that it will be the same due to scheduling conflicts and other potential issues.

(Q) Soil boring logs in the RFQ for B-34, B-35 and B-36 indicate artesian head in the groundwater observations at these locations. At both B-34 and B-36, the level of pressure is indicated in feet of head above ground surface. This is not provided for B-35. Is it available?

(A) Two sets of three monitoring wells were installed at borings B-34 and B-36. There are some additional observations noted under the Groundwater Observation section of the Geotechnical Summary Letter found in the RID. We do not have actual piezometer readings at B-35.